



Slovenski institut za  
kakovost in meroslovje  
Slovenian Institute of  
Quality and Metrology

# Poročilo o preskusu / Test Report

Št. / No.:

T211-0469/12

Datum / Date:

2012-10-08

<b>Proizvod / Product</b>	<b>Listov / Pages</b>
Power supply Model: GT-22011-WVVV-X.X Enclosure: TR9KE5000LCP-Y(R)	3
<b>Naročnik / Applicant</b>	<b>Vrsta preskusa / Test procedure</b>
GlobTek, Inc 186 Veterans Dr, Northvale, NJ 07647 / USA	IP40, IP41
<b>Proizvajalec / Manufacturer</b>	<b>Št. Merjencev / No. of Items tested</b>
GlobTek, Inc 186 Veterans Dr, Northvale, NJ 07647 / USA	1
<b>Blagovna znamka / Trade Mark</b>	<b>Mapa predmeta št. / Subject File No.</b>
GlobTek	C20121557
<b>Standardi – predpisi / Standards - regulations</b>	<b>Kraj preskusa / Place of test</b>
IEC 60529:2001	SIQ - Slovenian Institute of Quality and Metrology, Tržaška 2, 1000 Ljubljana, Slovenia
	<b>Opomba / Remark</b>
	/

## Zaključek / Conclusion

**Tested product complies with the requirements of stated standards for protection degree IP 40.**

The test results relate only to the items tested.

Date of receipt of test items: 2012-07-16

Date of performance of tests: 2012-07-16 to 2012-09-19

(Tested product not complies with the requirements of stated standards for protection degree IP 41)

Testni laboratorij je akreditiran pri Slovenski akreditaciji, reg. št.: LP-009 /  
Testing Laboratory is accredited by Slovenian Accreditation, Reg. No. LP-009

Odgovoren za preskušanje / Responsible for the test

Vodja področja / Department Manager

Mirko Čokar

dr. Miha Otrin

Slovenski institut za kakovost in meroslovje • Slovenian Institute of Quality and Metrology  
Tržaška cesta 2, SI-1000 Ljubljana, Slovenia • t: +386 1 4778 100 • f: +386 1 4778 444 • e: info@siq.si • http://www.siq.si  
Razmnoževanje poročila, razen v celoti, ni dovoljeno / This report shall not be reproduced except in full

## 1 TEST EQUIPMENT

- Rigid test wire diameter of 1 mm as specified by the standard (2013-01-22),
- Test device for verification of protection against vertically falling water drops-drip box-SIQ,
- High voltage tester ELABO Type 92-1G3 (2013-01-14)

Note: The date of the recommended recalibration is given for each measuring instrument (in brackets).

## 2 EQUIPMENT UNDER TEST (EUT)

Power supply, model GT-22011-WWVV-X.X, enclosure TR9KE5000LCP-Y(R) was subjected to testing for IP41 degree of protection (Figures 1 and 2).



Figure 1



Figure 2

### IP41 numeric description:

The first characteristic numeral **X**: indicates the degree of protection against access to hazardous parts and against solid foreign objects. Test equipment for degree 4 is rigid test wire of 1 mm diameter. The protection is satisfactory if the rigid wire does not fully penetrate and adequate clearance is kept.

The second characteristic numeral **Y** indicates the degree of protection provided by enclosures with respect to harmful effects on the equipment due to the ingress of water (degree 1-protected against dripping water). If any water has entered shall have no harmful effects.

## 3 TEST CONDITIONS

During the testing the sample was equipped with appliance connector.

### 3.1 Test for protection against solid foreign objects-IP4X (IEC 60529, tables 2 and 7, sub-cl. 13.2)

Procedure:

- Environmental temperature 23<sup>0</sup>C,
- Rigid test wire diameter of 1 mm (as specified by the standard) is pushed against any openings of the enclosure with the force of 1 N,
- Non-operating condition

**Conclusion:** The rigid test wire was not penetrated into the enclosure.

### 3.2 Tests for protection against ingress of water-IPX1 (IEC 60529, table 8, sub-cl. 14.2.1)

Procedure:

- Test device, drip box-as specified in standard,
- Water flow rate: 1 mm/min,
- The test sample was placed on the turntable under the drip box in most unfavourable normal position (Figure 3),
- Duration of the exposure: 10 minutes,




Figure 3: Test position

**Conclusion:** After the water test there was water on the connector pins.

### 3.3 Electric strength test

Immediately following the water test the dielectric strength test with 4000 V a.c. has been conducted between primary and secondary terminals and between primary terminals and enclosure. The voltage was applied and maintained for a period of one minute between the points indicated. The test did NOT pass.

## 4 CONCLUSIONS

After the exposure was concluded, the visual examination of the sample was performed. Results were obtained as follows:

- The rigid test wire was not penetrated into the enclosure
- After the IPX1 test there was water on connector pins.
- After the IPX1 test the dielectric strength test did NOT pass.

**Result:** Following the acceptance conditions, the equipment under test sustained the test conditions for IP40 degree of protection.