




Test Report issued under the responsibility of:



| | |
|--|--|
| IEC 60601-1 Medical electrical equipment Part 1: General requirements for basic safety and essential performance | |
| Report Reference No.....: | 200501730SHA-001 |
| Date of issue | 2020-12-15 |
| Total number of pages.....: | 183 |
| CB Testing Laboratory.....: | Intertek Testing Services Shanghai |
| Address | Building No.86, 1198 Qinzhou Road (North), 200233 Shanghai, China |
| Applicant's name.....: | GlobTek, Inc. |
| Address | 186 Veterans Dr. Northvale, NJ 07647 USA |
| Test specification: | |
| Standard | IEC 60601-1:2005 (Third Edition) + CORR. 1:2006 + CORR. 2:2007 + A1:2012 (or IEC 60601-1: 2012 reprint) |
| Test procedure.....: | CB Scheme |
| Non-standard test method.....: | N/A |
| Test Report Form No.....: | IEC60601_1K |
| Test Report Form Originator | UL(US) |
| Master TRF | 2015-11 |
| Copyright © 2015 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved. | |
| This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. | |
| If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. | |
| This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02. | |
| General disclaimer: | |
| The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB testing laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report. | |

| | |
|------------------------------------|--|
| Test item description | Medical Power Supply |
| Trade Mark |  |
| Manufacturer | Same as applicant |
| Model/Type reference..... | <p>GT*96225*P*****_*</p> <p>(The 1st "*" part can be 'M' or '-' or 'H' for market identification and not related to safety.</p> <p>The 2nd "*" can be 0, 1, 2 or 3, denote the different mechanical construction, "0" means open frame, "1" means L frame, "2" means cage, "3" means potted.</p> <p>The 3rd "*" can be "001" to "225", denotes the rated output wattage designation from 1W to 225W, in step of 1 denote 1W.</p> <p>The 4th "*" can be "12" to "54" or "12.0" to "54.0", denote the standard rated output voltage designation from 12.0V to 54.0Vdc, in step of 0.1 denote 0.1V.</p> <p>The 5th "*" can be optional, blank or A to H, denote the AUX Output voltage code.</p> <p>The 6th "*" can be Blank, -C or -D, related to PCB size, Blank=2"x4", -C=3"x5", -D= 7"x4.22".</p> <p>The 7th "*" =-F or F means Open Frame class I or class II with functional earth</p> <p>=-FW or FW means Open Frame class II</p> <p>=-P2 or P2 means Encapsulated Type, class II</p> <p>=-P3 or P3 means Encapsulated Type, class I or class II with functional earth</p> <p>The last * denote any six character, which can be 0-9 or A-Z or ()[] or – or blank for marketing purposes, -* can be blank.)</p> |
| Ratings..... | <p>Input: 100-240V~, 50-60Hz or 50/60Hz, 3.0A;</p> <p>Output: 12.0-54.0VDC, Max. 18.75A, Max. 225W.</p> <p>See model list for detail.</p> |

Model List:

| Model without AUX output voltage | Output Voltage | Max. output current | Max. output power |
|----------------------------------|----------------|---------------------|-------------------|
| GT*96225*P**-F/FW/P2/P3-* | 12.0-54.0Vdc | 18.75A | 225W |
| GT*96225*P**F/FW/P2/P3-* | | | |
| GT*96225*P**-C-F/FW/P2/P3-* | | | |
| GT*96225*P**-CF/FW/P2/P3-* | | | |
| GT*96225*P**-D-F/FW/P2/P3-* | | | |
| GT*96225*P**-DF/FW/P2/P3-* | | | |


| Model with AUX output voltage | Main Output Voltage | Max. output current | AUX output voltage code | AUX output current | Max. output power |
|-------------------------------|---------------------|---------------------|-------------------------|--------------------|-------------------|
| GT*96225*P**A*-F/FW/P2/P3-* | 12.0-54.0Vdc | 18.75A | 12Vdc | Max 1.2A | 225W |
| GT*96225*P**A*F/FW/P2/P3-* | | | | | |
| GT*96225*P**B*-F/FW/P2/P3-* | 12.0-24.0Vdc | 18.75A | 5Vdc | Max 1.2A | 225W |
| GT*96225*P**B*F/FW/P2/P3-* | | | | | |
| GT*96225*P**C*-F/FW/P2/P3-* | | | 6Vdc | | 225W |
| GT*96225*P**C*F/FW/P2/P3-* | | | | | |
| GT*96225*P**D*-F/FW/P2/P3-* | | | 7Vdc | | 225W |
| GT*96225*P**D*F/FW/P2/P3-* | | | | | |
| GT*96225*P**E*-F/FW/P2/P3-* | | | 8Vdc | | 225W |
| GT*96225*P**E*F/FW/P2/P3-* | | | | | |
| GT*96225*P**F*-F/FW/P2/P3-* | | | 9Vdc | | 225W |
| GT*96225*P**F*F/FW/P2/P3-* | | | | | |
| GT*96225*P**G*-F/FW/P2/P3-* | | | 10Vdc | | 225W |
| GT*96225*P**G*F/FW/P2/P3-* | | | | | |
| GT*96225*P**H*-F/FW/P2/P3-* | | | 11Vdc | | 225W |
| GT*96225*P**H*F/FW/P2/P3-* | | | | | |

| | | |
|---|--|--|
| Testing procedure and testing location: | | |
| <input checked="" type="checkbox"/> | CB Testing Laboratory: | |
| Testing location/ address | | Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), 200233 Shanghai, China |
| <input type="checkbox"/> | Associated CB Testing Laboratory: | |
| Testing location/ address | | |
| Tested by (name, function, signature) | | Albert Zhou (Engineer) <i>Albert Zhou</i> |
| Approved by (name, function, signature) .. | | Larry Zhong (Mandated Reviewer) <i>Larry Zhong</i> |
| | | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 1: | |
| Testing location/ address | | |
| Tested by (name, function, signature) | | |
| Approved by (name, function, signature) .. | | |
| | | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 2: | |
| Testing location/ address | | |
| Tested by (name, function, signature) | | |
| Witnessed by (name, function, signature) . : | | |
| Approved by (name, function, signature) .. | | |
| | | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 3: | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 4: | |
| Testing location/ address | | |
| Tested by (name, function, signature) | | |
| Witnessed by (name, function, signature) . : | | |
| Approved by (name, function, signature) .. | | |
| Supervised by (name, function, signature) : | | |

| List of Attachments (including a total number of pages in each attachment): | |
|---|--|
| National difference for USA: from page 142 to page 143, total 2 Pages National differences for Canada: from page 144 to page 148, total 5 pages National differences for Switzerland: page 149, total 1 page National differences for Korea: page 150, total 1 page National differences for Japan: from page 151 to page 164, total 14 pages Photo of EUT: from page 165 to page 183, total 19 Pages | |
| Summary of testing | |
| Tests performed (name of test and test clause): | Testing location: |
| 4.11 Power Input | Intertek Testing Services Shanghai Building No. 86, 1198 Qinzhou Road (North), 200233 Shanghai, China |
| 5.7 Humidity Preconditioning | |
| 7.1.2 Legibility of Markings | |
| 7.1.3 Durability of Markings | |
| 8.4.3 Plug Voltage and/or Energy | |
| 8.5.4 Working Voltage Measurement | |
| 8.6.4 Earthing | |
| 8.7.4 Leakage Current Test | |
| 8.8.3 Dielectric Strength | |
| 8.8.4.1 Ball Pressure Test | |
| 8.9.4 Creepage & Clearance Measurements | |
| 9.3 Surfaces, corners and edges | |
| 11.1 Excessive Temperature | |
| 13.2 Single Fault Conditions | |
| 15.3.2 Push Test | |
| 15.3.3 Impact Test | |
| 15.3.4 Drop Test | |
| 15.3.6 Moulding Stress Relief | |
| 15.5.1.2 Transformer Short-Circuit | |
| 15.5.1.3 Transformer Overload | |
| 15.5.2 Transformer Dielectric Strength | |
| Summary of compliance with National Differences | |
| List of countries addressed: The national differences for Canada, USA, Japan, Korea and Switzerland have been checked. The group and national differences the CENELEC (EU) countries have been check and found to include no national differences or deviations from the IEC 60601-1:2005 (Third Edition) + CORR. 1:2006 + CORR. 2:2007 + AM1:2012 standard, as reported on the IECEE webpage. <input checked="" type="checkbox"/> The product fulfils the requirements of IEC 60601-1: 2005 + CORR. 1:2006 + CORR. 2:2007 + AM1:2012 & EN 60601-1: 2016 + A11: 2011 + A1: 2013 & ANSI/AAMI ES60601-1:2005/A1:2012 & CAN/CSA-C22.2 No. 60601-1:14. | |

Copy of marking plate

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.



Note: The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.

Other models are with similar label as corresponding above models except different model name and output ratings.

| GENERAL INFORMATION | |
|--|---|
| Test item particulars (see also Clause 6): | |
| Classification of installation and use | Final determination in end product evaluation for open frame model. |
| Device type (component/sub-assembly/ equipment/ system): | Component |
| Intended use (Including type of patient, application location) : | PSU (internal power supply board) |
| Mode of operation | Continuous / non-continuous |
| Supply connection | Supply cord for potted model |
| | Final determination in end product evaluation for open frame model. |
| Accessories and detachable parts included.....: | None |
| Other options include | None |
| Testing | |
| Date of receipt of test item(s) | 2020-05-20 |
| Dates tests performed | 2020-05-20 to 2020-08-12 |
| Possible test case verdicts: | |
| - test case does not apply to the test object | N/A |
| - test object does meet the requirement.....: | Pass (P) |
| - test object was not evaluated for the requirement | N/E (collateral standards only) |
| - test object does not meet the requirement.....: | Fail (F) |
| Abbreviations used in the report: | |
| - normal condition | N.C. |
| - means of Operator protection | MOOP |
| - single fault condition.....: | S.F.C. |
| - means of Patient protection | MOPP |

General remarks:

"(See Attachment #)" refers to additional information appended to the report.
 "(See appended table)" refers to a table appended to the report.
 The tests results presented in this report relate only to the object tested.
 This report shall not be reproduced except in full without the written approval of the testing laboratory.
 List of test equipment must be kept on file and available for review.
 Additional test data and/or information provided in the attachments to this report.

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.
 The test report only allows to be revised only within the report defined retention period unless standard or regulation was withdrawn or invalid.

Throughout this report a ☐ comma / ☒ point is used as the decimal separator.

Manufacturer's Declaration per sub-clause 4.2.5 of IEC60068-2-1

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided: ☒ Yes ☐ Not applicable

When differences exist; they shall be identified in the General product information section.

Name and address of factory (ies)..... : 1. GlobTek, Inc.
 186 Veterans Dr. Northvale, NJ 07647 USA
 2.GlobTek (Suzhou) Co., Ltd
 Building 4, No. 76 JinLing East Road, Suzhou Industrial Park, Suzhou, 215021, JiangSu, China


General product information:

Product covered by this report is medical power supply module, which can be used as a part of medical equipment.
 Transformers used in all models are with same construction. The turns of secondary winding may be added or reduced according different output voltage.
 All models have same PCB, but some non-critical components may be adjusted according different output voltage. The parameters of these components depend on output voltage.
 The size of PCB type Blank=2"x4" is 101.6mm*50.8mm; the size of PCB type -C=3"x5" is 127mm*76.2mm, the size of PCB type -D=7"x4.22" is 177.8mm*107.188mm.
 The products were not intend to be used in maximum recommended ambient exceed of 50 °C.
 The differences between models followed by -F, F, -P3, P3 or -FW, FW, -P2, P2 are the earthing wire for functional earth. The models followed by -F, F or -P3, P3 have earthing wire maybe for functional earth or protective earth. The models followed by -FW, FW or -P2, P2 have not earthing wire for functional earth.
 The installation and use for the insulation construction shall be finally determined in the end product.

The products are not intended to use in environment which altitude exceed 5000m.

For models GT*96225*P12015***-*: output 15VDC, 7.0A at Tma=60 Deg.C;

For Models with output power more than 140W, fan (12Vdc, Max. 15W) should provide approximately 10CFM, in direction noted below:



All the types are designed for continuous operation and no applied part is defined.

The insulation construction of EUT is evaluated as 2MOPP in this report as customer's request.

Technical Considerations:

Transformers used in all models are with same construction. The turns of secondary winding may be added or reduced according different output voltage. All models have same PCB, but some non-critical components may be adjusted according different output voltage. The parameters of these components depend on output voltage.

1. Scope of Power Supply evaluation defers the following clauses to be determined as part of the end product investigation:

Clause 7.5 (Safety Signs),

Clause 7.9 (Accompanying Documents are provided for some critical issue like technical data, safety warnings, necessary information to set up, but further evaluation is needed on end product level.),

Clause 8.11.5 (Mains Fuse with High Breaking Capacity),

Clause 9 (ME Hazard), except 9.1 and 9.3 are evaluated,

Clause 10 (Radiation),

Clause 14 (PEMS),


Clause 16 (ME Systems),

Clause 17 (EMC)

2. As the product is open-frame power supply module, accessible parts, insulation construction and the tests thereof such as leakage current, mechanical hazards and fire enclosure shall be determined in end product evaluation.

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

INSULATION DIAGRAM



| TABLE: INSULATION DIAGRAM | | | | | | | | | P |
|--|--|------|------------------|-----------------|------------------------|-------------------------|------------------------|-------------------------|---|
| Pollution degree : 2 | | | | | | | | | — |
| Overvoltage category : II | | | | | | | | | — |
| Altitude..... : Up to 5000m | | | | | | | | | — |
| Additional details on parts considered as applied parts : <input checked="" type="checkbox"/> None <input type="checkbox"/> Areas _____ (See Clause 4.6 for details) | | | | | | | | | — |
| Area | Number and type of Means of Protection: MOOP, MOPP | CTI | Working voltage | | Required creepage (mm) | Required clearance (mm) | Measured creepage (mm) | Measured clearance (mm) | Remarks |
| | | | V _{rms} | V _{pk} | | | | | |
| A | 1MOOP | IIIb | 240 | -- | 3.0 | 3.0 ⁶ | 3.50 | 3.50 | Opposite polarity of mains part |
| B | 1MOOP | IIIb | 240 | -- | 3.0 | 3.0 ⁶ | 3.52 | 3.52 | Line/Neutral to PE terminal trace (for Class I) |
| B ¹ | 1MOPP | IIIb | 240 | 340 | 4.0 | 3.0 ⁶ | 4.05 | 4.05 | Mains parts to PE terminal |
| C | 2MOPP | IIIb | 240 | 340 | 7.9 ⁴ | 7.4 ⁶ | 7.96 | 7.96 | Mains part to secondary |

| IEC 60601-1 | | | | | | | | | |
|----------------------|--------------------|-------------|------------------------|------------|------------------------|------------------------|-----------------|-----------------|---|
| Clause | Requirement + Test | | | | | Result - Remark | | | Verdict |
| | | | | | | | | | circuits (Optocoupler) |
| D | 2MOPP | IIIb | 240 | 340 | 7.9⁴ | 7.4⁶ | 12.0 | 12.0 | Mains part to secondary circuits (Transformer) |
| D¹ | 2MOPP | IIIb | 240 | 340 | 7.9⁴ | 7.4⁶ | 8.20 | 8.20 | Core to secondary circuits (Transformer) |
| E | 2MOPP | IIIb | 240³ | -- | 7.9⁴ | 7.4⁶ | 8.10 | 8.10 | Mains parts to secondary circuits (PCB trace) |
| F | 2MOPP | IIIb | 240³ | -- | 7.9⁴ | 7.4⁶ | Min. 8.5 | Min. 8.5 | Mains parts to secondary pin-out (Y capacitor x 2) |
| G | -- | IIIb | Max. 54Vdc | -- | -- | -- | -- | -- | Accessible parts per 8.4.2 c) |

Note:

- 1) The same area is evaluated in open frame model. And there is no more difference if not specified.
- 2) Optionally an electromagnetic shield which is copper foil is added around the outside of the coil. It's connected to mains part.
- 3) The working voltage is highest measured value which acquired by testing all the models listed in the report at the rated input voltage, but not less than the rated input voltage.
- 4) Linear interpolation is applied to the determination of required creepage.
- 5) The minimum creepage and clearance is selected from all the types of optocouplers.
- 6) Multiplication factor for MOOP: 1.48; Multiplication factor for MOPP: 1.29.
- 7) Minimum 0.4 mm thick Mylar sheet wraps around internal conductive parts.

Two layers of insulating tape or one layer of min. 0.4 mm thickness insulating tube wrap around the secondary heatsink.

INSULATION DIAGRAM CONVENTIONS and GUIDANCE:

A measured value must be provided in the value columns for the device under evaluation. The symbol > (greater than sign) must not be used. Switch-mode power supplies must be re-evaluated in the device under evaluation therefore N/A must not be used with a generic statement that the component is certified.

Insulation diagram is a graphical representation of equipment insulation barriers, protective impedance and protective earthing. If feasible, use the following conventions to generate the diagram:

- All isolation barriers are identified by letters between separate parts of diagram, for example separate transformer

windings, optocouplers, wire insulation, creepage and clearance distances.

- Parts connected to earth with large dots are protectively earthed. Other connections to earth are functional

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

- Applied parts are extended beyond the equipment enclosure and terminated with an arrow.
- Parts accessible to the operator only are extended outside of the enclosure, but are not terminated with an arrow.

| IEC 60601-1 | | | |
|----------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 4 | GENERAL REQUIREMENTS | | P |
| 4.1 | Requirements of this standard applied in NORMAL USE and reasonably foreseeable misuse | | P |
| 4.2 | RISK MANAGEMENT PROCESS FOR ME EQUIPMENT OR ME SYSTEMS | | P |
| 4.2.2 | General requirement for RISK MANAGEMENT - PROCESS complies with ISO14971 (2007) | See Appended RM Results Table 4.2 | P |
| 4.2.3 | Evaluating RISK | | P |
| 4.2.3.1 | a) Compliance with the standard reduces residual risk to an acceptable level | | P |
| | b) Manufacturer has defined risk acceptability criteria in the RISK MANAGEMENT PLAN | RISK MANAGEMENT PLAN Document: Report No.GT-RMPLAN2020-003 | P |
| | c) When no specific technical requirements provided manufacturer has determined HAZARDS or HAZARDOUS SITUATIONS exists. | | P |
| | - HAZARDS or HAZARDOUS SITUATIONS have been evaluated using the RISK MANAGEMENT PROCESS. | | P |
| 4.2.3.2 | MANUFACTURER has addressed HAZARDS or HAZARDOUS SITUATIONS not specifically addressed in the IEC 60601-1 series. | | P |
| 4.3 | Performance of clinical functions necessary to achieve INTENDED USE or that could affect the safety of the ME EQUIPMENT or ME SYSTEM were identified during RISK ANALYSIS. | No essential performance | N/A |
| | - Performance limits were identified in both NORMAL CONDITION and SINGLE FAULT CONDITION. | | N/A |
| | - Loss or degradation of performance beyond the limits specified by the MANUFACTURER were evaluated | | N/A |
| | - Functions with unacceptable risks are identified as ESSENTIAL PERFORMANCE..... : | See Appended Table 4.3 | N/A |
| | - RISK CONTROL measures implemented | | N/A |
| | - Methods used to verify the effectiveness of RISK CONTROL measures implemented | | N/A |
| 4.4 | EXPECTED SERVICE LIFE stated in RISK MANAGEMENT FILE | | N/A |
| 4.5 | Alternative RISK CONTROL methods utilized: | | N/A |
| | RESIDUAL RISK resulting from the alternative RISK CONTROL measures or tests is acceptable and comparable to RESIDUAL RISK resulting from application of this standard..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | No alternative risk control method. | N/A |

| IEC 60601-1 | | | |
|-------------|--|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Alternative means based scientific data or clinical opinion or comparative studies : | | N/A |
| 4.6 | RISK MANAGEMENT PROCESS identifies parts that can come into contact with PATIENT but not defined as APPLIED PARTS, subjected to the requirements for APPLIED PARTS, except for Clause 7.2.10..... : | No such parts. | N/A |
| | MANUFACTURER assesses the risk of accessible parts coming into contact with the patient : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | Assessment identified the APPLIED PART TYPE requirements..... : | No applied part. | N/A |
| 4.7 | ME EQUIPMENT remained SINGLE FAULT SAFE, or the RISK remained acceptable as determined by Clause 4.2..... : | See Appended RM Results Table 4.7 | P |
| | MANUFACTURER RISK ANALYSIS was used to determine failures to be tested..... : (ISO 14971 Cl. 4.2-4.4) | See Appended RM Results Table 4.7 | P |
| | Failure of any one component at a time that could result in a HAZARDOUS SITUATION, including those in 13.1, simulated physically or theoretically : | Test performed, simulated physically | P |
| 4.8 | All components and wiring whose failure could result in a HAZARDOUS SITUATION used according to their applicable ratings, unless specified ... : | All components and wiring used according to applicable rating. | P |
| | Components and wiring exception in the standard or by RISK MANAGEMENT PROCESS | | P |
| | RISK MANAGEMENT PROCESS assesses components to identify components where the failure results in a HAZARDOUS SITUATION for components used outside their ratings : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | No components used outside their ratings. | N/A |
| | MANUFACTURER identified components where the failure results in a HAZARDOUS SITUATION.... : | See Table 8.10 b. | P |
| | Components determined to be acceptable where used as a MEANS OF PROTECTION : | RMF Reference to specific RISKS | P |
| | Reliability of components used as MEANS OF PROTECTION assessed for conditions of use in ME EQUIPMENT, and they complied with one of the following | | P |
| | a) Applicable safety requirements of a relevant IEC or ISO standard | | P |
| | b) Requirements of this standard applied in the absence of a relevant IEC or ISO standard | | P |

| IEC 60601-1 | | | |
|---------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 4.9 | A COMPONENT WITH HIGH-INTEGRITY CHARACTERISTICS provided and selected appropriately..... : | | N/A |
| | RISK MANAGEMENT FILE includes an assessment to determine if the failure of components results in unacceptable RISK..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | Components identified and required to be COMPONENTS WITH HIGH INTEGRITY CHARACTERISTIC: | | N/A |
| 4.10 | Power supply | | P |
| 4.10.1 | ME EQUIPMENT is suitable for connection to indicated power source (select applicable).....: | Suitable for connection to a SUPPLY MAINS. | P |
| 4.10.2 | Maximum rated voltage for ME EQUIPMENT intended to be connected to SUPPLY MAINS: | Not hand-held equipment. | N/A |
| | - 250 V for HAND-HELD ME EQUIPMENT (V)..... : | 100-240Vac, single phase, less than 4KVA | P |
| | - 250 V d.c. or single-phase a.c., or 500 V poly-phase a.c. for ME EQUIPMENT and ME SYSTEMS with a RATED input ≤ 4 kVA (V)..... : | 100-240Vac, single phase, less than 4KVA | N/A |
| | - 500 V for all other ME EQUIPMENT and ME SYSTEMS | | N/A |
| 4.11 | Power input | | P |
| | Steady-state measured input of ME EQUIPMENT or ME SYSTEM at RATED voltage or voltage range and at operating settings indicated in instructions for use didn't exceed marked rating by more than 10%..... : | See appended Table 4.11 | P |

| | | | |
|------------|--|-------------------------------|------------|
| 5 | GENERAL REQUIREMENTS FOR TESTING ME EQUIPMENT | | P |
| 5.1 | Test not performed when analysis indicated condition being tested was adequately evaluated by other tests or methods.....: | All tests were conducted | N/A |
| | RISK MANAGEMENT FILE identifies combinations of simultaneous independent faults that could result in a HAZARDOUS SITUATION. (ISO 14971 Cl. 4.2-4.4) | | N/A |
| 5.3 | Tests conducted within the environmental conditions specified in technical description | | P |
| | Temperature (°C), Relative Humidity (%) : | 0-40 °C, 20-80%RH. | — |
| | Atmospheric Pressure (kPa) : | 700-1060hPa. (3000m altitude) | — |

| IEC 60601-1 | | | |
|-------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 5.5 | a) Supply voltage during tests was the least favourable of the voltages specified in 4.10.2 or voltages marked on ME EQUIPMENT (V) | 100-240V~ | P |
| | b) ME EQUIPMENT marked with a RATED frequency range tested at the least favourable frequency within the range (Hz)..... | 50-60Hz or 50/60Hz | P |
| | c) ME EQUIPMENT with more than one RATED voltage, both a.c./ d.c. or both external power and INTERNAL ELECTRICAL POWER SOURCE tested in conditions (see 5.4) related to the least favourable voltage, nature of supply, and type of current..... | 90-264V~, 50-60Hz or 50/60Hz, considered. | P |
| | d) ME EQUIPMENT intended for only d.c. supply connection tested with d.c. and influence of polarity considered..... | Not for d.c. supply connection. | N/A |
| | e) ME EQUIPMENT tested with alternative ACCESSORIES and components specified in ACCOMPANYING DOCUMENTS to result in the least favourable conditions..... | No alternative accessory. | N/A |
| | f) ME EQUIPMENT connected to a separate power supply as specified in instructions for use | No separate power supply used. | N/A |
| 5.7 | ME EQUIPMENT or parts thereof affected by climatic conditions were set up completely, or partially, with covers detached and subjected to a humidity preconditioning prior to tests of Clauses 8.7.4 and 8.8.3..... | Equipment subject to humidity preconditioning. | P |
| | ME EQUIPMENT heated to a temperature between T and T + 4°C for at least 4 h and placed in a humidity chamber and ambient within 2 °C of T in range of +20°C to +32°C for indicated time | Pre-condition performed: 26°C, 93%RH for 120 h according to client's request. | — |
| 5.9 | Determination of APPLIED PARTS and ACCESSIBLE PARTS | | P |
| 5.9.1 | APPLIED PARTS identified by inspection and reference to ACCOMPANYING DOCUMENTS | See clause 4.6 Remark | N/A |
| 5.9.2 | ACCESSIBLE PARTS | | P |
| 5.9.2.1 | Accessibility determined using standard test finger of Fig. 6 | See Appended Table 5.9.2 | P |
| 5.9.2.2 | Test hook of Fig. 7 inserted in all openings of ME EQUIPMENT and pulled with a force of 20 N for 10 s | Test hook can't enter opening | N/A |
| 5.9.2.3 | Conductive parts of actuating mechanisms of electrical controls accessible after removal of handles, knobs, levers and the like regarded as ACCESSIBLE PARTS | No such part. | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|--|--|---------------|------------|
| | Conductive parts of actuating mechanisms not considered ACCESSIBLE PARTS when removal of handles, knobs, required use of a TOOL.....: | No such part. | N/A |
|--|--|---------------|------------|

| | | | |
|------------|---|--|------------|
| 6 | CLASSIFICATION OF ME EQUIPMENT AND ME SYSTEMS | | P |
| 6.2 | CLASS I ME EQUIPMENT, externally powered | Class I or Class II shall be determined in end product evaluation. | P |
| | CLASS II ME EQUIPMENT, externally powered | Class I or Class II shall be determined in end product evaluation. | P |
| | INTERNALLY POWERED ME EQUIPMENT | Not internally powered. | N/A |
| | EQUIPMENT with means of connection to a SUPPLY MAINS complied with CLASS I or CLASS II ME EQUIPMENT requirements when so connected, and when not connected to SUPPLY MAINS with INTERNALLY POWERED ME EQUIPMENT requirements | | N/A |
| | TYPE B APPLIED PART | No applied part. | N/A |
| | TYPE BF APPLIED PART | | N/A |
| | TYPE CF APPLIED PART | | N/A |
| | DEFIBRILLATION-PROOF APPLIED PARTS | | N/A |
| 6.3 | ENCLOSURES classified according to degree of protection against ingress of water and particulate matter as per IEC 60529 : | IPX0 for adapter model Final determination in the end product for open frame model. | P |
| 6.4 | ME EQUIPMENT or its parts intended to be sterilized classified according to method(s) of sterilization in instructions for use..... : | No sterilization required. | N/A |
| 6.5 | ME EQUIPMENT and ME SYSTEMS intended for use in an OXYGEN RICH ENVIRONMENT classified for such use and complied with 11.2.2 | Power supply not investigated for oxygen rich environment. | N/A |
| 6.6 | CONTINUOUS or Non-CONTINUOUS OPERATION : | Continuous operation. | P |

| | | | |
|--------------|---|---------------------------|----------|
| 7 | ME EQUIPMENT IDENTIFICATION, MARKING, AND DOCUMENTS | | P |
| 7.1.2 | Legibility of Markings Test for Markings specified in Clause 7.2-7.6 : | See Appended Table 7.1.2 | P |
| 7.1.3 | Required markings can be removed only with a TOOL or by appreciable force, are durable and remain CLEARLY LEGIBLE during EXPECTED SERVICE LIFE of ME EQUIPMENT in NORMAL USE | See appended Tables 7.1.3 | P |
| 7.2 | Marking on the outside of ME EQUIPMENT or ME EQUIPMENT parts | | P |

| IEC 60601-1 | | | |
|-------------|--|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.2.1 | At least markings in 7.2.2, 7.2.5, 7.2.6, 7.2.10, and 7.2.13 were applied when size of EQUIPMENT, its part, an ACCESSORY, or ENCLOSURE did not permit application of all required markings | See attached copy of Marking Plate. | P |
| | Remaining markings fully recorded in ACCOMPANYING DOCUMENTS..... | All required marking provided on name plate. | N/A |
| | Markings applied to individual packaging when impractical to apply to ME EQUIPMENT | No such condition. | N/A |
| | Single use item marked | No part intended for a single use. | N/A |
| 7.2.2 | ME EQUIPMENT marked with: | | P |
| | – the name or trademark and contact information of the MANUFACTURER | See attached copy of Marking Plate. | P |
| | – a MODEL OR TYPE REFERENCE | See attached copy of Marking Plate. | P |
| | – a serial number or lot or batch identifier; and | | P |
| | – the date of manufacture or use by date | | P |
| | Detachable components of the ME EQUIPMENT not marked; misidentification does not present an unacceptable risk, or | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of the RISKS relating to misidentification of all detachable parts: (ISO 14971 Cl. 4.2-4.4, 5, 6.4) | | N/A |
| | Detachable components of the ME EQUIPMENT are marked with the name or trademark of the MANUFACTURER, and | | N/A |
| | – a MODEL OR TYPE REFERENCE | | N/A |
| | Software forming part of a PEMS identified with a unique identifier | No PEMS. | N/A |
| 7.2.3 | Symbol 11 on Table D.1 used, optionally, advice to OPERATOR to consult ACCOMPANYING DOCUMENTS | | N/A |
| | Safety sign 10 on Table D.2) used, advising OPERATOR that ACCOMPANYING DOCUMENTS must be consulted | | N/A |
| 7.2.4 | ACCESSORIES marked with name or trademark and contact information of their MANUFACTURER, and..... | No such accessories. | N/A |
| | - with a MODEL OR TYPE REFERENCE | | N/A |
| | – a serial number or lot or batch identifier | | N/A |
| | – the date of manufacture or use by date | | N/A |

| IEC 60601-1 | | | |
|--------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Markings applied to individual packaging when not practical to apply to ACCESSORIES | | N/A |
| 7.2.5 | ME EQUIPMENT and ME SYSTEM intended to receive power from other equipment, provided with one of the following | Not receive power from other equipment. | N/A |
| | - the name or trademark of the manufacturer of the other electrical equipment and type reference marked adjacent to the relevant connection point; or | | N/A |
| | – Table D.2, safety sign No. 10 adjacent to the relevant connection point and listing of the required details in the instructions for use; or | | N/A |
| | – Special connector style used that is not commonly available on the market and listing of the required details in the instructions for use. | | N/A |
| 7.2.6 | Connection to the Supply Mains | | P |
| | Marking appearing on the outside of part containing SUPPLY MAINS connection and, adjacent to connection point | | P |
| | For PERMANENTLY INSTALLED ME EQUIPMENT, NOMINAL supply voltage or range marked inside or outside of ME EQUIPMENT | Not for permanently installed. | N/A |
| | – RATED supply voltage(s) or RATED voltage range(s) with a hyphen (-) between minimum and maximum voltages (V, V-V)..... : | 100-240V | P |
| | Multiple RATED supply voltages or multiple RATED supply voltage ranges are separated by (V/V)..... : | Not so marked. | N/A |
| | – Nature of supply and type of current..... : | Single phase, AC. | P |
| | Symbols 1-5, Table D.1 (used for same parameters..... : | ‘~’ is used. | P |
| | – RATED supply frequency or RATED frequency range in hertz..... : | 50-60Hz or 50/60HZ | P |
| | – Symbol 9 of Table D.1 used for CLASS II ME EQUIPMENT..... : | Symbol 9 is used for Class II adapter model. | P |
| 7.2.7 | RATED input in amps or volt-amps, (A, VA).....: | RATED input in amps: 3.0A | P |
| | RATED input in amps or volt-amps, or in watts when power factor exceeds 0.9 (A, VA, W).....: | No such range provided. | N/A |
| | RATED input for one or more RATED voltage ranges provided for upper and lower limits of the range or ranges when the range(s) is/are greater than ± 10 % of the mean value of specified range (A, VA,W)..... : | | N/A |


| IEC 60601-1 | | | |
|-------------|--|-----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Input at mean value of range marked when range limits do not differ by more than 10 % from mean value (A, VA, W)..... : | | N/A |
| | Marking includes long-time and most relevant momentary volt-ampere ratings when provided, each plainly identified and indicated in ACCOMPANYING DOCUMENTS (VA) : | | N/A |
| | Marked input of ME EQUIPMENT provided with means for connection of supply conductors of other electrical equipment includes RATED and marked output of such means (A, VA, W) : | | N/A |
| 7.2.8 | Output connectors | | P |
| 7.2.8.2 | Output connectors are marked, except for MULTIPLE SOCKET-OUTLETS or connectors intended for specified ACCESSORIES or equipment | | P |
| | Rated Voltage (V), Rated Current (A) : | See model similarity. | — |
| | Rated Power (W), Output Frequency (Hz) : | See model similarity. | — |
| 7.2.9 | ME EQUIPMENT or its parts marked with the IP environmental Code per IEC 60529 according to classification in 6.3 (Table D.3, Code 2), marking optional for ME EQUIPMENT or parts rated IPX0... : | IPX0 | N/A |
| 7.2.10 | Degrees of protection against electric shock as classified in 6.2 for all APPLIED PARTS marked with relevant symbols : | No applied part. | N/A |
| | TYPE B APPLIED PARTS with symbol 19 of Table D.1 | | N/A |
| | TYPE BF APPLIED PARTS with symbol 20 of Table D.1 : | | N/A |
| | TYPE CF APPLIED PARTS with symbol 21 of Table D.1 : | | N/A |
| | DEFIBRILLATION-PROOF APPLIED PARTS marked with symbols 25-27 of Table D.1 : | | N/A |
| | Proper symbol marked adjacent to or on connector for APPLIED PART : | | N/A |
| | Safety sign 2 of Table D.2 placed near relevant outlet : | | N/A |
| | An explanation indicating protection of ME EQUIPMENT against effects of discharge of a cardiac defibrillator depends on use of proper cables included in instructions for use : | | N/A |
| 7.2.11 | ME EQUIPMENT suitable for CONTINUOUS OPERATION | | P |
| | DUTY CYCLE for ME EQUIPMENT intended for non-CONTINUOUS OPERATION appropriately marked to provide maximum “on” and “off” time : | Continuous operation. | N/A |


| IEC 60601-1 | | | |
|-------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.2.12 | Type and full rating of a fuse marked adjacent to ACCESSIBLE fuse-holder | No accessible fuse-holder. | N/A |
| | Fuse type..... : | | — |
| | Voltage (V) and Current (A) rating.....: | | — |
| | Operating speed (s) and Breaking capacity.....: | | — |
| 7.2.13 | Physiological effects – safety sign and warning statements : | EUT is component power supply only, no physiological effect | N/A |
| | Nature of HAZARD and precautions for avoiding or minimizing the associated RISK described in instructions for use..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.3) | | N/A |
| 7.2.14 | HIGH VOLTAGE TERMINAL DEVICES on the outside of ME EQUIPMENT accessible without the use of a TOOL marked with symbol 24 of Table D.1 | No such high voltage terminal device. | N/A |
| 7.2.15 | Requirements for cooling provisions marked .. : | | N/A |
| 7.2.17 | Packaging marked with special handling instructions for transport and/or storage..... : | Component, to be determined as part of end product. | N/A |
| | Permissible environmental conditions marked on outside of packaging: | Component, to be determined as part of end product. | N/A |
| | Packaging marked with a suitable safety sign indicating premature unpacking of ME EQUIPMENT could result in an unacceptable RISK..... : | | N/A |
| | RISK MANAGEMENT FILE includes the assessment to determine premature unpacking of ME EQUIPMENT or its parts could result in an unacceptable RISK. : (ISO 14971 Cl. 4.2-4.4, 5, 6.3-6.4) | | N/A |
| | Packaging of sterile ME EQUIPMENT or ACCESSORIES marked sterile and indicates the methods of sterilization | | N/A |
| 7.2.18 | RATED maximum supply pressure from an external source marked on ME EQUIPMENT adjacent to each input connector, and: | No external pressure source. | N/A |
| | - the RATED flow rate also marked | | N/A |
| 7.2.19 | Symbol 7 of Table D.1 marked on FUNCTIONAL EARTH TERMINAL..... : | No FE terminal. | N/A |
| 7.2.20 | Removable protective means marked to indicate the necessity for replacement when the function is no longer needed : | Component, to be determined as part of end product. | N/A |
| 7.2.21 | MOBILE ME EQUIPMENT marked with its mass including its SAFE WORKING LOAD in kilograms.... : | Not mobile me equipment. | N/A |
| 7.3 | Marking on the inside of ME EQUIPMENT or ME EQUIPMENT parts | | P |

| IEC 60601-1 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.3.1 | Maximum power loading of heating elements or lamp-holders designed for use with heating lamps marked near or in the heater (W)..... : | No heating element, no lamp holder. | N/A |
| | A marking referring to ACCOMPANYING DOCUMENTS provided for heating elements or lamp-holders designed for heating lamps that can be changed only by SERVICE PERSONNEL using a TOOL | | N/A |
| 7.3.2 | Symbol 24 of Table D.1, or safety sign No.3 of Table D.2 used to mark presence of HIGH VOLTAGE parts : | No such HV part. | N/A |
| 7.3.3 | Type of battery and mode of insertion marked: | No battery. | N/A |
| | An identifying marking provided referring to instructions in ACCOMPANYING DOCUMENTS for batteries intended to be changed only by SERVICE PERSONNEL using a TOOL..... : | | N/A |
| | A warning provided indicating replacement of lithium batteries or fuel cells when incorrect replacement would result in an unacceptable RISK : | | N/A |
| | RISK MANAGEMENT FILE includes an assessment to determine the replacement of lithium batteries or fuel cells leads to an unacceptable RISK if replaced incorrectly..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.3) | | N/A |
| | ACCOMPANYING DOCUMENTS contain a warning indicating the replacement of lithium batteries or fuel cells by inadequately trained personnel could result in a HAZARD : | | N/A |
| 7.3.4 | Fuses, replaceable THERMAL CUT-OUTS and OVER-CURRENT RELEASES, accessible by use of a TOOL Identified : | Specification adjacent to component. | P |
| | Voltage (V) and Current (A) rating..... : | T4A/250V. | — |
| | Operating speed(s), size & breaking capacity .. : | See the table 8.10 | — |
| 7.3.5 | PROTECTIVE EARTH TERMINAL marked with symbol 6 of Table D.1 | Protective bonding terminal is provided on PCB for open frame model. | P |
| | Markings on or adjacent to PROTECTIVE EARTH TERMINALS not applied to parts requiring removal to make the connection, and remained visible after connection made | | P |
| 7.3.6 | Symbol 7 of Table D.1 marked on FUNCTIONAL EARTH TERMINALS | No FE terminal. | N/A |
| 7.3.7 | Terminals for supply conductors marked adjacent to terminals : | No hazard if connections are interchanged. | P |

| IEC 60601-1 | | | |
|--------------|--|----------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Terminals for supply connections are not marked, the RISK MANAGEMENT FILE includes an assessment of the RISKS resulting from misconnections.....: (ISO 14971 Cl. 4.3) | | N/A |
| | Terminal markings included in ACCOMPANYING DOCUMENTS when ME EQUIPMENT too small to accommodate markings | Marked on EUT. | P |
| | Terminals exclusively for neutral supply conductor in PERMANENTLY INSTALLED ME EQUIPMENT marked with Code 1 of Table D.3 | Not permanently installed. | N/A |
| | Marking for connection to a 3-phase supply, complies with IEC 60445 | Not 3-phase. | N/A |
| | Markings on or adjacent to electrical connection points not applied to parts requiring removal to make connection, and remained visible after connection made | | P |
| 7.3.8 | “For supply connections, use wiring materials suitable for at least X °C” or equivalent, marked at the point of supply connections | No such high temperature. | N/A |
| | Statement not applied to parts requiring removal to make the connection, and CLEARLY LEGIBLE after connections made | | N/A |
| 7.4 | Marking of controls and instruments | | N/A |
| 7.4.1 | The “on” & “off” positions of switch to control power to ME EQUIPMENT or its parts, including mains switch, marked with symbols 12 and 13 of Table D.1 or | No power switch. | N/A |
| | – indicated by an adjacent indicator light, or | | N/A |
| | – indicated by other unambiguous means | | N/A |
| | The “on/off” positions of push button switch with bi-stable positions marked with symbol 14 of Table D.1, and | | N/A |
| | – status indicated by adjacent indicator light | | N/A |
| | – status indicated by other unambiguous means | | N/A |
| | The “on/off” positions of push button switch with momentary on position marked with symbol 15 of Table D.1 or | | N/A |
| | – status indicated by adjacent indicator light | | N/A |
| | – status indicated by other unambiguous means | | N/A |
| 7.4.2 | Different positions of control devices/switches indicated by figures, letters, or other visual means | No such device. | N/A |

| IEC 60601-1 | | | |
|--------------|---|---------------------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | RISK MANAGEMENT FILE identifies controls where a change in setting during NORMAL USE results in an unacceptable RISK.....: (ISO 14971 Cl. 4.2-4.4, 5, 6.2, 6.3) | | N/A |
| | Controls provided with an associated indicating device when change of setting of a control could result in an unacceptable RISK to PATIENT in NORMAL USE | | N/A |
| | – or an indication of direction in which magnitude of the function changes | | N/A |
| | Control device or switch that brings the ME EQUIPMENT into the "stand-by" condition marked with symbol IEC 60417-5009 | | N/A |
| 7.4.3 | Numeric indications of parameters on ME EQUIPMENT expressed in SI units according to ISO 80000-1 except the base quantities listed in Table 1 expressed in the indicated units | No numeric indications of parameters. | N/A |
| | ISO 80000-1 applied for application of SI units, their multiples, and certain other units | | N/A |
| | All Markings in Sub-clause 7.4 complied with tests and criteria of 7.1.2 and 7.1.3 | | N/A |
| 7.5 | Safety signs | | N/A |
| | Safety sign with established meaning used | No safety sign used. | N/A |
| | RISK MANAGEMENT PROCESS identifies markings used to convey a warning, prohibition or mandatory action that mitigate a RISK not obvious to the OPERATOR (ISO 14971 Cl. 4.2-4.4, 5, 6.3) | | N/A |
| | Affirmative statement together with safety sign placed in instructions for use if insufficient space on ME EQUIPMENT | | N/A |
| | Specified colours in ISO 3864-1 used for safety signs.....: | | N/A |
| | Safety notices include appropriate precautions or instructions on how to reduce RISK(S) | | N/A |
| | Safety signs including any supplementary text or symbols described in instructions for use | | N/A |
| | - and in a language acceptable to the intended OPERATOR | | N/A |
| 7.6 | Symbols | | P |
| 7.6.1 | Meanings of symbols used for marking described in instructions for use | See Appended Instruction for Use | P |

| IEC 60601-1 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.6.3 | Symbols used for controls and performance conform to the IEC or ISO publication where symbols are defined, as applicable | | N/A |
| 7.7 | Colours of the insulation of conductors | | P |
| 7.7.1 | PROTECTIVE EARTH CONDUCTOR identified by green and yellow insulation | Class I model provides PE conductor | P |
| 7.7.2 | Insulation on conductors inside ME EQUIPMENT forming PROTECTIVE EARTH CONNECTIONS identified by green and yellow at least at terminations | Class I model provides PE conductor | P |
| 7.7.3 | Green and yellow insulation identify only following conductors: | | P |
| | – PROTECTIVE EARTH CONDUCTORS | | N/A |
| | – conductors specified in 7.7.2 | | P |
| | – POTENTIAL EQUALIZATION CONDUCTORS | | N/A |
| | – FUNCTIONAL EARTH CONDUCTORS | | N/A |
| 7.7.4 | Neutral conductors of POWER SUPPLY CORDS are “light blue” | No power supply cord | N/A |
| 7.7.5 | Colours of conductors in POWER SUPPLY CORDS in accordance with IEC 60227-1 or IEC 60245-1 | No power supply cord | N/A |
| 7.8 | Indicator lights and controls | | N/A |
| 7.8.1 | Red indicator lights used only for Warning | No indicator light. | N/A |
| | Yellow indicator lights used only for Caution | | N/A |
| | Green indicator lights used only for Ready for use | | N/A |
| | Other colours: Meaning other than red, yellow, or green (colour, meaning) | | N/A |
| 7.8.2 | Red used only for emergency control | | N/A |
| 7.9 | ACCOMPANYING DOCUMENTS | | P |
| 7.9.1 | ME EQUIPMENT accompanied by documents containing instructions for use, and a technical description | Accompany documents are provided for some critical issue like technical data, safety warnings, necessary information to set up, but further evaluation is needed on end product level. | P |
| | ACCOMPANYING DOCUMENTS identify ME EQUIPMENT by the following, as applicable: | | P |
| | – Name or trade-name of MANUFACTURER and contact information for the RESPONSIBLE ORGANIZATION can be referred to |  | P |
| | – MODEL or TYPE REFERENCE..... | GT*96225*P****-* | P |

| IEC 60601-1 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | When ACCOMPANYING DOCUMENTS provided electronically, USABILITY ENGINEERING PROCESS includes instructions as to what is required in hard copy or as markings on ME EQUIPMENT | | N/A |
| | ACCOMPANYING DOCUMENTS specify special skills, training, and knowledge required of OPERATOR or RESPONSIBLE ORGANIZATION and environmental restrictions on locations of use | | N/A |
| | ACCOMPANYING DOCUMENTS written at a level consistent with education, training, and other needs of individuals for whom they are intended | | N/A |
| 7.9.2 | Instructions for use include the required information | | P |
| 7.9.2.1 | – use of ME EQUIPMENT as intended by the MANUFACTURER: | Power adapter. | P |
| | – frequently used functions, | Power supply only. | P |
| | – known contraindication(s) to use of ME EQUIPMENT | | N/A |
| | - parts of the ME EQUIPMENT that are not serviced or maintained while in use with the patient | | N/A |
| | – name or trademark and address of the MANUFACTURER |  | P |
| | – MODEL OR TYPE REFERENCE | GT*96225*P****-* | P |
| | Instruction for use included the following when the PATIENT is an intended OPERATOR: | | N/A |
| | – the PATIENT is an intended OPERATOR | | N/A |
| | – warning against servicing and maintenance while the ME EQUIPMENT is in use | | N/A |
| | - functions the PATIENT can safely use and, where applicable, which functions the PATIENT cannot safely use; and | | N/A |
| | –maintenance the PATIENT can perform | | N/A |
| | Classifications as in Clause 6, all markings per Clause 7.2, and explanation of safety signs and symbols marked on ME EQUIPMENT | | P |
| | Instructions for use are in a language acceptable to the intended operator | English. | P |
| 7.9.2.2 | Instructions for use include all warning and safety notices | | P |
| | Warning statement for CLASS I ME EQUIPMENT included | | P |
| | Warnings regarding significant RISKS of reciprocal interference posed by ME EQUIPMENT during specific investigations or treatments | | P |

| IEC 60601-1 | | | |
|----------------|--|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Information on potential electromagnetic or other interference and advice on how to avoid or minimize such interference | | P |
| | Warning statement for ME EQUIPMENT supplied with an integral MULTIPLE SOCKET-OUTLET provided | No multiple socket-outlet. | N/A |
| | The RESPONSIBLE ORGANIZATION is referred to this standard for the requirements applicable to ME SYSTEMS | | N/A |
| 7.9.2.3 | Statement on ME EQUIPMENT for connection to a separate power supply provided in instructions | | N/A |
| 7.9.2.4 | Warning statement for mains- operated ME EQUIPMENT with additional power source not automatically maintained in a fully usable condition indicating the necessity for periodic checking or replacement of power source | | N/A |
| | RISK MANAGEMENT FILE assesses the RISK resulting from leakage of batteries : (ISO 14971 Cl. 4.2-4.4, 5, 6.3) | | N/A |
| | Where the RISK is unacceptable, the IFU includes a warning to remove the battery if the ME EQUIPMENT is not likely to be used for some time..... : | No battery. | N/A |
| | Specifications of replaceable INTERNAL ELECTRICAL POWER SOURCE when provided..... : | No internal electrical power source. | N/A |
| | Warning indicating ME EQUIPMENT must be connected to an appropriate power source when loss of power source would result in an unacceptable RISK : | Further evaluation is needed on end product level. | N/A |
| 7.9.2.5 | Instructions for use include a description of ME EQUIPMENT, its functions, significant physical and performance characteristics together with the expected positions of OPERATOR, PATIENT, or other persons near ME EQUIPMENT in NORMAL USE | | P |
| | Information provided on materials and ingredients PATIENT or OPERATOR is exposed to | | N/A |
| | Restrictions specified on other equipment or NETWORK/DATA COUPLINGS, other than those forming part of an ME SYSTEM, to which a SIGNAL INPUT/OUTPUT PART may be connected | No SIP/SOP. | N/A |
| | APPLIED PARTS specified | No applied parts. | N/A |
| 7.9.2.6 | Information provided indicating where the installation instructions may be found or information on qualified personnel who can perform the installation | | N/A |

| IEC 60601-1 | | | |
|-------------|--|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.9.2.7 | Instructions provided indicating not to position ME EQUIPMENT to make it difficult to operate the disconnection device | | N/A |
| 7.9.2.8 | Necessary information provided for OPERATOR to bring ME EQUIPMENT into operation | | N/A |
| 7.9.2.9 | Information provided to operate ME EQUIPMENT | | N/A |
| | Meanings of figures, symbols, warning statements, abbreviations and indicator lights described in instructions for use | | N/A |
| 7.9.2.10 | A list of all system messages, error messages, and fault messages provided with an explanation of messages including important causes and possible action(s) to be taken to resolve the problem indicated by the message | | N/A |
| 7.9.2.11 | Information provided for the OPERATOR to safely terminate operation of ME EQUIPMENT | | P |
| 7.9.2.12 | Information provided on cleaning, disinfection, and sterilization methods, and applicable parameters that can be tolerated by ME EQUIPMENT parts or ACCESSORIES specified | | N/A |
| | Components, ACCESSORIES or ME EQUIPMENT marked for single use, except when required by MANUFACTURER to be cleaned, disinfected, or sterilized prior to use | | N/A |
| 7.9.2.13 | Instructions provided on preventive inspection, calibration, maintenance and its frequency | Further evaluation is needed on end product level. | N/A |
| | Information provided for safe performance of routine maintenance necessary to ensure continued safe use of ME EQUIPMENT | | N/A |
| | Parts requiring preventive inspection and maintenance to be performed by SERVICE PERSONNEL identified including periods of application | | N/A |
| | Instructions provided to ensure adequate maintenance of ME EQUIPMENT containing rechargeable batteries to be maintained by anyone other than SERVICE PERSONNEL | | N/A |
| 7.9.2.14 | A list of ACCESSORIES, detachable parts, and materials for use with ME EQUIPMENT provided | No accessories. | N/A |
| | Other equipment providing power to ME SYSTEM sufficiently described | | N/A |
| 7.9.2.15 | Disposal of waste products, residues, etc., and of ME EQUIPMENT and ACCESSORIES at the end of their EXPECTED SERVICE LIFE are identified in the instruction for use | | N/A |

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.9.2.16 | Instructions for use include information specified in 7.9.3 or identify where it can be found (e.g. in a service manual) | | P |
| 7.9.2.17 | Instruction for use for ME EQUIPMENT emitting radiation for medical purposes, indicate the nature, type, intensity and distribution of this radiation | | N/A |
| 7.9.2.18 | The instructions for use for ME EQUIPMENT or ACCESSORIES supplied sterile indicate that they have been sterilized and the method of sterilization | | N/A |
| | The instructions for use indicate the necessary instructions in the event of damage to the sterile packaging, and where appropriate, details of the appropriate methods of re-sterilization | | N/A |
| 7.9.2.19 | The instructions for use contain a unique version identifier: | Version A | P |
| 7.9.3 | Technical description | | P |
| 7.9.3.1 | All essential data provided for safe operation, transport, storage, and measures or conditions necessary for installing ME EQUIPMENT, and preparing it for use | | P |
| | Technical description separable from instructions for use contains required information, as follows | | P |
| | – all applicable classifications in Clause 6, warning and safety notices, and explanation of safety signs marked on ME EQUIPMENT | | P |
| | – a brief description of the ME EQUIPMENT, how the ME EQUIPMENT functions and its significant physical and performance characteristics; and | | P |
| | a unique version identifier: | | P |
| | MANUFACTURER'S optional requirements for minimum qualifications of SERVICE PERSONNEL documented in technical description | | N/A |
| 7.9.3.2 | The technical description contains the following required information | | N/A |
| | –type and full rating of fuses used in SUPPLY MAINS external to PERMANENTLY INSTALLED ME EQUIPMENT: | | N/A |
| | – a statement for ME EQUIPMENT with a non-DETACHABLE POWER SUPPLY CORD if POWER SUPPLY CORD is replaceable by SERVICE PERSONNEL, and | | N/A |
| | – instructions for correct replacement of interchangeable or detachable parts specified by MANUFACTURER as replaceable by SERVICE PERSONNEL, and | | N/A |

| IEC 60601-1 | | | |
|----------------|--|-----------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | RISK MANAGEMENT FILE includes an assessment to determine if replacement of components results in any unacceptable RISKS..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | – warnings identifying nature of HAZARD when replacement of a component could result in an unacceptable RISK, and when replaceable by SERVICE PERSONNEL all information necessary to safely replace the component | | N/A |
| 7.9.3.3 | Technical description indicates, MANUFACTURER will provide circuit diagrams, component part lists, descriptions, calibration instructions to assist to SERVICE PERSONNEL in parts repair | | N/A |
| 7.9.3.4 | Means used to comply with requirements of 8.11.1 clearly identified in technical description | | P |

| | | | |
|--------------|--|---------------------------|------------|
| 8 | PROTECTION AGAINST ELECTRICAL HAZARDS FROM ME EQUIPMENT | | P |
| 8.1 | Limits specified in Clause 8.4 not exceeded for ACCESSIBLE PARTS and APPLIED PARTS in NORMAL or SINGLE FAULT CONDITIONS | | P |
| | RISK MANAGEMENT FILE identifies conductors and connectors where breaking free results in a HAZARDOUS SITUATION : (ISO 14971 Cl. 4.3) | GT-RM2020-003 Cl.6.3 No.6 | P |
| 8.2 | Requirements related to power sources | | N/A |
| 8.2.1 | Connection to a separate power source | | N/A |
| | When ME EQUIPMENT specified for connection to a separate power source other than SUPPLY MAINS, separate power source considered as part of ME EQUIPMENT or combination considered as an ME SYSTEM | Connect to mains only. | N/A |
| | Tests performed with ME EQUIPMENT connected to separate power supply when one specified | | N/A |
| | When a generic separate power supply specified, specification in ACCOMPANYING DOCUMENTS examined | | N/A |
| 8.2.2 | Connection to an external d.c. power source | | N/A |
| | No HAZARDOUS SITUATION as described in 13.1 developed when a connection with wrong polarity made for ME EQUIPMENT from an external d.c. source | | N/A |
| | ME EQUIPMENT connected with correct polarity maintained BASIC SAFETY and ESSENTIAL PERFORMANCE | | N/A |

| IEC 60601-1 | | | |
|--------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Protective devices that can be reset by anyone without a TOOL returns to NORMAL CONDITION on reset | | N/A |
| 8.3 | Classification of APPLIED PARTS | | N/A |
| | a) APPLIED PART specified in ACCOMPANYING DOCUMENTS as suitable for DIRECT CARDIAC APPLICATION is TYPE CF | No applied part. | N/A |
| | b) An APPLIED PART provided with a PATIENT CONNECTION intended to deliver electrical energy or an electrophysiological signal to or from PATIENT is TYPE BF or CF APPLIED PART | | N/A |
| | c) An APPLIED PART not covered by a) or b) is a TYPE B, BF, or CF | | N/A |
| 8.4 | Limitation of voltage, current or energy | | P |
| 8.4.2 | ACCESSIBLE PARTS and APPLIED PARTS | | P |
| | a) Currents from, to, or between PATIENT CONNECTIONS did not exceed limits for PATIENT LEAKAGE CURRENT & PATIENT AUXILIARY CURRENT : | | N/A |
| | b) LEAKAGE CURRENTS from, to, or between ACCESSIBLE PARTS did not exceed limits for TOUCH CURRENT..... : | See appended Table 8.7 | P |
| | c) Limits specified in b) not applied to parts when probability of a connection to a PATIENT, directly or through body of OPERATOR, is negligible in NORMAL USE, and the OPERATOR is appropriately instructed | The likelihood of the current flowing through body of OPERATOR to be determined in end-product evaluation. | N/A |
| | Voltage to earth or to other ACCESSIBLE PARTS did not exceed 42.4 V peak a.c. or 60 V d.c. for above parts in NORMAL or single fault condition (V a.c. or d.c.) : | See appended Table 8.4.2 | P |
| | Energy did not exceed 240 VA for longer than 60 s or stored energy available did not exceed 20 J at a potential of 2 V or more (VA or J)..... : | See appended Table 8.4.2 | P |
| | d) Voltage and energy limits specified in c) above also applied to the following: | No such part. | N/A |
| | – internal parts touchable by test pin in Fig 8 inserted through an opening in an ENCLOSURE; and | No internal part is touchable for potted model. Open frame model shall be determined in end product evaluation | N/A |
| | – internal parts touchable by a metal test rod with a diameter of 4 mm and a length 100 mm, inserted through any opening on top of ENCLOSURE or through any opening provided for adjustment of pre-set controls by RESPONSIBLE ORGANIZATION in NORMAL USE using a TOOL | | N/A |

| IEC 60601-1 | | | |
|----------------|---|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Test pin or the test rod inserted through relevant openings with minimal force of no more than 1 N | No opening for potted model. Open frame model shall be determined in end product evaluation | N/A |
| | Test rod inserted in every possible position through openings provided for adjustment of pre-set controls that can be adjusted in NORMAL USE, with a force of 10 N | | N/A |
| | Test repeated with a TOOL specified in instructions for use | | N/A |
| | Test rod freely and vertically suspended through openings on top of ENCLOSURE | | N/A |
| | e) Devices used to de-energize parts when an ACCESS COVER opened without a TOOL gives access to parts at voltages above levels permitted by this Clause comply with 8.11.1 for mains isolating switches and remain effective in SINGLE FAULT CONDITION | No such part for potted model. Open frame model shall be determined in end product evaluation | N/A |
| | A TOOL is required when it is possible to prevent the devices from operating | | N/A |
| 8.4.3 | Worst case voltage between pins of plug and between either supply pin and ENCLOSURE did not exceed 60 V one sec after disconnecting the plug of ME EQUIPMENT or its parts (V)..... : | See appended Table 8.4.3 | P |
| | When voltage exceeded 60 V, calculated or measured stored charge didn't exceed 45 μC .. : | See appended Table 8.4.3 | P |
| 8.4.4 | Residual voltage of conductive parts of capacitive circuits, having become accessible after ME EQUIPMENT was de-energized after removal of ACCESS COVERS, didn't exceed 60V or calculated stored charge didn't exceed 45μC .. : | No such part. | N/A |
| | A device manually discharging capacitors used when automatic discharging was not possible and ACCESS COVERS could be removed only with aid of a TOOL | | N/A |
| | Capacitor(s) and connected circuitry marked with symbol 24 of Table D.1, and manual discharging device specified in technical description | | N/A |
| 8.5 | Separation of parts | | P |
| 8.5.1 | MEANS OF PROTECTION (MOP) | | P |
| 8.5.1.1 | Two MEANS of PROTECTION provided for ME EQUIPMENT to prevent APPLIED and other ACCESSIBLE PARTS from exceeding limits in 8.4 | | P |

| IEC 60601-1 | | | |
|----------------|--|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Varnishing, enamelling, oxidation, and similar protective finishes and coatings with sealing compounds re-plasticizing at temperatures expected during operation and sterilization disregarded as MEANS OF PROTECTION | | P |
| | Components and wiring forming a MEANS OF PROTECTION comply with 8.10 | | P |
| 8.5.1.2 | MEANS OF PATIENT PROTECTION (MOPP) | | P |
| | Solid insulation forming a MEANS OF PATIENT PROTECTION complied with dielectric strength test..... : | See appended Table 8.8.3 | P |
| | CREEPAGE and CLEARANCES forming a MEANS OF PATIENT PROTECTION complied with Table 12 | | P |
| | PROTECTIVE EARTH CONNECTIONS forming a MEANS OF PATIENT PROTECTION complied with Cl. 8.6 | Class I power adapter models have been checked. Open frame model shall be determined in end product evaluation. | P |
| | Y1 or Y2 capacitor complying with standard IEC 60384-14 considered one MEANS OF PATIENT PROTECTION : | See appended Tables 8.8.3 and 8.10 | P |
| | Single Y1 capacitor used for two MEANS OF PATIENT PROTECTION when the working voltage is less than 42,4 V peak a.c. or 60 V d.c. : | See appended Tables 8.8.3 and 8.10 | P |
| | Two capacitors used in series, each RATED for total WORKING VOLTAGE across the pair and have the same NOMINAL capacitance | Two identical Y1 used in series. | P |
| | Voltage Total Working (V) and C Nominal (μF) : | 250VAC, Max.1500pF | — |
| 8.5.1.3 | MEANS OF OPERATOR PROTECTION (MOOP) | | P |
| | Solid insulation forming a MEANS OF OPERATOR PROTECTION complied with: | The separation between primary and secondary was evaluated by MOPP. | P |
| | – dielectric strength test : | See appended Table 8.8.3 | P |
| | – requirements of IEC 60950-1 for INSULATION CO-ORDINATION | | N/A |
| | CREEPAGE and CLEARANCES forming a MEANS OF OPERATOR PROTECTION complied with: | | P |
| | – limits of Tables 13 to 16 (inclusive); or | | P |
| | – requirements of IEC 60950-1 for INSULATION CO-ORDINATION | | N/A |
| | PROTECTIVE EARTH CONNECTIONS forming a MEANS OF OPERATOR PROTECTION complied with Cl. 8.6 | | N/A |

| IEC 60601-1 | | | |
|-------------|--|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – or with requirements and tests of IEC 60950-1 for protective earthing..... : | | N/A |
| | A Y2 (IEC 60384-14) capacitor is considered one MEANS OF OPERATOR PROTECTION : | | N/A |
| | A Y1 (IEC 60384-14) capacitor is considered two MEANS OF OPERATOR PROTECTION : | | N/A |
| | Two capacitors used in series each RATED for total WORKING VOLTAGE across the pair and have the same NOMINAL capacitance | | N/A |
| | Voltage Total Working (V) and C Nominal (μF) : | | — |
| | Points and applied parts at which impedances of components, CREEPAGE, CLEARANCES, PROTECTIVE EARTH CONNECTIONS or insulation, prevent ACCESSIBLE PARTS from exceeding limits in 8.4 were examined whether a failure at any of these points is to be regarded as a NORMAL or SINGLE FAULT CONDITION | | P |
| | A MEANS OF PROTECTION protecting APPLIED PARTS, or parts identified by 4.6 as parts subject to the same requirements, considered MEANS OF PATIENT PROTECTION..... : | See the insulation diagram. | P |
| | A MEANS OF PROTECTION protecting other parts considered MEANS OF OPERATOR PROTECTION : | EUT is evaluated according to requirement of MOPP. | N/A |
| 8.5.2 | Separation of PATIENT CONNECTIONS | | N/A |
| 8.5.2.1 | PATIENT CONNECTIONS of F-TYPE APPLIED PART separated from all other parts by equivalent to one MEANS OF PATIENT PROTECTION for a WORKING VOLTAGE equal to the MAX. MAINS VOLTAGE : | No patient connections. | N/A |
| | Separation requirement not applied between multiple functions of a single F-TYPE APPLIED PART | | N/A |
| | PATIENT CONNECTIONS treated as one APPLIED PART in the absence of electrical separation between PATIENT CONNECTIONS of same or another function | | N/A |
| | MANUFACTURER has defined if multiple functions are to be considered as all within one APPLIED PART or as multiple APPLIED PARTS : | | N/A |
| | Classification as TYPE BF, CF, or DEFIBRILLATION-PROOF applied to one entire APPLIED PART | | N/A |
| | LEAKAGE CURRENT tests conducted per 8.7.4 : | See appended Table 8.7 | N/A |
| | Dielectric strength test conducted per 8.8.3..... : | See appended Table 8.8.3 | N/A |
| | CREEPAGE and CLEARANCES measured : | Refer to Insulation Diagram | N/A |

| IEC 60601-1 | | | |
|----------------|--|--------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | A protective device connected between PATIENT CONNECTIONS of an F-TYPE APPLIED PART and ENCLOSURE to protect against excessive voltages did not operate below 500 V r.m.s | | N/A |
| 8.5.2.2 | PATIENT CONNECTIONS of a TYPE B APPLIED PART not PROTECTIVELY EARTHED are separated by one MEANS OF PATIENT PROTECTION from metal ACCESSIBLE PARTS not PROTECTIVELY EARTHED : | | N/A |
| | – except when metal ACCESSIBLE PART is physically close to APPLIED PART and can be regarded as a part of APPLIED PART; and | | N/A |
| | – RISK that metal ACCESSIBLE PART will make contact with a source of voltage or LEAKAGE CURRENT above permitted limits is acceptably low | | N/A |
| | LEAKAGE CURRENT tests conducted per 8.7.4 : | | N/A |
| | Dielectric strength test conducted per 8.8.3.... : | | N/A |
| | Relevant CREEPAGE and CLEARANCES measured | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of the RISK of metal ACCESSIBLE PARTS contacting a source of voltage or LEAKAGE CURRENT above the limits: (ISO 14971 Cl. 4.2-4.4, 5) | | N/A |
| 8.5.2.3 | A connector on a PATIENT lead or PATIENT cable located at the end of the lead or cable remote from PATIENT, with conductive part not separated from all PATIENT CONNECTIONS by one MEANS OF PATIENT PROTECTION for a WORKING VOLTAGE equal to MAXIMUM MAINS VOLTAGE | | N/A |
| | - cannot be connected to earth or hazardous voltage while the PATIENT CONNECTIONS are in contact with PATIENT : | | N/A |
| | – conductive part of connector not separated from all PATIENT CONNECTIONS did not come into contact with a flat conductive plate of not less than 100 mm diameter | | N/A |
| | – CLEARANCE between connector pins and a flat surface is at least 0.5 mm | | N/A |
| | – conductive part pluggable into a mains socket protected from making contact with parts at MAINS VOLTAGE by insulation with a CREEPAGE DISTANCE of at least 1.0 mm, a 1500 V dielectric strength and complying with 8.8.4.1 | | N/A |
| | – required test finger did not make electrical contact with conductive part when applied against access openings with a force of 10 N, | | N/A |
| | Test finger test (10 N) : | See appended Table 5.9.2 | N/A |

| IEC 60601-1 | | | |
|----------------|--|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Except when RISK MANAGEMENT PROCESS includes an assessment of RISKS resulting from contact with objects other than mains sockets or flat surfaces : (ISO 14971 Cl. 4.2-4.4, 5) | | N/A |
| 8.5.4 | WORKING VOLTAGE | | P |
| | – Input supply voltage to ME EQUIPMENT was RATED voltage or voltage within RATED range resulting in highest measured value (V) : | 240Vac | P |
| | – WORKING VOLTAGE for d.c. voltages with superimposed ripple was average value when peak-to-peak ripple less than 10% of average value or peak voltage when peak-to-peak ripple exceeding 10% of average value (V)..... : | | P |
| | – WORKING VOLTAGE for each MEANS OF PROTECTION forming DOUBLE INSULATION was voltage DOUBLE INSULATION, as a whole, subjected to (V)..... : | See Insulation Diagram and Insulation Table | P |
| | – Intentional or accidental earthing of PATIENT regarded as a NORMAL CONDITION for WORKING VOLTAGE involving a PATIENT CONNECTION not connected to earth | No patient connection. | N/A |
| | – WORKING VOLTAGE between PATIENT CONNECTIONS of an F-TYPE APPLIED PART and ENCLOSURE was highest voltage appearing across insulation in NORMAL USE including earthing of any part of APPLIED PART (V)..... : | No applied part. | N/A |
| | – WORKING VOLTAGE for DEFIBRILLATION-PROOF APPLIED PARTS determined disregarding possible presence of defibrillation voltages | No applied parts. | N/A |
| | – WORKING VOLTAGE was equal to resonance voltage in case of motors provided with capacitors between the point where a winding and a capacitor are connected together and a terminal for external conductors (V)..... : | No motor. | N/A |
| 8.5.5 | DEFIBRILLATION-PROOF APPLIED PARTS | | N/A |
| 8.5.5.1 | Classification “DEFIBRILLATION-PROOF APPLIED PART” applied to one APPLIED PART in its entirety | No applied parts. | N/A |
| | Isolation of PATIENT CONNECTIONS of a DEFIBRILLATION-PROOF APPLIED PART from other parts of ME EQUIPMENT accomplished as follows: | | N/A |
| | a) No hazardous electrical energies appear during a discharge of cardiac defibrillator : | See appended Table 8.5.5.1a | N/A |

| IEC 60601-1 | | | |
|----------------|--|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | b) ME EQUIPMENT complied with relevant requirements of this standard, providing BASIC SAFETY and ESSENTIAL PERFORMANCE following exposure to defibrillation voltage, and recovery time stated in ACCOMPANYING DOCUMENTS : | See appended Table 8.5.5.1b | N/A |
| 8.5.5.2 | Means provided to limit energy delivered to a 100 Ω load..... : | See appended Table 8.5.5.2 | N/A |
| 8.6 | Protective and functional earthing and potential equalization of ME EQUIPMENT | | P |
| 8.6.1 | Requirements of 8.6.2 to 8.6.8 applied | | P |
| | Parts complying with IEC 60950-1 for protective earthing and serving as MEANS OF OPERATOR PROTECTION but not PATIENT PROTECTION exempted from requirements of 8.6.2 to 8.6.8 | No such parts | N/A |
| 8.6.2 | PROTECTIVE EARTH TERMINAL is suitable for connection to an external protective earthing system by a PROTECTIVE EARTH CONDUCTOR in a POWER SUPPLY CORD and a suitable plug or by a FIXED PROTECTIVE EARTH CONDUCTOR..... : | Further evaluation is needed on end product level. | N/A |
| | Clamping means of PROTECTIVE EARTH TERMINAL of ME EQUIPMENT for FIXED supply conductors or POWER SUPPLY CORDS comply with 8.11.4.3, and cannot be loosened without TOOL | No such construction | N/A |
| | Screws for internal PROTECTIVE EARTH CONNECTIONS completely covered or protected against accidental loosening from outside : | No such construction | N/A |
| | Earth pin of APPLIANCE INLET forming supply connection to ME EQUIPMENT regarded as PROTECTIVE EARTH TERMINAL | | P |
| | PROTECTIVE EARTH TERMINAL not used for mechanical connection between different parts of ME EQUIPMENT or securing components not related to protective or functional earthing | No such construction | N/A |
| 8.6.3 | PROTECTIVE EARTH CONNECTION not used for a moving part, | Final determination in end product for open frame model. | N/A |
| | except when MANUFACTURER demonstrated in RISK MANAGEMENT FILE connection will remain reliable during EXPECTED SERVICE LIFE : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 8.6.4 | a) PROTECTIVE EARTH CONNECTIONS carried fault currents reliably and without excessive voltage drop..... : | For Class I model, the maximum grounding impedance is 16m Ω . Final determination in end product for open frame model. | P |

| IEC 60601-1 | | | |
|--------------|---|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | b) Allowable TOUCH CURRENT and PATIENT LEAKAGE CURRENT in SINGLE FAULT CONDITION were not exceeded, when impedance of PROTECTIVE EARTH CONNECTIONS exceeded values in 8.6.4 a) and Table 8.6.4, due to limited current capability of relevant circuits | See appended Table 8.6.4 & Clause 8.7 | N/A |
| 8.6.5 | Surface coatings | | N/A |
| | Poorly conducting surface coatings on conductive elements removed at the point of contact | | N/A |
| | Coating not removed when requirements for impedance and current-carrying capacity met | | N/A |
| 8.6.6 | Plugs and sockets | | P |
| | PROTECTIVE EARTH CONNECTION where connection between SUPPLY MAINS and ME EQUIPMENT or between separate parts of ME EQUIPMENT made via a plug and socket was made before and interrupted after supply connections | To be determined in end product evaluation. | P |
| | - applied also where interchangeable parts are PROTECTIVELY EARTHED | | N/A |
| 8.6.7 | Terminal for connection of a POTENTIAL EQUALIZATION CONDUCTOR | | N/A |
| | – Terminal is accessible to OPERATOR with ME EQUIPMENT in any position of NORMAL USE | | N/A |
| | –accidental disconnection avoided in NORMAL USE | | N/A |
| | – Terminal allows conductor to be detached without a TOOL | | N/A |
| | – Terminal not used for a PROTECTIVE EARTH CONNECTION | | N/A |
| | – Terminal marked with symbol 8 of Table D.1 | | N/A |
| | – Instructions for use contain information on function and use of POTENTIAL EQUALIZATION CONDUCTOR together with a reference to requirements of this standard | | N/A |
| | POWER SUPPLY CORD does not incorporate a POTENTIAL EQUALIZATION CONDUCTOR | | N/A |
| 8.6.8 | FUNCTIONAL EARTH TERMINAL not used to provide a PROTECTIVE EARTH CONNECTION | | N/A |
| 8.6.9 | Class II ME EQUIPMENT | | N/A |
| | Third conductor of POWER SUPPLY CORD connected to protective earth contact of MAINS PLUG provided with CLASS II ME EQUIPMENT with isolated internal screens used as functional earth connection to the screen's FUNCTIONAL EARTH TERMINAL, coloured green and yellow | | N/A |

| IEC 60601-1 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | ACCOMPANYING DOCUMENTS include a statement that the third conductor in the POWER SUPPLY CORD is only a functional earth. | | N/A |
| | Two MEANS OF PROTECTION provided between insulation of internal screens and all internal wiring connected to them and ACCESSIBLE PARTS | | N/A |
| 8.7 | LEAKAGE CURRENTS and PATIENT AUXILIARY CURRENTS | | P |
| 8.7.1 | a) Electrical isolation providing protection against electric shock limits currents to values in 8.7.3..... : | See appended Tables 8.7 | P |
| | b) Specified values of EARTH LEAKAGE, TOUCH, PATIENT LEAKAGE, and PATIENT AUXILIARY CURRENTS applied in combination of conditions in appended Table 8.7 : | See appended Tables 8.7 | P |
| 8.7.2 | Allowable values specified in 8.7.3 applied under SINGLE FAULT CONDITIONS of 8.1 b), except | | P |
| | – where insulation used in conjunction with a PROTECTIVE EARTH CONNECTION, insulation short circuited only under conditions in 8.6.4 b) | Final determination in end product for open frame model. | N/A |
| | – the only SINGLE FAULT CONDITION for EARTH LEAKAGE CURRENT was interruption of one supply conductor at a time | Final determination in end product for open frame model. So earth leakage current was not measured. | N/A |
| | – LEAKAGE CURRENTS and PATIENT AUXILIARY CURRENT not measured in SINGLE FAULT CONDITION of short circuiting of one constituent part of DOUBLE INSULATION | | P |
| | SINGLE FAULT CONDITIONS not applied at same time as special test conditions of MAXIMUM MAINS VOLTAGE ON APPLIED PARTS and non-PROTECTIVELY EARTHED parts of ENCLOSURE | | P |
| 8.7.3 | Allowable Values | | P |
| | a) Allowable values in 8.7.3 b), c), and d) measured based on, and are relative to currents in Fig 12 a), or by a device measuring frequency contents of currents as in Fig 12 b. : | See appended Table 8.7 | P |
| | b) Allowable values of PATIENT LEAKAGE and AUXILIARY CURRENTS are according to Tables 3 & 4, and values of a.c. are relative to currents having a frequency not less than 0.1Hz : | See appended Table 8.7 | N/A |
| | c) TOUCH CURRENT did not exceed 100 μ A in NORMAL CONDITION and 500 μ A in SINGLE FAULT CONDITION (I_{TNC} , I_{TSFC})..... : | See appended Table 8.7 | P |
| | d) EARTH LEAKAGE CURRENT did not exceed 5 mA in NORMAL CONDITION and 10 mA in SINGLE FAULT CONDITION (I_{ENC} , I_{ESFC}) : | See appended Table 8.7 | P |

| IEC 60601-1 | | | |
|--------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Higher values of EARTH LEAKAGE CURRENT permitted for PERMANENTLY INSTALLED ME EQUIPMENT connected to a supply circuit supplying only this ME EQUIPMENT according to local regulations or IEC 60364-7-710 : | Not permanently installed ME equipment | N/A |
| | e) LEAKAGE CURRENTS, regardless of waveform and frequency, did not exceed 10 mA r.m.s. in NORMAL or in SINGLE FAULT CONDITION (measured with a non-frequency-weighted device : | See appended Table 8.7 | P |
| | f) LEAKAGE CURRENTS flowing in a FUNCTIONAL EARTH CONDUCTOR in a non-PERMANENTLY INSTALLED ME EQUIPMENT are 5 mA in NORMAL CONDITION, 10 mA in SINGLE FAULT CONDITION : | See appended Table 8.7 | N/A |
| 8.7.4 | LEAKAGE and PATIENT AUXILIARY CURRENTS measurements : | See appended Table 8.7 | P |
| 8.8 | Insulation | | P |
| 8.8.1 | Insulation relied on as MEANS OF PROTECTION, including REINFORCED INSULATION subjected to testing | | P |
| | Insulation exempted from test (complies with clause 4.8) | | P |
| | Insulation forming MEANS OF OPERATOR PROTECTION and complying with IEC 60950-1 for INSULATION CO-ORDINATION not tested as in 8.8 | | N/A |
| 8.8.2 | Distance through solid insulation or use of thin sheet material | | P |
| | Solid insulation forming SUPPLEMENTARY or REINFORCED INSULATION for a PEAK WORKING VOLTAGE greater than 71 V provided with: | | P |
| | a) 0.4 mm, min, distance through insulation, or | Enclosure is 2.0mm thick | P |
| | b) does not form part of an ENCLOSURE and not subject to handling or abrasion during NORMAL USE, and comprised of: | | P |
| | – at least two layers of material, each passed the appropriate dielectric strength test..... : | See appended Table 8.8.3 | P |
| | – or three layers of material, for which all combinations of two layers together passed the appropriate dielectric strength test..... : | See appended Table 8.8.3 | N/A |
| | Dielectric strength test for one or two layers was same as for one MEANS OF PROTECTION for SUPPLEMENTARY INSULATION | | N/A |
| | Dielectric strength test for one or two layers was same as for two MEANS OF PROTECTION for REINFORCED INSULATION | | P |

| IEC 60601-1 | | | |
|----------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | BASIC, SUPPLEMENTARY, and REINFORCED INSULATION required between windings of wound components separated by interleaved insulation complying with a) or b), or both, except when | | N/A |
| | c) Wire with solid insulation, other than solvent based enamel, complying with a) | | N/A |
| | d) Wire with multi-layer extruded or spirally wrapped insulation complying with b) and complying with Annex L | | N/A |
| | e) Finished wire with spirally wrapped or multi-layer extruded insulation, complying with Annex L | Certified triple insulated wire is used. | P |
| | – BASIC INSULATION: minimum two wrapped layers or one extruded layer | | N/A |
| | – SUPPLEMENTARY INSULATION: minimum two layers, wrapped or extruded | | N/A |
| | – REINFORCED INSULATION: minimum three layers, wrapped or extruded | | P |
| | In d) and e), for spirally wrapped insulation with CREEPAGE DISTANCES between layers less than in Table 12 or 16 (Pollution Degree 1) depending on type of insulation, path between layers sealed as a cemented joint in 8.9.3.3 and test voltages of TYPE TESTS in L.3 equal 1.6 times of normal values | | N/A |
| | Protection against mechanical stress provided where two insulated wires or one bare and one insulated wire are in contact inside wound component, crossing at an angle between 45° and 90° and subject to winding tension | Additional protection by insulating tape. | P |
| | Finished component complied with routine dielectric strength tests of 8.8.3..... | See appended Table 8.8.3 | N/A |
| | Tests of Annex L not repeated since material data sheets confirm compliance | See Table 8.10 and Material Information Attachment | P |
| 8.8.3 | Dielectric Strength | | P |
| | Solid insulating materials with a safety function withstood dielectric strength test voltages | See appended Table 8.8.3 | P |
| 8.8.4 | Insulation other than wire insulation | | P |
| 8.8.4.1 | Resistance to heat retained by all insulation and insulating partition walls during EXPECTED SERVICE LIFE OF ME EQUIPMENT | | P |
| | ME EQUIPMENT and design documentation examined | Final determination in the end-product evaluation | N/A |

| IEC 60601-1 | | | |
|----------------|--|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | RISK MANAGEMENT FILE examined in conjunction with resistance to moisture, dielectric strength, and mechanical strength tests..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | Final determination in the end-product evaluation. | N/A |
| | Satisfactory evidence of compliance provided by manufacturer for resistance to heat : | | N/A |
| | Tests conducted in absence of satisfactory evidence for resistance to heat : | Ball pressure test performed | P |
| | a) ENCLOSURE and other external parts of insulating material, except insulation of flexible cords and parts of ceramic material, subjected to ball-pressure test using Fig 21 apparatus ... : | See appended Table 8.8.4.1 | P |
| | b) Parts of insulating material supporting uninsulated parts of MAINS PART subjected to ball-pressure test in a), except at 125 °C ± 2 ° C or ambient indicated in technical description ±2°C plus temperature rise determined during test of 11.1 of relevant part, if higher (°C) : | See appended Table 8.8.4.1 | P |
| | Test not performed on parts of ceramic material, insulating parts of commutators, brush-caps, and similar, and on coil formers not used as REINFORCED INSULATION | | N/A |
| 8.8.4.2 | Resistance to environmental stress | | P |
| | Insulating characteristics and mechanical strength of all MEANS OF PROTECTION not likely to be impaired by environmental stresses including deposition of dirt resulting from wear of parts within EQUIPMENT, potentially reducing CREEPAGE and CLEARANCES below 8.9 | | P |
| | Ceramic and similar materials not tightly sintered, and beads alone not used as SUPPLEMENTARY OF REINFORCED INSULATION | | N/A |
| | Insulating material with embedded heating conductors considered as one MEANS OF PROTECTION but not two MEANS OF PROTECTION | | N/A |
| | Parts of natural latex rubber aged by suspending samples freely in an oxygen cylinder containing commercial oxygen to a pressure of 2.1 MPa ± 70 kPa, with an effective capacity of at least 10 times volume of samples | | N/A |
| | There were no cracks visible to naked eyes after samples kept in cylinder at 70 °C ± 2 ° C for 96h, and afterwards, left at room temperature for at least 16h | | N/A |
| 8.9 | CREEPAGE DISTANCES and AIR CLEARANCES | | P |

| IEC 60601-1 | | | |
|-------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.9.1.1 | CREEPAGE DISTANCES and AIR CLEARANCES are equal to or greater than values in Tables 12 to 16 (inclusive) : | Refer to Insulation Diagram | P |
| 8.9.1.15 | CREEPAGE DISTANCES and AIR CLEARANCES for DEFIBRILLATION-PROOF APPLIED PARTS are 4 mm or more to meet 8.5.5.1 | No applied parts. | N/A |
| 8.9.2 | a) Short circuiting of each single one of CREEPAGE DISTANCES and CLEARANCES in turn did not result in a HAZARDOUS SITUATION, min CREEPAGE and CLEARANCES not applied : | See appended Table 8.9.2 | N/A |
| 8.9.3 | Spaces filled by insulating compound | | N/A |
| 8.9.3.1 | Only solid insulation requirements applied where distances between conductive parts filled with insulating compound | | N/A |
| | Thermal cycling, humidity preconditioning, and dielectric strength tests | | N/A |
| 8.9.3.2 | For insulating compound forming solid insulation between conductive parts, a single sample subjected to thermal cycling PROCEDURE of 8.9.3.4 followed by humidity preconditioning per 5.7 (for 48 hours), followed by dielectric strength test (cl. 8.8.3 at 1,6 x test voltage) : | See appended Table 8.9.3.2 | N/A |
| | Cracks or voids in insulating compound affecting homogeneity of material didn't occur | | N/A |
| 8.9.3.3 | Where insulating compound forms a cemented joint with other insulating parts, three samples tested for reliability of joint | | N/A |
| | A winding of solvent-based enamelled wire replaced for the test by a metal foil or by a few turns of bare wire placed close to cemented joint, and three samples tested as follows: | | N/A |
| | – One sample subjected to thermal cycling PROCEDURE of 8.9.3.4, and immediately after the last period at highest temperature during thermal cycling followed by dielectric strength test of cl. 8.8.3 at 1.6 x the test voltage : | See appended Table 8.9.3.3 | N/A |
| | – The other two samples subjected to humidity preconditioning of 5.7, except for 48 hours only followed by a dielectric strength test of cl. 8.8.3 at 1.6 times the test voltage | | N/A |
| 8.9.4 | Minimum spacing of grooves transvers to the CREEPAGE DISTANCES considered a MEANS OF OPERATOR PROTECTION adjusted based on pollution degree | Pollution degree: 2 | P |
| | Force was applied between bare conductors and outside metal enclosure when measuring CREEPAGE DISTANCES and AIR CLEARANCES | Refer to Insulation Diagram supplemental information for location and force used | P |

| IEC 60601-1 | | | |
|-----------------|---|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.10 | Components and wiring | | P |
| 8.10.1 | Components of ME EQUIPMENT likely to result in an unacceptable RISK by their movements mounted securely | Except open frame model, all the other models have been checked by inspection. No evidence of such risk is found. Final determination in the end-product for open frame model. | P |
| | RISK MANAGEMENT FILE includes an assessment of RISKS related to unwanted movement of components : (ISO 14791 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 8.10.2 | Conductors and connectors of ME EQUIPMENT adequately secured or insulated to prevent accidental detachment..... | Except open frame model, all the other models have been checked by inspection. No evidence of such risk is found. Final determination in the end-product for open frame model. | P |
| | Stranded conductors are not solder-coated when secured by clamping means to prevent HAZARDOUS SITUATIONS | No stranded conductor. | N/A |
| 8.10.3 | Interconnecting flexible cords detachable without a TOOL used provided with means for connection to comply with requirements for metal ACCESSIBLE PARTS when a connection is loosened or broken | See appended Table 5.9.2 | N/A |
| 8.10.4 | Cord-connected HAND-HELD parts and cord-connected foot-operated control devices | | N/A |
| 8.10.4.1 | Control devices of ME EQUIPMENT and their connection cords contain only conductors and components operating at 42.4 V peak a.c., max, or 60 V d.c. in circuits isolated from MAINS PART by two MEANS OF PROTECTION | No cord connected hand-held control device, no cord connected foot-operated control device. | N/A |
| 8.10.4.2 | Connection and anchorage of a flexible cord to a HAND-HELD or foot-operated control device of ME EQUIPMENT, at both ends of the cable to the control device, complies with the requirements for POWER SUPPLY CORDS in Cl. 8.11.3 | | N/A |
| | Other HAND-HELD parts, if disturbance or breaking of one or more of the connections could result in a HAZARDOUS SITUATION, also comply with tests of Cl. 8.11.3 | | N/A |
| 8.10.5 | Mechanical protection of wiring | | N/A |
| | a) Internal cables and wiring adequately protected against contact with a moving part or from friction at sharp corners and edges | No moving parts. | N/A |

| IEC 60601-1 | | | |
|---------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | b) Wiring, cord forms, or components are not likely to be damaged during assembly or during opening or closing of ACCESS COVERS | | N/A |
| 8.10.6 | Guiding rollers prevent bending of movable insulated conductors around a radius of less than five times the outer diameter of the lead | No guiding roller. | N/A |
| 8.10.7 | a) Insulating sleeve adequately secured..... : | See appended Table 8.10 | P |
| | b) Sheath of a flexible cord not used as a MEANS OF PROTECTION inside ME EQUIPMENT when it is subject to mechanical or thermal stresses beyond its RATED characteristics | | P |
| | c) Insulated conductors of ME EQUIPMENT subject to temperatures exceeding 70 °C : | See appended Table 8.10 | P |
| 8.11 | MAINS PARTS, components and layout | | P |
| 8.11.1 | a) ME EQUIPMENT provided with means of electrically isolating its circuits from SUPPLY MAINS simultaneously on all poles : | Component, to be determined in end product evaluation. | P |
| | PERMANENTLY INSTALLED ME EQUIPMENT connected to a poly-phase SUPPLY MAINS equipped with a device not interrupting neutral conductor, provided local installation conditions prevent voltage on neutral conductor from exceeding limits in 8.4.2 c) | Not permanently installed. | N/A |
| | PERMANENTLY INSTALLED ME EQUIPMENT provided with means to isolate its circuits electrically from the SUPPLY MAINS are capable of being locked in the off position | | N/A |
| | - the isolation device specified in the ACCOMPANYING DOCUMENTS | | P |
| | b) Means of isolation incorporated in ME EQUIPMENT, or if external, described in technical description : | Component, to be determined in end product evaluation. | N/A |
| | c) A SUPPLY MAINS switch used to comply with 8.11.1 a) complies with CREEPAGE / CLEARANCES for a MAINS TRANSIENT VOLTAGE of 4 kV..... : | See appended Table 8.10 | N/A |
| | d) A SUPPLY MAINS switch not incorporated in a POWER SUPPLY CORD or external flexible lead | | N/A |
| | e) Actuator of a SUPPLY MAINS switch used to comply with 8.11.1 a) complies with IEC 60447 | | N/A |
| | f) A suitable plug device used in non-PERMANENTLY INSTALLED ME EQUIPMENT with no SUPPLY MAINS SWITCH : | See appended Table 8.10 | N/A |
| | g) A fuse or a semiconductor device not used as an isolating means | | P |

| IEC 60601-1 | | | |
|-----------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | h) ME EQUIPMENT not provided with a device causing disconnection of ME EQUIPMENT from SUPPLY MAINS by producing a short circuit resulting in operation of an overcurrent protection device | | P |
| | i) Parts within ENCLOSURE of ME EQUIPMENT with a circuit > 42.4 V peak a.c. or 60 V d.c. that cannot be disconnected from its supply by an external switch or a plug device accessible at all times is protected against touch even after opening ENCLOSURE by an additional covering | No such part. | N/A |
| | A clear warning notice is marked on outside of ME EQUIPMENT to indicate it exceeds allowable touch voltage | | N/A |
| | For a part that could not be disconnected from supply by an external switch or a plug device accessible at all times, the required cover or warning notice complied with this clause | | N/A |
| | Standard test finger applied | | N/A |
| 8.11.2 | MULTIPLE SOCKET-OUTLETS integral with ME EQUIPMENT complied with 16.2 d), second dash; and 16.9.2 | No multiple socket-outlets. | N/A |
| 8.11.3 | POWER SUPPLY CORDS | | N/A |
| 8.11.3.1 | MAINS PLUG not fitted with more than one POWER SUPPLY CORD | No power supply cord. | N/A |
| 8.11.3.2 | POWER SUPPLY CORDS are no less robust than ordinary tough rubber sheathed flexible cord (IEC 60245-1:2003, Annex A, designation 53) or ordinary polyvinyl chloride sheathed flexible cord (IEC 60227-1:1993, Annex A, design 53)... : | No power supply cord. | N/A |
| | Only polyvinyl chloride insulated POWER SUPPLY CORD with appropriate temperature rating used for ME EQUIPMENT having external metal parts with a temperature > 75 °C touchable by the cord in NORMAL USE : | Not subject to such temperatures | N/A |
| 8.11.3.3 | NOMINAL cross-sectional area of conductors of POWER SUPPLY CORDS of ME EQUIPMENT is not less than in Table 17..... : | No power supply cord. | N/A |
| 8.11.3.4 | APPLIANCE COUPLERS complying with IEC 60320-1 are considered to comply with 8.11.3.5 and 8.11.3.6 : | | N/A |
| 8.11.3.5 | Cord anchorage | | N/A |
| | a) Conductors of POWER SUPPLY CORD provided with strain relief and insulation protected from abrasion at point of entry to ME EQUIPMENT or a MAINS CONNECTOR by a cord anchorage | Final determination in the end-product for open frame model. | N/A |

| IEC 60601-1 | | | |
|-----------------|--|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | b) Cord anchorage of POWER SUPPLY CORD is an insulating material, or | | N/A |
| | – metal, insulated from conductive ACCESSIBLE PARTS non-PROTECTIVELY EARTHED by a MEANS OF PROTECTION, or | | N/A |
| | – metal provided with an insulating lining affixed to cord anchorage | | N/A |
| | c) Cord anchorage prevents cord from being clamped by a screw bearing directly on cord insulation | | N/A |
| | d) Screws to be operated when replacing POWER SUPPLY CORD do not serve to secure any components | | N/A |
| | e) Conductors of POWER SUPPLY CORD arranged to prevent PROTECTIVE EARTH CONDUCTOR against strain as long as phase conductors are in contact with their terminals | | N/A |
| | f) Cord anchorage prevents POWER SUPPLY CORD from being pushed into ME EQUIPMENT or MAINS CONNECTOR | | N/A |
| | Conductors of POWER SUPPLY CORD supplied by MANUFACTURER disconnected from terminals or from MAINS CONNECTOR and cord subjected 25 times to a pull applied with no jerks, each time for 1 s, on sheath of the value in Table 18 : | | N/A |
| | Cord subjected to a torque in Table 18 for one minute immediately after pull tests | | N/A |
| | Cord anchorage did not allow cord sheath to be longitudinally displaced by more than 2 mm or conductor ends to move over a distance of more than 1 mm from their connected position | | N/A |
| | CREEPAGE and CLEARANCES not reduced below limits in 8.9 | | N/A |
| | It was not possible to push the cord into ME EQUIPMENT or MAINS CONNECTOR to an extent the cord or internal parts would be damaged | | N/A |
| 8.11.3.6 | POWER SUPPLY CORDS protected against excessive bending at inlet opening of equipment | No such construction. Final determination in the end-product for open frame model. | N/A |
| | Cord guard complied with test of IEC 60335-1:2001, Clause 25.14, or | | N/A |
| | ME EQUIPMENT placed such that axis of cord guard projected at an angle of 45° with cord free from stress, and a mass equal 10 x D² gram attached to the free end of cord (g) : | | N/A |

| IEC 60601-1 | | | |
|-----------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Cord guard of temperature-sensitive material tested at 23 °C ± 2 °C, and flat cords bent in the plane of least resistance | | N/A |
| | Curvature of the cord radius, immediately after mass attached, was not less than 1.5 x D..... : | | N/A |
| 8.11.4 | MAINS TERMINAL DEVICES | | N/A |
| 8.11.4.1 | PERMANENTLY INSTALLED and ME EQUIPMENT with non-DETACHABLE POWER SUPPLY CORD provided with MAINS TERMINAL DEVICES ensuring reliable connection | Final determination in the end-product for open frame model. | N/A |
| | Terminals alone are not used to keep conductors in position | | N/A |
| | Terminals of components other than terminal blocks complying with requirements of this Clause and marked accordingly used as terminals intended for external conductors | | N/A |
| | Screws and nuts clamping external conductors do not serve to secure any other component | | N/A |
| 8.11.4.2 | Arrangement of MAINS TERMINAL DEVICES | | N/A |
| | a) Terminals provided for connection of external cords or POWER SUPPLY CORDS together with PROTECTIVE EARTH TERMINAL grouped to provide convenient means of connection | Final determination in the end-product for open frame model. | N/A |
| | d) MAINS TERMINAL DEVICES not accessible without use of a TOOL | | N/A |
| | e) A MEANS OF PROTECTION are not short circuited when one end of a flexible conductor with NOMINAL cross-sectional area is stripped 8 mm and a single free wire is bent in each possible direction | | N/A |
| 8.11.4.3 | Internal wiring not subjected to stress and CREEPAGE and CLEARANCES not reduced after fastening and loosening a conductor of largest cross-sectional area 10 times | Final determination in the end-product for open frame model. | N/A |
| 8.11.4.4 | Terminals with clamping means for a rewirable flexible cord did not require special preparation of conductors and conductors were not damaged and did not slip out when clamping means tightened | Final determination in the end-product for open frame model. | N/A |
| 8.11.4.5 | Adequate space provided inside ME EQUIPMENT designed for FIXED wiring or a rewirable POWER SUPPLY CORD to allow for connection of conductors | Final determination in the end-product for open frame model. | N/A |
| | Correct connection and positioning of conductors before ACCESS COVER verified by an installation test | | N/A |
| 8.11.5 | Mains fuses and OVER-CURRENT RELEASES | | P |

| IEC 60601-1 | | | |
|---------------|--|-------------------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | A fuse or OVER-CURRENT RELEASE provided in each supply lead for CLASS I and CLASS II ME EQUIPMENT with a functional earth connection . : | See appended Table 8.10 | P |
| | - in at least one supply lead for other single-phase CLASS II ME EQUIPMENT : | Checked | P |
| | – neutral conductor not fused for PERMANENTLY INSTALLED ME EQUIPMENT | Not permanently installed. | N/A |
| | – fuses or OVER-CURRENT RELEASES omitted due to provision of two MEANS OF PROTECTION between all parts within MAINS PART | | N/A |
| | Protective devices have adequate breaking capacity to interrupt the max. fault current : | See appended Table 8.10 | N/A |
| | A fuse or OVER-CURRENT RELEASE not provided in a PROTECTIVE EARTH CONDUCTOR | | P |
| | Justification for omission of fuses or OVER-CURRENT RELEASES documented : | | N/A |
| 8.11.6 | Internal wiring of the MAINS PART | | N/A |
| | a) Cross-sectional area of internal wiring in a MAINS PART between MAINS TERMINAL DEVICE or APPLIANCE INLET and protective devices suitable : | No such internal wire. | N/A |
| | b) Cross-sectional area of other wiring in MAINS PART and sizes of tracks on printed wiring circuits are sufficient..... : | See appended Table 8.10 for details | N/A |

| | | | |
|--------------|---|---|------------|
| 9 | PROTECTION AGAINST MECHANICAL HAZARDS OF ME EQUIPMENT AND ME SYSTEMS | | P |
| 9.2 | HAZARDS associated with moving parts | | N/A |
| 9.2.1 | When ME EQUIPMENT with moving parts PROPERLY INSTALLED, used per ACCOMPANYING DOCUMENTS or under foreseeable misuse, RISKS associated with moving parts reduced to an acceptable level : | No moving part. Final determination in the end product evaluation. | N/A |
| | RISK from contact with moving parts reduced to an acceptable level using protective measures, (access, function, shape of parts, energy, speed of motion, and benefits to PATIENT considered) | | N/A |
| | RESIDUAL RISK associated with moving parts considered acceptable when exposure was needed for ME EQUIPMENT to perform its intended function, and | | N/A |
| | RISK CONTROLS implemented : | | N/A |

| IEC 60601-1 | | | |
|------------------|---|----------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | RISK MANAGEMENT FILE includes an assessment of RISKS associated with moving parts: (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | All RISKS associated with moving parts have been reduced to an acceptable level | | N/A |
| 9.2.2 | TRAPPING ZONE | | N/A |
| 9.2.2.1 | ME EQUIPMENT with a TRAPPING ZONE complied with one or more of the following as feasible: | No trapping zone. | N/A |
| | – Gaps in Clause 9.2.2.2, or | | N/A |
| | – Safe distances in Clause 9.2.2.3, or | | N/A |
| | – GUARDS and other RISK CONTROL measures in 9.2.2.4, or | | N/A |
| | – Continuous activation in Clause 9.2.2.5 | | N/A |
| | Control of relevant motion complied with 9.2.2.6 when implementation of above protective measures were inconsistent with INTENDED USE OF ME EQUIPMENT OR ME SYSTEM | | N/A |
| 9.2.2.2 | A TRAPPING ZONE considered not to present a MECHANICAL HAZARD when gaps of TRAPPING ZONE complied with dimensions per Table 20: | See appended Table 9.2.2.2 | N/A |
| 9.2.2.3 | A TRAPPING ZONE considered not to present a MECHANICAL HAZARD when distances separating OPERATOR, PATIENT, and others from TRAPPING ZONES exceeded values in ISO 13857:2008: | See appended Table 9.2.2.2 | N/A |
| 9.2.2.4 | GUARDS and other RISK CONTROL measures | | N/A |
| 9.2.2.4.1 | A TRAPPING ZONE do not to present a MECHANICAL HAZARD when GUARDS or other RISK CONTROL measures are of robust construction, not easy to bypass or render non-operational, and did not introduce additional unacceptable RISK: | See appended Table 15.3 | N/A |
| 9.2.2.4.2 | FIXED GUARDS held in place by systems that can only be dismantled with a TOOL | | N/A |
| 9.2.2.4.3 | Movable GUARDS that can be opened without a TOOL remained attached when GUARD was open | | N/A |
| | – they are associated with an interlock preventing relevant moving parts from starting to move while TRAPPING ZONE is accessible, and stops movement when the GUARD is opened, | | N/A |
| | – absence or failure of one of their components prevents starting, and stops moving parts | | N/A |
| | Movable GUARDS complied with any applicable tests | | N/A |
| 9.2.2.4.4 | Other RISK CONTROL designed and incorporated into to the control system stops movement and | | N/A |

| IEC 60601-1 | | | |
|-------------|--|----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – SINGLE FAULT CONDITIONS have a second RISK CONTROL, or | | N/A |
| | ME EQUIPMENT is SINGLE FAULT SAFE | | N/A |
| 9.2.2.5 | Continuous activation | | N/A |
| | Continuous activation used as a RISK CONTROL, complies with the following | | N/A |
| | a) movement was in OPERATOR's field of view | | N/A |
| | b) movement of ME EQUIPMENT or its parts was possible only by continuous activation of control by OPERATOR | | N/A |
| | c) a second RISK CONTROL provided for SINGLE FAULT CONDITION of continuous activation system, or | | N/A |
| | - the continuous activation system is SINGLE FAULT SAFE | | N/A |
| 9.2.2.6 | Speed of movement(s) positioning parts of ME EQUIPMENT or PATIENT limited to allow OPERATOR control of the movement | | N/A |
| | Over travel of such movement occurring after operation of a control to stop movement, did not result in an unacceptable RISK | | N/A |
| 9.2.3 | Other MECHANICAL HAZARDS associated with moving parts | | N/A |
| 9.2.3.1 | Controls positioned, recessed, or protected by other means so that they cannot be accidentally actuated | | N/A |
| | - unless for the intended PATIENT, the USABILITY ENGINEERING PROCESS concludes otherwise (e.g. PATIENT with special needs), or | | N/A |
| | - activation does not result in an unacceptable RISK | | N/A |
| 9.2.3.2 | Over travel past range limits of the ME EQUIPMENT prevented | | N/A |
| | Over travel means provided with mechanical strength to withstand loading in NORMAL CONDITION & reasonably foreseeable misuse..... | See appended Table 9.2.3.2 | N/A |
| 9.2.4 | Emergency stopping devices | | N/A |
| | Where necessary to have one or more emergency stopping device(s), emergency stopping device complied with all the following, except for actuating switch capable of interrupting all power | | N/A |
| | a) Emergency stopping device reduced RISK to an acceptable level | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | RISK MANAGEMENT FILE indicates the use of an emergency stopping device reduces the RISK to an acceptable level : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.6) | | N/A |
| | b) Proximity and response of OPERATOR to actuate emergency stopping device could be relied upon to prevent HARM | | N/A |
| | c) Emergency stopping device actuator was readily accessible to OPERATOR | | N/A |
| | d) Emergency stopping device(s) are not part of normal operation of ME EQUIPMENT | | N/A |
| | e) Emergency switching operation or stopping means neither introduced further HAZARD nor interfered with operation necessary to remove original MECHANICAL HAZARD | | N/A |
| | f) Emergency stopping device was able to break full load of relevant circuit, including possible stalled motor currents and the like | | N/A |
| | g) Means for stopping of movements operate as a result of one single action | | N/A |
| | h) Emergency stopping device provided with an actuator in red and easily distinguishable and identifiable from other controls | | N/A |
| | i) An actuator interrupting/opening mechanical movements marked on or immediately adjacent to face of actuator with symbol 18 of Table D.1 or "STOP" | | N/A |
| | j) Emergency stopping device, once actuated, maintained ME EQUIPMENT in disabled condition until a deliberate action, different from that used to actuate it, was performed | | N/A |
| | k) Emergency stopping device is suitable for its application | | N/A |
| 9.2.5 | Means provided to permit quick and safe release of PATIENT in event of breakdown of ME EQUIPMENT or failure of power supply, activation of a RISK CONTROL measure, or emergency stopping : | | N/A |
| | – and uncontrolled or unintended movement of ME EQUIPMENT that could result in an unacceptable RISK prevented | | N/A |
| | – Situations where PATIENT is subjected to unacceptable RISKS due to proximity of moving parts, removal of normal exit routes, or other HAZARDS prevented | | N/A |

| IEC 60601-1 | | | |
|----------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – Measures provided to reduce RISK to an acceptable level when after removal of counterbalanced parts, other parts of ME EQUIPMENT can move in a hazardous way | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of RISKS to the PATIENT related to breakdown of the ME EQUIPMENT.....: (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 9.3 | Rough surfaces, sharp corners and edges of ME EQUIPMENT that could result in injury or damage avoided or covered | Final determination in the end product for open frame model. No rough surface / sharp edge on the other models. | P |
| 9.4 | Instability HAZARDS | | N/A |
| 9.4.1 | ME EQUIPMENT and its parts, other than FIXED, for placement on a surface did not overbalance (tip over) or move unexpectedly in NORMAL USE | Component, to be determined as part of end product | N/A |
| 9.4.2 | Instability – overbalance | | N/A |
| 9.4.2.1 | ME EQUIPMENT or its parts did not overbalance when prepared per ACCOMPANYING DOCUMENTS, or when tested | See appended Table 9.4.2.1 | N/A |
| 9.4.2.2 | Instability excluding transport | | N/A |
| | ME EQUIPMENT or its did not overbalance when placed in different positions of NORMAL USE, ...: | See appended Table 9.4.2.2 | N/A |
| | A warning provided when overbalance occurred during 10° inclined plane test | | N/A |
| 9.4.2.3 | Instability from horizontal and vertical forces | | N/A |
| | a) ME EQUIPMENT or its parts with a mass of 25kg or more, intended to be used on the floor, didn't overbalance due to pushing, leaning against it | | N/A |
| | Surfaces of ME EQUIPMENT or its parts where a RISK of overbalancing exists from pushing, etc., permanently marked with a warning of the RISK | | N/A |
| | ME EQUIPMENT did not overbalance when tested according to Cl. 9.4.2.3 a) | See appended Table 9.4.2.3 | N/A |
| | b) ME EQUIPMENT, for use on the floor or on a table, did not overbalance due to sitting or stepping | | N/A |
| | ME EQUIPMENT or its parts, for use on the floor or on a table, where RISK of overbalancing exists, permanently marked with the RISK warning.....: | | N/A |
| | ME EQUIPMENT did not overbalance when tested according to Cl. 9.4.2.3b).....: | See appended Table 9.4.2.3 | N/A |
| 9.4.2.4 | Castors and wheels | | N/A |

| IEC 60601-1 | | | |
|-------------|---|------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 9.4.2.4.1 | Means used for transportation of MOBILE ME EQUIPMENT did not result in an unacceptable RISK when MOBILE ME EQUIPMENT moved or parked in NORMAL USE | | N/A |
| 9.4.2.4.2 | Force required to move MOBILE ME EQUIPMENT did not exceed 200 N | See appended Table 9.4.2.4.2 | N/A |
| 9.4.2.4.3 | MOBILE ME EQUIPMENT exceeding 45 kg able to pass over threshold | See appended Table 9.4.2.4.3 | N/A |
| 9.4.3 | Instability from unwanted lateral movement (including sliding) | | N/A |
| 9.4.3.1 | a) Brakes of power-driven MOBILE ME EQUIPMENT normally activated and could only be released by continuous actuation of a control | | N/A |
| | b) MOBILE ME EQUIPMENT provided with locking means to prevent unwanted movements | | N/A |
| | c) No unwanted lateral movement resulted when MOBILE ME EQUIPMENT placed in its transport position when test per 9.4.3.1 | See appended Table 9.4.3.1 | N/A |
| 9.4.3.2 | Instability excluding transport | | N/A |
| | a) MOBILE ME EQUIPMENT provided with wheel locks or braking system compliant with 5° tilt test | See appended Table 9.4.3.2 | N/A |
| | b) MOBILE ME EQUIPMENT provided with wheel locks or braking system compliant with lateral stability test | See appended Table 9.4.3.2 | N/A |
| 9.4.4 | Grips and other handling devices | | N/A |
| | a) ME EQUIPMENT with a mass of over 20 kg requiring lifting in NORMAL USE or transport provided with suitable handling means, or ACCOMPANYING DOCUMENTS specify safe lifting method | | N/A |
| | Handles, suitably placed to enable ME EQUIPMENT or its part to be carried by two or more persons and by examination of EQUIPMENT, its part, or ACCOMPANYING DOCUMENTS | | N/A |
| | b) PORTABLE ME EQUIPMENT with a mass > 20 kg provided with one or more carrying-handles suitably placed to enable carrying by two or more persons as confirmed by actual carrying | | N/A |
| | c) Carrying handles and grips and their means of attachment withstood loading test | See appended Table 9.4.4 | N/A |
| 9.5 | Expelled parts HAZARD | | N/A |
| 9.5.1 | Suitability of means of protecting against expelled parts determined by assessment and examination of RISK MANAGEMENT FILE (ISO 14971 Cl. 4.3, 4.4, 5, 6.2-6.5) | No expelled parts. | N/A |

| IEC 60601-1 | | | |
|----------------|---|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | All identified RISKS associated with expelled parts mitigated to an acceptable level | | N/A |
| 9.5.2 | Cathode Ray tube(s) complied with IEC 60065:2001, Clause 18, or IEC 61965 | See appended Table 8.10 | N/A |
| 9.6 | Acoustic energy (including infra- and ultrasound) and vibration | | N/A |
| 9.6.1 | Human exposure to acoustic energy and vibration from ME EQUIPMENT doesn't result in unacceptable RISK and | Component, to be determined as part of end product. | N/A |
| | If necessary, confirmed in RISK MANAGEMENT FILE including audibility of auditory alarm signals, and PATIENT sensitivity | | N/A |
| | If necessary, confirmed in RISK MANAGEMENT FILE including audibility of auditory alarm signals, PATIENT sensitivity, and (ISO 14971 Cl. 4.2-44, 5, 6.2-6.5) | | N/A |
| | All identified RISKS mitigated to an acceptable level | | N/A |
| 9.6.2 | Acoustic energy | | N/A |
| 9.6.2.1 | PATIENT, OPERATOR, and other persons are not exposed to acoustic energy from ME EQUIPMENT in NORMAL USE | | N/A |
| | – 80 dBA for a cumulative exposure of 24 h over a 24 h period (dBA)..... | | — |
| | - 83 dBA (when halving the cumulative exposure time) (dBA) | | — |
| | – 140 dBC (peak) sound pressure level for impulsive or impact acoustic energy (dB)..... | | — |
| 9.6.2.2 | RISK MANAGEMENT FILE examined..... (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 9.6.3 | Hand-transmitted vibration | | N/A |
| | Means provided to protect PATIENT and OPERATOR when hand-transmitted frequency-weighted r.m.s. acceleration generated in NORMAL USE exceeds specified values | | N/A |
| | – 2.5 m/s² for a cumulative time of 8 h during a 24 h period (m/s²) | | N/A |
| | – Accelerations for different times, inversely proportional to square root of time (m/s²)..... | | N/A |
| 9.7 | Pressure vessels and parts subject to pneumatic and hydraulic pressure | | N/A |
| 9.7.2 | Pneumatic and hydraulic parts of ME EQUIPMENT or ACCESSORIES met requirements based on examination of RISK MANAGEMENT FILE (ISO 14971 Cl. 4.3-4.4, 5, 6.2-6.5) | | N/A |

| IEC 60601-1 | | | |
|-------------|---|--------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – No unacceptable RISK resulted from loss of pressure or loss of vacuum | | N/A |
| | – No unacceptable RISK resulted from a fluid jet caused by leakage or a component failure | | N/A |
| | – Elements of ME EQUIPMENT or an ACCESSORY, especially pipes and hoses leading to an unacceptable RISK protected against harmful external effects | | N/A |
| | – Reservoirs and similar vessels leading to an unacceptable RISK are automatically depressurized when ME EQUIPMENT is isolated from its power supply | | N/A |
| | Means provided for isolation, or local depressurizing reservoirs and similar vessels, and pressure indication when above not possible | | N/A |
| | – All elements remaining under pressure after isolation of ME EQUIPMENT or an ACCESSORY from its power supply resulting in an unacceptable RISK provided with clearly identified exhaust devices, and a warning to depressurize these elements before setting or maintenance activity | | N/A |
| 9.7.3 | Maximum pressure a part of ME EQUIPMENT can be subjected to in NORMAL and SINGLE FAULT CONDITIONS considered to be highest of following: | | N/A |
| | a) RATED maximum supply pressure from an external source | | N/A |
| | b) Pressure setting of a pressure-relief device provided as part of assembly | | N/A |
| | c) Max pressure that can develop by a source of pressure that is part of assembly, unless pressure limited by a pressure-relief device | | N/A |
| 9.7.4 | Max pressure in NORMAL and SINGLE FAULT CONDITIONS did not exceed MAXIMUM PERMISSIBLE WORKING PRESSURE for EQUIPMENT part, except as allowed in 9.7.7, confirmed by inspection of THE MANUFACTURER'S data for the component, ME EQUIPMENT, and by functional tests | | N/A |
| 9.7.5 | A pressure vessel withstood a HYDRAULIC TEST PRESSURE when pressure was more than 50 kPa, and product of pressure and volume was more than 200 kPaI | See appended Table 9.7.5 | N/A |

| IEC 60601-1 | | | |
|-------------|---|-------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 9.7.6 | Pressure-control device regulating pressure in ME EQUIPMENT with pressure-relief device completed 100,000 cycles of operation under RATED load and prevented pressure from exceeding 90 % of setting of pressure-relief device in different conditions of NORMAL USE .: | | N/A |
| 9.7.7 | Pressure-relief device(s) used where MAXIMUM PERMISSIBLE WORKING PRESSURE could otherwise be exceeded met the following, as confirmed by MANUFACTURER'S data, ME EQUIPMENT, RISK MANAGEMENT FILE, and functional tests | | N/A |
| | a) Connected as close as possible to pressure vessel or parts of system it is to protect | | N/A |
| | b) Installed to be readily accessible for inspection, maintenance, and repair | | N/A |
| | c) Could be adjusted or rendered inoperative without a TOOL | | N/A |
| | d) With discharge opening located and directed as to not to release material towards any person | | N/A |
| | e) With discharge opening located and directed as to not to deposit material on parts that could result in an unacceptable RISK | | N/A |
| | f) Adequate discharge capacity provided to ensure that pressure will not exceed MAXIMUM PERMISSIBLE WORKING PRESSURE of system it is connected to by more than 10 % when failure occurs in control of supply pressure | | N/A |
| | g) No shut-off valve provided between a pressure-relief device and parts it is to protect | | N/A |
| | h) Min number of cycles of operation 100 000, except for one-time use devices (bursting disks) | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of the risks associated with the discharge opening of the pressure relief device: (ISO 14971 Cl. 4.3, 4.4, 5, 6.2-6.5) | | N/A |
| 9.8 | HAZARDS associated with support systems | | N/A |
| 9.8.1 | ME EQUIPMENT parts designed to support loads or provide actuating forces when a mechanical fault could constitute an unacceptable RISK ...: | See appended Table 8.10 | N/A |
| | – Construction of support, suspension, or actuation system complied with Table 21 and TOTAL LOAD | | N/A |
| | – Means of attachment of ACCESSORIES prevent possibility of incorrect attachment that could result in an unacceptable RISK | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – RISK ANALYSIS of support systems included MECHANICAL HAZARDS from static, dynamic, vibration, foundation and other movements, impact and pressure loading, temperature, environmental, manufacture and service conditions: (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | – RISK ANALYSIS included effects of failures such as excessive deflection, plastic deformation, ductile/brittle fracture, fatigue fracture, instability (buckling), stress-assisted corrosion cracking, wear, material creep and deterioration, and residual stresses from manufacturing PROCESSES | | N/A |
| | – Instructions on attachment of structures to a floor, wall, ceiling, included in ACCOMPANYING DOCUMENTS making adequate allowances for quality of materials used to make the connection and list the required materials | | N/A |
| | Additional instructions provided on checking adequacy of surface of structure parts will be attached to | | N/A |
| 9.8.2 | Support systems maintain structural integrity during EXPECTED SERVICE LIFE, and TENSILE SAFETY FACTORS are not less than in Table 21, except when an alternative method used to demonstrate structural integrity throughout EXPECTED SERVICE LIFE, or for a foot rest | | N/A |
| | Compliance with 9.8.1 and 9.8.2 confirmed by examination of ME EQUIPMENT, RISK MANAGEMENT FILE, specifications and material processing...: | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of the structural integrity of support system ...: (ISO 14971 Cl. 4.3-4.4, 5, 6.2-6.5) | | N/A |
| | All identified RISKS are mitigated to an acceptable level | | N/A |
| | When test were conducted, testing consisted of application of a test load to support assembly equal to TOTAL LOAD times required TENSILE SAFETY FACTOR while support assembly under test was in equilibrium after 1 min, or not resulted in an unacceptable RISK.....: | See appended Table 8.10 | N/A |
| | Where the equipment is not at equilibrium after 1 min, the RISK MANAGEMENT FILE includes an assessment of the test results.....: (ISO 14971 Cl. 4.3-4.4, 5, 6.2-6.5) | | N/A |
| 9.8.3 | Strength of PATIENT or OPERATOR support or suspension systems | | N/A |

| IEC 60601-1 | | | |
|-------------|---|--------------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 9.8.3.1 | ME EQUIPMENT parts supporting or immobilizing PATIENTS presents no unacceptable RISK of physical injuries and accidental loosening of secured joints | | N/A |
| | RISK MANAGEMENT FILE includes assessment of the RISKS associated with physical injuries and accidental loosening of fixings..... (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | SAFE WORKING LOAD of ME EQUIPMENT or its parts supporting or suspending PATIENTS or OPERATORS is sum of mass of PATIENTS or mass of OPERATORS plus mass of ACCESSORIES supported by ME EQUIPMENT or its parts | | N/A |
| | Supporting and suspending parts for adult human PATIENTS or OPERATORS designed for a PATIENT or OPERATOR with a min mass of 135 kg and ACCESSORIES with a min mass of 15 kg, unless stated by MANUFACTURER | | N/A |
| | Maximum mass of PATIENT included in SAFE WORKING LOAD of ME EQUIPMENT or its parts supporting or suspending PATIENTS adapted when MANUFACTURER specified applications | | N/A |
| | Max allowable PATIENT mass < 135 kg marked on ME EQUIPMENT and stated in ACCOMPANYING DOCUMENTS | | N/A |
| | Max allowable PATIENT mass over 135 kg stated in ACCOMPANYING DOCUMENTS | | N/A |
| | Examination of markings, ACCOMPANYING DOCUMENTS, and RISK MANAGEMENT FILE confirmed compliance | See copy of Marking Label | N/A |
| 9.8.3.2 | a) Entire mass of PATIENT or OPERATOR distributed over an area of 0.1 m ² on a foot rest temporarily supporting a standing PATIENT or OPERATOR | | N/A |
| | Compliance confirmed by examination of ME EQUIPMENT specifications of materials and their processing, and tests | See appended Tables 8.10 and 9.8.3.2 | N/A |
| | b) Deflection of a support surface from PATIENT or OPERATOR loading on an area of support/ suspension where a PATIENT or OPERATOR can sit did not result in an unacceptable RISK | | N/A |
| | Compliance confirmed by examination of ME EQUIPMENT, specifications of materials and their processing, and by a test | See appended Tables 8.10 and 9.8.3.2 | N/A |

| IEC 60601-1 | | | |
|-------------|---|----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 9.8.3.3 | Dynamic forces that can be exerted on equipment parts supporting or suspending a PATIENT or OPERATOR in NORMAL USE maintained BASIC SAFETY and ESSENTIAL PERFORMANCE confirmed test | See appended Table 9.8.3.3 | N/A |
| 9.8.4 | Systems with MECHANICAL PROTECTIVE DEVICES | | N/A |
| 9.8.4.1 | a) A MECHANICAL PROTECTIVE DEVICE provided for the support system | | N/A |
| | b) MECHANICAL PROTECTIVE complies with the requirements as follows: | | N/A |
| | – Designed based on TOTAL LOAD | | N/A |
| | – Has TENSILE SAFETY FACTORS for all parts not less than Table 21, row 7 | | N/A |
| | – Activated before travel produced an unacceptable RISK | | N/A |
| | – Takes into account Clauses 9.2.5 and 9.8.4.3 | | N/A |
| | Compliance confirmed by examination of ME EQUIPMENT over travel calculations and evaluation plus functional tests | See appended Table 8.10 | N/A |
| 9.8.4.2 | Activation of MECHANICAL PROTECTIVE DEVICE is made obvious to OPERATOR when ME EQUIPMENT can still be used after failure of suspension or actuation means and activation of a MECHANICAL PROTECTIVE DEVICE | | N/A |
| | MECHANICAL PROTECTIVE DEVICE requires use of a TOOL to be reset or replaced | | N/A |
| 9.8.4.3 | MECHANICAL PROTECTIVE DEVICE intended to function once | | N/A |
| | –use of ME EQUIPMENT not possible until replacement of MECHANICAL PROTECTIVE DEVICE : | | N/A |
| | – ACCOMPANYING DOCUMENTS provided with required information on replacement by service personal | | N/A |
| | – ME EQUIPMENT permanently marked with safety sign 2 of Table D. | | N/A |
| | – Marking is adjacent to MECHANICAL PROTECTIVE DEVICE | | N/A |
| | – Compliance confirmed by examination and following test | See appended Table 8.10 | N/A |
| | A chain, cable, band, spring, belt, jack screw nut, pneumatic or hydraulic hose, structural part or the like, employed to support a load, defeated by a convenient means causing maximum normal load to fall from most adverse position permitted by construction of ME EQUIPMENT | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Load included SAFE WORKING LOAD in 9.8.3.1 when system was capable of supporting a PATIENT or OPERATOR | | N/A |
| | No evidence of damage to MECHANICAL PROTECTIVE DEVICE affecting its ability to perform its intended function | | N/A |
| 9.8.5 | Systems without MECHANICAL PROTECTIVE DEVICES | | N/A |
| | Support Systems does not require MECHANICAL PROTECTIVE DEVICES | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of RISKS associated with wear on the support system (ISO 14971 Cl. 4.3,4.4,5,6.2-6.5) | | N/A |

| | | | |
|--------|---|-------------------------------------|-----|
| 10 | PROTECTION AGAINST UNWANTED AND EXCESSIVE RADIATION HAZARDS | | N/A |
| 10.1 | X-Radiation | | N/A |
| 10.1.1 | The air kerma did not exceed 5 µGy/hat 5 cm from surface of ME EQUIPMENT | See Table 10.1.1 No X-radiation. | N/A |
| | Annual exposure reduced taking into account the irradiated body part, national regulations, and/or international recommendations for ME EQUIPMENT that has permanent proximity to a PATIENT as part of the INTENDED USE | | N/A |
| 10.1.2 | RISK from unintended X-radiation from ME EQUIPMENT producing X-radiation for diagnostic and therapeutic purposes addressed application of applicable particular and collateral standards, or | | N/A |
| | RISK MANAGEMENT PROCESS as indicated in RISK MANAGEMENT FILE..... (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 10.2 | RISK associated with alpha, beta, gamma, neutron, and other particle radiation, addressed in RISK MANAGEMENT PROCESS as shown in RISK MANAGEMENT FILE (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 10.3 | The power density of unintended microwave radiation at frequencies between 1 GHz and 100 GHz does not exceed 10 W/m2 | | N/A |
| | Microwave radiation is propagated intentionally | | N/A |
| 10.4 | Relevant requirements of IEC 60825-1:2007 applied to lasers, laser light barriers or similar with a wavelength range of 180nm to 1 mm. | | N/A |

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 10.5 | RISK associated with visible electromagnetic radiation other than emitted by lasers and LEDS, when applicable, addressed in RISK MANAGEMENT PROCESS as indicated in RISK MANAGEMENT FILE : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 10.6 | RISK associated with infrared radiation other than emitted by lasers and LEDS addressed in RISK MANAGEMENT PROCESS as indicated in RISK MANAGEMENT FILE : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 10.7 | RISK associated with ultraviolet radiation other than emitted by lasers and LEDS addressed in RISK MANAGEMENT PROCESS as indicated in RISK MANAGEMENT FILE : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |

| | | | |
|----------|--|---|-----|
| 11 | PROTECTION AGAINST EXCESSIVE TEMPERATURES AND OTHER HAZARDS | | P |
| 11.1 | Excessive temperatures in ME EQUIPMENT | | P |
| 11.1.1 | Temperatures on ME EQUIPMENT parts did not exceed values in Tables 22 and : | See appended Table 11.1.1 Open frame model shall be revaluated in the end product. | P |
| | Surfaces of test corner did not exceed 90 °C | | P |
| | THERMAL CUT-OUTS did not operate in NORMAL CONDITION | No thermal cut-out | N/A |
| | RISK MANAGEMENT FILE includes an assessment of the duration of contact for all APPLIED PARTS and ACCESSIBLE PARTS : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | Open frame model shall be revaluated in the end product | N/A |
| 11.1.2 | Temperature of APPLIED PARTS | | N/A |
| 11.1.2.1 | APPLIED PARTS (hot or cold intended to supply heat to a PATIENT comply : | No applied parts. | N/A |
| | Clinical effects determined and documented in the RISK MANAGEMENT FILE (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | Temperature (hot or cold) of APPLIED PARTS intended to supply heat to a PATIENT disclosed in the instructions for use | | N/A |
| 11.1.2.2 | APPLIED PARTS not intended to supply heat to a PATIENT complies with the limits of Table 24 in NORMAL CONDITION and SINGLE FAULT CONDITION. : | | N/A |
| | APPLIED PARTS surface temperature exceeds 41°C disclosed in the instruction manual: | | N/A |
| | Maximum Temperature : | | — |

| IEC 60601-1 | | | |
|-------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Conditions for safe contact, e.g. duration or condition of the PATIENT..... : | | — |
| | Clinical effects with respect to characteristics taken or surface pressure documented in the RISK MANAGEMENT FILE (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | APPLIED PARTS surface temperature of equal to or less than 41°C | | N/A |
| | Analysis documented in the RISK MANAGEMENT FILE show that APPLIED PART temperatures are not affected by operation of the ME EQUIPMENT including SINGLE FAULT CONDITIONS. Measurement of APPLIED PART temperature according to 11.1.3 is not conducted | | N/A |
| | Surfaces of APPLIED PARTS that are cooled below ambient temperatures evaluated in the RISK MANAGEMENT PROCESS (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 11.1.3 | Measurements not made when engineering judgment and rationale by MANUFACTURER indicated temperature limits could not exceed, as documented in RISK MANAGEMENT FILE (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | Test corner not used where engineering judgment and rationale by MANUFACTURER indicated test corner will not impact measurements, as documented in RISK MANAGEMENT FILE..... (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | Probability of occurrence and duration of contact for parts likely to be touched and for APPLIED PARTS documented in RISK MANAGEMENT FILE..... (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | e) Where thermal regulatory devices make this method inappropriate, alternative methods for measurement are justified in the RISK MANAGEMENT FILE..... | | N/A |
| 11.1.4 | GUARDS preventing contact with hot or cold accessible surfaces removable only with a TOOL | No alternative method. | N/A |
| 11.2 | Fire prevention | | N/A |
| 11.2.1 | ENCLOSURE has strength and rigidity necessary to prevent a fire and met mechanical strength tests for ENCLOSURES in 15.3 | To be determined in end product evaluation. | N/A |
| 11.2.2 | Me equipment and me systems used in conjunction with OXYGEN RICH ENVIRONMENTS | | N/A |

| IEC 60601-1 | | | |
|-----------------|--|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 11.2.2.1 | RISK of fire in an OXYGEN RICH ENVIRONMENT reduced by means limiting spread of : | Component, not evaluated for use with Oxygen Rich Environment | N/A |
| | a) No sources of ignition discovered in an OXYGEN RICH ENVIRONMENT under any of the following conditions | | N/A |
| | 1) when temperature of material raised to its ignition temperature | | N/A |
| | 2) when temperatures affected solder or solder joints causing loosening, short circuiting, or other failures causing sparking or increasing material temperature to its ignition temperature | | N/A |
| | 3) when parts affecting safety cracked or changed outer shape exposing temperatures higher than 300°C or sparks due to overheating | | N/A |
| | 4) when temperatures of parts or components exceeded 300°C, atmosphere was 100 % oxygen, contact material solder, and fuel cotton | | N/A |
| | 5) when sparks provided adequate energy for ignition by exceeding limits of Figs 35 to 37 (inclusive), atmosphere was 100 % oxygen, contact material solder, and fuel cotton | | N/A |
| | Deviations from worst case limits in 4) and 5) above based on lower oxygen concentrations or less flammable fuels justified and documented in RISK MANAGEMENT FILE : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | Alternative test in this clause did not identify existence of ignition sources at highest voltage or current, respectively : | See appended Table 11.2.2.1 | N/A |
| | A safe upper limit determined by dividing upper limit of voltage or current, respectively, with safety margin factor of three..... : | | N/A |
| | b) RESIDUAL RISK of fire in an OXYGEN RICH ENVIRONMENT as determined by application of RISK MANAGEMENT PROCESS is based on following configurations, or in combination : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | 1) Electrical components in an OXYGEN RICH ENVIRONMENT provided with power supplies having limited energy levels lower than those considered sufficient for ignition in 11.2.2.1 a) as determined by examination, measurement or calculation of power, energy, and temperatures in NORMAL and SINGLE FAULT CONDITIONS identified in 11.2.3..... : | See appended Tables 4.11, 11.1.1, 11.2.2.1 and 13.2 | N/A |

| IEC 60601-1 | | | |
|-----------------|--|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | 2) Max oxygen concentration measured until it did not exceed 25 % in ventilated compartments with parts that can be a source of ignition only in SINGLE FAULT CONDITION and can be penetrated by oxygen due to an undetected leak (%) : | | N/A |
| | 3) A compartment with parts or components that can be a source of ignition only under SINGLE FAULT CONDITION separated from another compartment containing an OXYGEN RICH ENVIRONMENT by sealing all joints and holes for cables, shafts, or other purposes | | N/A |
| | Effect of possible leaks and failures under SINGLE FAULT CONDITION that could cause ignition evaluated using a RISK ASSESSMENT to determine maintenance intervals by examination of documentation and RISK MANAGEMENT FILE : | | N/A |
| | 4) Fire initiated in ENCLOSURE of electrical components in a compartment with OXYGEN RICH ENVIRONMENT that can become a source of ignition only under SINGLE FAULT CONDITIONS self-extinguished rapidly and no hazardous amount of toxic gases reached PATIENT as determined by analysis of gases : | | N/A |
| 11.2.2.2 | RISK of ignition did not occur and oxygen concentration did not exceed 25% in immediate surroundings due to location of external exhaust outlets of an OXYGEN RICH ENVIRONMENT | | N/A |
| 11.2.2.3 | Electrical connections within a compartment containing an OXYGEN RICH ENVIRONMENT under NORMAL USE did not produce sparks | | N/A |
| | – Screw-attachments protected against loosening during use by varnishing, use of spring washers, or adequate torques | | N/A |
| | – Soldered, crimped, and pin-and-socket connections of cables exiting ENCLOSURE include additional mechanical securing means | | N/A |
| 11.2.3 | SINGLE FAULT CONDITIONS related to OXYGEN RICH ENVIRONMENTS ME EQUIPMENT and ME SYSTEMS considered | | N/A |
| | – Failure of a ventilation system constructed in accordance with 11.2.2.1 b) 2) : | Component, not evaluated for use with Oxygen Rich Environment | N/A |
| | – Failure of a barrier constructed in accordance with 11.2.2.1 b) 3) : | | N/A |
| | – Failure of a component creating a source of ignition (as defined in 11.2.2.1 a) : | | N/A |

| IEC 60601-1 | | | |
|-------------|---|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – Failure of solid insulation or creepage and clearances providing equivalent of at least one MEANS OF PATIENT PROTECTION but less than two MEANS OF PATIENT PROTECTION that could create a source of ignition defined in 11.2.2.1 a) | | N/A |
| | – Failure of a pneumatic component resulting in leakage of oxygen-enriched gas..... | | N/A |
| 11.3 | Constructional requirements for fire ENCLOSURES of ME EQUIPMENT | | P |
| | ME EQUIPMENT met this clause for alternate means of compliance with selected HAZARDOUS SITUATIONS and fault conditions in 13.1.2 | Final determination to be competed in the end product for open frame model. | N/A |
| | Constructional requirements were met, or | | P |
| | - constructional requirements specifically analysed in RISK MANAGEMENT FILE : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | Justification, when requirement not met | | N/A |
| | a) Flammability classification of insulated wire within fire ENCLOSURE is FV-1, or better, based on IEC 60695 series as determined by examination of data on materials..... | See appended Table 8.10 | P |
| | Flammability classification of connectors, printed circuit boards, and insulating material on which components are mounted is FV-2, or better, based on IEC 60695-11-10 as decided by examination of materials data | See appended Table 8.10 | P |
| | If no FV Certification, FV tests based on IEC 60695-11-10 conducted on 3 samples of complete parts (or sections of it), including area with min. thickness, ventilation openings | UL 94 approved | N/A |
| | b) Fire ENCLOSURE met following: | | P |
| | 1) No openings at bottom or, as specified in Fig 39, constructed with baffles as in Fig 38, or made of perforated metal as in Table 25, or a metal screen with a mesh $\leq 2 \times 2$ mm centre to centre and wire diameter of at least 0.45 mm | No openings on the enclosure of potted models. Final determination to be competed in the end product for open frame model. | P |
| | 2) No openings on the sides within the area included within the inclined line C in Fig 39 | | P |
| | 3) ENCLOSURE, baffles, and flame barriers have adequate rigidity and are made of appropriate metal or of non-metallic materials | See appended Table 8.10 | P |
| 11.4 | ME EQUIPMENT and ME SYSTEMS intended for use with flammable anaesthetics | | N/A |
| | ME EQUIPMENT, ME SYSTEMS and parts described in ACCOMPANYING DOCUMENTS for use with flammable with Annex G | | N/A |

| IEC 60601-1 | | | |
|-------------|---|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 11.5 | ME EQUIPMENT and ME SYSTEMS intended for use in conjunction with flammable agents | | N/A |
| | MANUFACTURER'S RISK MANAGEMENT PROCESS addresses possibility of fire and associated mitigations as confirmed by examination of RISK MANAGEMENT FILE : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 11.6 | Overflow, spillage, leakage, ingress of water or particulate matter, cleaning, disinfection, sterilization and compatibility with substances used with the ME EQUIPMENT | | N/A |
| 11.6.1 | Sufficient degree of protection provided against overflow, spillage, leakage, ingress of water or particulate matter, cleaning, disinfection and sterilization, and compatibility with substances used with ME EQUIPMENT..... : | See Appended Table 11.6.1 | N/A |
| 11.6.2 | Overflow in ME EQUIPMENT | | N/A |
| | ME EQUIPMENT incorporates a reservoir or liquid storage that did not wet any MEANS OF PROTECTION, nor result in the loss of BASIC SAFETY OR ESSENTIAL PERFORMANCE : | See Appended Table 11.6.1 | N/A |
| | Maximum fill level is indicated by marking on the ME EQUIPMENT and a warning or safety notice is given, no HAZARDOUS SITUATION (as specified in 13.1) or unacceptable RISK due to overflow developed when the reservoir or liquid storage chamber is filled to its maximum capacity and the TRANSPORTABLE ME EQUIPMENT is tilted through an angle of 10°, or for MOBILE ME EQUIPMENT exceeding 45 kg, is moved over a threshold as described in 9.4.2.4.3. | | N/A |
| | No warning or safety notice provided regarding the maximum fill level, no HAZARDOUS SITUATION (as specified in 13.1) or unacceptable RISK due to overflow developed when the reservoir or liquid storage chamber was filled to 15 % above the maximum capacity and the TRANSPORTABLE ME EQUIPMENT was tilted through an angle of 10°, or in MOBILE ME EQUIPMENT exceeding 45 kg, was moved over a threshold as described in 9.4.2.4.3. | | N/A |
| 11.6.3 | Spillage on ME EQUIPMENT and ME SYSTEM | | N/A |
| | ME EQUIPMENT and ME SYSTEMS handling liquids constructed that spillage does not wet parts as determined by review of the RISK MANAGEMENT FILE and test : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | See appended Tables 11.6.1; 8.7, 8.8.3 | N/A |
| | RISK ANALYSIS identifies the type of liquid, volume, duration and location of the spill : | | N/A |
| 11.6.5 | Ingress of water or particulate matter into ME EQUIPMENT and ME SYSTEMS | | N/A |

| IEC 60601-1 | | | |
|---------------|--|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | ME EQUIPMENT with IP Code placed in least favourable position of NORMAL USE and subjected to tests of IEC 60529 (IP Code)..... : | Final determination to be completed in the end product. EUT is ordinary. | N/A |
| | ME EQUIPMENT met dielectric strength and LEAKAGE CURRENT tests and there were no bridging of insulation or electrical components that could result in the loss of BASIC SAFETY or ESSENTIAL PERFORMANCE in NORMAL CONDITION or in combination with a SINGLE FAULT CONDITION.. : | EUT is ordinary. | N/A |
| 11.6.6 | Cleaning and disinfection of ME EQUIPMENT and ME SYSTEMS | | N/A |
| | ME EQUIPMENT/ME SYSTEM and their parts and ACCESSORIES cleaned or disinfected using methods specified in instructions for use : | See Appended Tables 11.6.1, 8.7, and 8.8.3 | N/A |
| | Effects of multiple cleanings/disinfections during EXPECTED SERVICE LIFE of EQUIPMENT evaluated by MANUFACTURER : | | N/A |
| 11.6.7 | Sterilization of ME EQUIPMENT and ME SYSTEMS | | N/A |
| | ME EQUIPMENT, ME SYSTEMS and their parts or ACCESSORIES intended to be sterilized assessed and documented and compliant with tests..... : | See appended Tables 8.7 8.8.3, and 11.6.1 | N/A |
| | RISK MANAGEMENT FILE includes an assessment of the RISKS associated with any deterioration following sterilization : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 11.6.8 | RISKS associated with compatibility of substances used with ME EQUIPMENT addressed in RISK MANAGEMENT PROCESS..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 11.7 | ME EQUIPMENT, ME SYSTEM, and ACCESSORIES coming into direct or indirect contact with biological tissues, cells, or body fluids assessed and documented | Component, to be determined in end-product evaluation. | N/A |
| 11.8 | Interruption and restoration of power supply did not result in a loss of BASIC SAFETY or ESSENTIAL PERFORMANCE | Component, to be determined in end-product evaluation. | N/A |

| | | | |
|-------------|---|--|------------|
| 12 | ACCURACY OF CONTROLS AND INSTRUMENTS AND PROTECTION AGAINST HAZARDOUS OUTPUTS | | N/A |
| 12.1 | RISKS associated with accuracy of controls and instruments stated..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | Not applicable to component power supply | N/A |
| 12.2 | RISK of poor USABILITY, including identification, marking, and documents addressed in a USABILITY ENGINEERING..... : | | N/A |
| 12.3 | MANUFACTURER implemented an ALARM SYSTEM compliant with IEC 60601-1-8. : | | N/A |

| IEC 60601-1 | | | |
|-----------------|---|-----------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 12.4 | Protection against hazardous output | | N/A |
| 12.4.1 | RISKS associated with hazardous output arising from intentional exceeding of safety limits addressed in RISK MANAGEMENT PROCESS..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 12.4.2 | - need for indication associated with hazardous output addressed in RISK MANAGEMENT PROCESS..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 12.4.3 | RISKS associated with accidental selection of excessive output values for ME EQUIPMENT with a multi-purpose unit addressed in RISK MANAGEMENT PROCESS..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 12.4.4 | RISKS associated with incorrect output addressed in RISK MANAGEMENT PROCESS..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 12.4.5 | Diagnostic or therapeutic radiation | | N/A |
| 12.4.5.1 | Adequate provisions to protect OPERATORS, PATIENTS, other persons and sensitive devices in vicinity of unwanted or excessive radiation | | N/A |
| | Radiation safety ensured by compliance with requirements of appropriate standards | | N/A |
| 12.4.5.2 | ME EQUIPMENT and ME SYSTEMS designed to produce X-radiation for diagnostic imaging purposes complied with IEC 60601-1-3..... : | | N/A |
| 12.4.5.3 | RISKS associated with radiotherapy addressed in RISK MANAGEMENT PROCESS as : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 12.4.5.4 | RISKS associated with ME EQUIPMENT producing diagnostic or therapeutic radiation other than diagnostic X-rays and radiotherapy addressed in RISK MANAGEMENT PROCESS as : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 12.4.6 | RISKS associated with diagnostic or therapeutic acoustic pressure addressed in RISK MANAGEMENT : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |

| | | | |
|---------------|---|--|------------|
| 13 | HAZARDOUS SITUATIONS AND FAULT CONDITIONS | | P |
| 13.1 | Specific HAZARDOUS SITUATIONS | | P |
| 13.1.2 | Emissions, deformation of ENCLOSURE or exceeding maximum temperature | | P |
| | – Emission of flames, molten metal, poisonous or ignitable substance in hazardous quantities did not occur | | P |
| | – Deformation of ENCLOSURE impairing compliance with 15.3.1 did not occur | | N/A |

| IEC 60601-1 | | | |
|-------------|--|---------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – Temperatures of APPLIED PARTS did not exceed allowable values in Table 24..... : | See appended Table 11.1.1 | P |
| | – Temperatures of ME EQUIPMENT parts that are not APPLIED PARTS likely to be touched did not exceed values in Table 23..... : | See appended Table 11.1.1 | P |
| | –Allowable values for “other components and materials” in Table 22 times 1.5 minus 12.5 °C were not exceeded | | P |
| | Limits for windings in Tables 26, 27, and 31 not exceeded | | P |
| | Table 22 not exceeded in all other cases | | P |
| | After tests of this Clause, settings of THERMAL CUT-OUTS and OVER-CURRENT RELEASES did not change sufficiently to affect their safety function | See appended Table 13.1.2 | P |
| 13.1.3 | – limits for LEAKAGE CURRENT in SINGLE FAULT CONDITION did not exceed..... : | See appended Table 8.7 | P |
| | – voltage limits for ACCESSIBLE PARTS including APPLIED PARTS did not exceed..... : | See appended Table 8.7 | P |
| 13. 2 | SINGLE FAULT CONDITIONS | | P |
| 13.2.1 | During the application of the SINGLE FAULT CONDITIONS listed in 13.2.2 to 13.2.13 (inclusive), the NORMAL CONDITIONS identified in 8.1 a) also applied in the least favourable combination | | P |
| | ME EQUIPMENT complied with 13.2.2 -13.2.12 : | See appended Table 13.2 | P |
| | RISK MANAGEMENT FILE includes and assessment of RISKS associated with leakage of liquid in a SINGLE FAULT CONDITION..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | RISK MANAGEMENT FILE defines the appropriate test conditions..... : | | N/A |
| 13.2.13 | ME EQUIPMENT remained safe after tests of 13.2.13.2 to 13.2.13.4, and cooling down to within 3 °C of test environment temperature | | P |
| | ME EQUIPMENT examined for compliance or appropriate tests such as dielectric strength of motor insulation according to 8.8.3 conducted | | P |
| | For insulation of thermoplastic materials relied upon as a MEANS OF PROTECTION, the ball-pressure test specified in 8.8.4.1 a) performed at a temperature 25 °C higher than temperature of insulation measured during tests of 13.2.13.2 to 13.2.13.4 (inclusive). | | P |
| 13.2.13.2 | ME EQUIPMENT with heating elements | | N/A |

| IEC 60601-1 | | | |
|-------------|---|-------------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | a 1) thermostatically controlled ME EQUIPMENT with heating elements for building-in, r for unattended operation, or with a capacitor not protected by a fuse connected in parallel with THERMOSTAT contacts met tests | No heating elements provided. | N/A |
| | a 2) ME EQUIPMENT with heating elements RATED for non-CONTINUOUS OPERATION met tests | | N/A |
| | a 3) other ME EQUIPMENT with heating elements met test | | N/A |
| | When more than one test was applicable to same ME EQUIPMENT, tests performed consecutively | | N/A |
| | Heating period stopped when a heating element or an intentionally weak part of a non-SELF-RESETTING THERMAL CUT-OUT ruptured, or current interrupted before THERMAL STABILITY without possibility of automatic restoration | | N/A |
| | Test repeated on a second sample when interruption was due to rupture of a heating element or an intentionally weak part | | N/A |
| | Both samples met 13.1.2, and open circuiting of a heating element or an intentionally weak part in second sample not considered a failure by itself | | N/A |
| | b) ME EQUIPMENT with heating elements without adequate heat discharge, and supply voltage set at 90 or 110 % of RATED supply voltage, least favourable of the two (V) : | | N/A |
| | Operating period stopped when a non-SELF-RESETTING THERMAL CUT-OUT operated, or current interrupted without possibility of automatic restoration before THERMAL STABILITY | | N/A |
| | ME EQUIPMENT switched off as soon as THERMAL STABILITY established and allowed to cool to room temperature when current not interrupted | | N/A |
| | Test duration was equal to RATED operating time for non-CONTINUOUS OPERATION | | N/A |
| | c) Heating parts of ME EQUIPMENT tested with ME EQUIPMENT operated in NORMAL CONDITION at 110 % of RATED supply voltage and as in 11.1, and | | N/A |
| | 1) Controls limiting temperature in NORMAL CONDITION disabled, except THERMAL CUT-OUTS | | N/A |
| | 2) When more than one control provided, they were disabled in turn | | N/A |
| | 3) ME EQUIPMENT operated at RATED DUTY CYCLE until THERMAL STABILITY achieved, regardless of RATED operating time | | N/A |

| IEC 60601-1 | | | |
|------------------|--|-------------------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 13.2.13.3 | ME EQUIPMENT with motors | | N/A |
| | a 1) For the motor part of the ME EQUIPMENT, compliance checked by tests of 13.2.8- 13.2.10, 13.2.13.3 b), 13.2.13.3 c), and 13.2.13.4, as applicable | No motors provided in power supply. | N/A |
| | To determine compliance with 13.2.9 and 13.2.10 motors in circuits running at 42.4 V peak a.c./ 60 V d.c. or less are covered with a single layer of cheesecloth which did not ignite during the test | | N/A |
| | a 2) Tests on ME EQUIPMENT containing heating parts conducted at prescribed voltage with motor & heating parts operated simultaneously to produce the least favourable condition | | N/A |
| | a 3) Tests performed consecutively when more tests were applicable to the same ME EQUIPMENT | | N/A |
| | b) Motor met running overload protection test of this clause when: | | N/A |
| | 1) it is intended to be remotely or automatically controlled by a single control device with no redundant protection, or | | N/A |
| | 2) it is likely to be subjected to CONTINUOUS OPERATION while unattended | | N/A |
| | Motor winding temperature determined during each steady period and maximum value did not exceed Table 27 (Insulation Class, Maximum temperature measured °C)..... : | | N/A |
| | Motor removed from ME EQUIPMENT and tested separately when load could not be changed in appropriate steps | | N/A |
| | Running overload test for motors operating at 42.4 V peak a.c./60 V d.c. or less performed only when examination and review of design indicated possibility of an overload | | N/A |
| | Test not conducted where electronic drive circuits maintained a substantially constant drive current | | N/A |
| | Test not conducted based on other justifications (justification)..... : | | N/A |
| | c) ME EQUIPMENT with 3-phase motors operated with normal load, connected to a 3-phase SUPPLY MAINS with one phase disconnected, and periods of operation per 13.2.10 | | N/A |
| 13.2.13.4 | ME EQUIPMENT RATED for NON-CONTINUOUS OPERATION | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-----------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | ME EQUIPMENT (other than HAND-HELD) operated under normal load and at RATED voltage or at upper limit of RATED voltage range until increase in temperature was $\leq 5^{\circ}\text{C}$ in one hour, or a protective device operated | Continuous operation. | N/A |
| | When a load-reducing device operated in NORMAL USE, test continued with ME EQUIPMENT running idle | | N/A |
| | Motor winding temperatures did not exceed values in 13.2.10 | | N/A |
| | Insulation Class | | — |
| | Maximum temperature measured ($^{\circ}\text{C}$)..... | | — |

| | | | |
|-------------|---|--|------------|
| 14 | PROGRAMMABLE ELECTRICAL MEDICAL SYSTEMS (PEMS) | | N/A |
| 14.1 | Requirements in 14.2 to 14.12 not applied to PEMS when it provides no functionality necessary for BASIC SAFETY or ESSENTIAL PERFORMANCE, or | No Such Parts/ PESS relied upon for Basic Safety or Essential Performance. | N/A |
| | - when application of RISK MANAGEMENT showed that failure of PESS does not lead to unacceptable RISK..... | | N/A |
| | RISK MANAGEMENT FILE contains an assessment of RISKS associated with the failure of the PESS: (ISO 14971 Cl. 4.2-4.4, 5) | | N/A |
| | Requirements of 14.13 not applied to PEMS intended to be incorporated into an IT NETWORK | | N/A |
| | When the requirements of 14.2 to 14.13 apply, the requirements of IEC 6204:2006 clause 4.3, 5, 7, 8 and 9 apply for the development or modification of software of each PESS | | N/A |
| | Software development process for Software Classification applied in accordance with Clause 4.3 of IEC 62304 | | N/A |
| | Software development process applied according to Clause 5 of IEC 62304..... | | N/A |
| | Software development process for Software risk management applied according to Clause 7 of IEC 62304 | | N/A |
| | Software development process Configuration Management applied according to Clause 8 of IEC 62304..... | | N/A |
| | Software development process for Software Problem Resolution applied according to Clause 9 of IEC 62304 | | N/A |

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 14.2 | Documents required by Clause 14 reviewed, approved, issued and revised according to a formal document control process | | N/A |
| 14.3 | RISK MANAGEMENT plan required by 4.2.2 includes reference to PEMS VALIDATION plan | | N/A |
| 14.4 | A PEMS DEVELOPMENT LIFE-CYCLE including a set of defined milestones has been documented | | N/A |
| | At each milestone, activities to be completed, and VERIFICATION methods to be applied to activities have been defined | | N/A |
| | Each activity including its inputs and outputs defined, and each milestone identifies RISK MANAGEMENT activities that must be completed before that milestone | | N/A |
| | PEMS DEVELOPMENT LIFE-CYCLE tailored for a specific development by making plans detailing activities, milestones, and schedules | | N/A |
| | PEMS DEVELOPMENT LIFE-CYCLE includes documentation requirements | | N/A |
| 14.5 | A documented system for problem resolution within and between all phases and activities of PEMS DEVELOPMENT LIFE-CYCLE has been developed and maintained | | N/A |
| 14.6 | RISK MANAGEMENT PROCESS | | N/A |
| 14.6.1 | MANUFACTURER considered HAZARDS associated with software and hardware aspects of PEMS including those associated with the incorporating PEMS into an IT-NETWORK, components of third-party origin, legacy subsystems when compiling list of known or foreseeable HAZARDS..... | | N/A |
| | RISK MANAGEMENT FILE includes known or foreseeable HAZARDS associated with software, hardware, incorporation of the PEMS into an IT-NETWORK, components of 3rd party origin and legacy subsystems..... (ISO 14971 Cl. 4.3) | | N/A |
| 14.6.2 | Suitably validated tools and PROCEDURES assuring each RISK CONTROL measure reduces identified RISK(s) satisfactorily provided in addition to PEMS requirements in Clause 4.2.2 : | | N/A |
| | RISK MANAGEMENT FILE documents the suitability of tools and procedures to validate each RISK CONTROL measure..... (ISO 14971 Cl. 6.1) | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 14.7 | A documented requirement specification for PEMS and each of its subsystems (e.g. for a PESS) which includes ESSENTIAL PERFORMANCE and RISK CONTROL measures implemented by that system or subsystem : (ISO 14971 Cl. 6.3) | | N/A |
| 14.8 | An architecture satisfying the requirement is specified for PEMS and each of subsystems : (ISO 14971 Cl. 6.3) | | N/A |
| 14.9 | Design is broken up into sub systems and descriptive data on design environment documented : | | N/A |
| 14.10 | A VERIFICATION plan containing the specified information used to verify and document functions implementing BASIC SAFETY, ESSENTIAL PERFORMANCE, or RISK CONTROL measures : (ISO 14971 Cl. 6.3) | | N/A |
| | – milestone(s) when VERIFICATION is to be performed for each function | | N/A |
| | – selection and documentation of VERIFICATION strategies, activities, techniques, and appropriate level of independence of the personnel performing the VERIFICATION | | N/A |
| | – selection and utilization of VERIFICATION tools | | N/A |
| | – coverage criteria for VERIFICATION | | N/A |
| | The VERIFICATION performed according to the VERIFICATION plan and results of the VERIFICATION activities documented | | N/A |
| 14.11 | A PEMS VALIDATION plan containing validation of BASIC SAFETY & ESSENTIAL PERFORMANCE : | | N/A |
| | The PEMS VALIDATION performed according to the PEMS VALIDATION plan with results of PEMS VALIDATION activities and methods used for PEMS VALIDATION documented | | N/A |
| | The person with overall responsibility for PEMS VALIDATION is independent | | N/A |
| | All professional relationships of members of PEMS VALIDATION team with members of design team documented in RISK MANAGEMENT FILE (ISO 14971 Cl. 6.3) | | N/A |
| 14.12 | Continued validity of previous design documentation assessed under a documented modification/change PROCEDURE | | N/A |
| | Software Classification for Software changes applied in accordance with Clause 4.3 of IEC 62304 : | | N/A |

| IEC 60601-1 | | | |
|--------------|---|-----------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Software Process for Software changes applied according to Clause 5 of IEC 62304..... : | | N/A |
| | RISK MANAGEMENT for Software changes applied according to Clause 7 of IEC 62304..... : | | N/A |
| | Configuration management of software changes applied per Clause 8 of IEC 62304 : | | N/A |
| | Problem resolution for Software changes applied according to Clause 9 of IEC 62304 : | | N/A |
| 14.13 | For PEMS incorporated into an IT-NETWORK not VALIDATED by the PEMS MANUFACTURER, instructions made available for implementing the connection include the following : | | N/A |
| | a) Purpose of the PEMS connection to an IT-NETWORK | | N/A |
| | b) required characteristics of the IT-NETWORK | | N/A |
| | c) required configuration of the IT-NETWORK | | N/A |
| | d) technical specifications of the network connection, including security specifications | | N/A |
| | e) intended information flow between the PEMS, the IT-NETWORK and other devices on the IT-NETWORK, and the intended routing through the IT-NETWORK | | N/A |
| | f) a list of HAZARDOUS SITUATIONS resulting from failure of the IT-NETWORK to provide the required characteristics (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.3) | | N/A |
| | ACCOMPANYING DOCUMENTS for the RESPONSIBLE ORGANIZATION include the following: | | N/A |
| | – statement that connection to IT-NETWORKS including other equipment could result in previously unidentified RISKS TO PATIENTS, OPERATORS or third parties | | N/A |
| | – Notification that the RESPONSIBLE ORGANIZATION should identify, analyse, evaluate and control these RISKS | | N/A |
| | – Notification that changes to the IT-NETWORK could introduce new RISKS that require additional analysis | | N/A |
| | - Changes to the IT-NETWORK include: - changes in network configuration - connection of additional items - disconnection of items - update of equipment - upgrade of equipment | | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|-----------------|---|--|------------|
| 15 | CONSTRUCTION OF ME EQUIPMENT | | P |
| 15.1 | RISKS associated with arrangement of controls and indicators of ME EQUIPMENT addressed through the application of a USABILITY ENGINEERING PROCESS..... : | No controls and indicators. | N/A |
| 15.2 | Parts of ME EQUIPMENT subject to mechanical wear, electrical, environmental degradation or ageing resulting in unacceptable RISK when unchecked for a long period, are accessible for inspection, replacement, and maintenance | | N/A |
| | Inspection, servicing, replacement, and adjustment of parts of ME EQUIPMENT can easily be done without damage to or interference with adjacent parts or wiring | | N/A |
| 15.3 | Mechanical strength | | P |
| 15.3.1 | Mould stress relief, push, impact, drop, and rough handling tests did not result in loss of BASIC SAFETY or ESSENTIAL PERFORMANCE | | P |
| 15.3.2 | Push test conducted | See Appended Table 15.3 Final determination to be competed in the end product for open frame model. | P |
| | No damage resulting in an unacceptable RISK sustained | | P |
| 15.3.3 | Impact test conducted..... : | See Appended Table 15.3 Final determination to be competed in the end product for open frame model. | P |
| | No damage resulting in an unacceptable RISK sustained | | P |
| 15.3.4 | Drop test | | P |
| 15.3.4.1 | Sample of HAND-HELD ME EQUIPMENT, ACCESSORIES and HAND-HELD part with SAFE WORKING LOAD tested | See Appended Table 15.3 Not hand-held ME equipment. | N/A |
| | No unacceptable RISK resulted | | N/A |
| 15.3.4.2 | Sample of PORTABLE ME EQUIPMENT, ACCESSORIES and PORTABLE part with SAFE WORKING LOAD withstood stress as demonstrated by test | See Appended Table 15.3 Final determination to be competed in the end product for open frame model. | P |
| | No damage resulting in an unacceptable RISK sustained | | P |

| IEC 60601-1 | | | |
|-------------|---|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 15.3.5 | MOBILE ME EQUIPMENT and MOBILE part with SAFE WORKING LOAD and in most adverse condition in NORMAL USE passed Rough Handling tests..... : | See Appended Table 15.3 Not mobile ME equipment. | N/A |
| | No damage resulting in an unacceptable RISK sustained | | N/A |
| 15.3.6 | Examination of ENCLOSURE made from moulded or formed thermoplastic material indicated that material distortion due to release of internal stresses by moulding or forming operations will not result in an unacceptable RISK | | P |
| | Mould-stress relief test conducted by placing one sample of complete ME EQUIPMENT, ENCLOSURE or a portion of larger ENCLOSURE, for 7 hours in a circulating air oven at 10°C over the max temperature measured on ENCLOSURE in 11.1.3, but no less than 70 °C : | 70°C | P |
| | No damage resulting in an unacceptable RISK | No damage. | P |
| 15.3.7 | INTENDED USE, EXPECTED SERVICE LIFE, and conditions for transport and storage were taken into consideration for selection and treatment of materials used in construction of ME EQUIPMENT | No such environmental influences. | N/A |
| | Based on review of EQUIPMENT, ACCOMPANYING DOCUMENTS, specifications and processing of materials, and MANUFACTURER'S relevant tests or calculations, corrosion, ageing, mechanical wear, degradation of biological materials due to bacteria, plants, animals and the like, will not result in an unacceptable RISK | Component, to be determined in end product evaluation. | N/A |
| 15.4 | ME EQUIPMENT components and general assembly | | N/A |
| 15.4.1 | Incorrect connection of accessible connectors, removable without a TOOL, prevented where an unacceptable RISK exists,..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | Final determination to be competed in the end product. | N/A |
| | a) Plugs for connection of PATIENT leads or PATIENT cables cannot be connected to outlets on same ME EQUIPMENT intended for other functions,..... : | | N/A |
| | b) Medical gas connections on ME EQUIPMENT for different gases to be operated in NORMAL USE are not interchangeable inspection : | | N/A |
| 15.4.2 | Temperature and overload control devices | | N/A |
| 15.4.2.1 | a) THERMAL CUT-OUTS and OVER-CURRENT RELEASES with automatic resetting not used in ME EQUIPMENT when their use could lead to a HAZARDOUS SITUATION : (ISO 14971 Cl. 4.2-4.4, 5) | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | b) THERMAL CUT-OUTS with a safety function with reset by a soldering not fitted in ME EQUIPMENT | | N/A |
| | c) An additional independent non-SELF-RESETTING THERMAL CUT-OUT is provided : (ISO 14971 Cl. 4.2-4.4) | | N/A |
| | d) Operation of THERMAL CUT-OUT or OVER CURRENT RELEASE doesn't result in a HAZARDOUS SITUATION or loss of ESSENTIAL PERFORMANCE : (ISO 14971 Cl. 4.2-4.4) | | N/A |
| | e) Capacitors or other spark-suppression devices not connected between contacts of THERMAL CUT-OUTS | | N/A |
| | f) Use of THERMAL CUT-OUTS or OVER-CURRENT RELEASES do not affect safety as verified by following tests | | N/A |
| | - Positive temperature coefficient devices) complied with IEC 60730-1: 2010, Clauses 15, 17, J.15, and J.17 | | N/A |
| | - ME EQUIPMENT containing THERMAL CUT-OUTS and OVER-CURRENT RELEASES operated under the conditions of Clause 13 : | See appended Table 13.2 | N/A |
| | - SELF-RESETTING THERMAL CUT-OUTS and OVER-CURRENT RELEASES including circuits performing equivalent functions Certified according to appropriate standards..... | | N/A |
| | - In the absence of Certification in accordance with IEC standards, SELF-RESETTING THERMAL CUT-OUTS and OVER-CURRENT RELEASES including circuits performing equivalent functions operated 200 times | | N/A |
| | Manual reset THERMAL CUT-OUTS and OVER-CURRENT RELEASES Certified in accordance with appropriate IEC standards | | N/A |
| | manual reset THERMAL CUT-OUTS and OVER-CURRENT RELEASES operated 10 times | | N/A |
| | Thermal protective devices tested separately from ME EQUIPMENT when engineering judgment indicated test results would not be impacted | | N/A |
| | g) Protective device incorporating a fluid filled container with heating means, operated when heater switched on with container empty and prevented an unacceptable RISK due to overheating | | N/A |
| | h) ME EQUIPMENT with tubular heating elements provided with protection against overheating : (ISO 14971 Cl. 4.2-4.4) | | N/A |

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 15.4.2.2 | Temperature settings clearly indicated when means provided to vary setting of THERMOSTATS | | N/A |
| 15.4.3 | Batteries | | N/A |
| 15.4.3.1 | Battery housings provided with ventilation.... : (ISO 14971 Cl. 4.2-4.4) | | N/A |
| | Battery compartments designed to prevent accidental short circuiting | | N/A |
| 15.4.3.2 | Means provided to prevent incorrect connection of polarity : | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of RISKS associated with incorrect connection or replacement of batteries : (ISO 14971 Cl. 4.2-4.4) | | N/A |
| 15.4.3.3 | Overcharging of battery prevented by virtue of design : | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of RISKS associated with overcharging of batteries : (ISO 14971 Cl. 4.2-4.4) | | N/A |
| 15.4.3.4 | Primary lithium batteries comply with IEC 80086-4 | | N/A |
| | Secondary lithium batteries comply with IEC 62133 | | N/A |
| 15.4.3.5 | A properly RATED protective device provided within INTERNAL ELECTRICAL POWER SOURCE to protect against fire : | | N/A |
| | Protective device has adequate breaking capacity | | N/A |
| | Justification for OVER-CURRENT RELEASES or FUSE exclusion is documented | | N/A |
| | Short circuit test between the positive and negative poles of an INTERNAL ELECTRICAL POWER SOURCE between the output and protective device(s) omitted where 2 MOOPS provided, or | | N/A |
| | Short circuit between the positive and negative poles of an INTERNAL ELECTRICAL POWER SOURCE between the output and protective device(s) does not result in any HAZARDOUS SITUATION | | N/A |
| 15.4.4 | Indicator lights provided to indicate ME EQUIPMENT is ready for : | | N/A |
| | An additional indicator light provided on ME EQUIPMENT with a stand-by state or a warm-up state exceeding 15 s, | | N/A |

| IEC 60601-1 | | | |
|-----------------|--|---------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Indicator lights provided on ME EQUIPMENT incorporating non-luminous heaters to indicate heaters are operational | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of RISKS associated with the use of indicator lights for EQUIPMENT incorporating non-luminous heaters : (ISO 14971 Cl. 4.2-4.4) | | N/A |
| | Requirement not applied to heated stylus-pens for recording purposes | | N/A |
| | Indicator lights provided on ME EQUIPMENT to indicate an output exists | | N/A |
| | Colours of indicator lights complied with 7.8.1 | | N/A |
| | Charging mode visibly indicated | | N/A |
| 15.4.5 | RISKS associated with pre-set controls addressed in RISK MANAGEMENT PROCESS : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| 15.4.6 | Actuating parts of controls of ME EQUIPMENT | | N/A |
| 15.4.6.1 | a) Actuating parts cannot be pulled off or loosened during NORMAL USE | | N/A |
| | b) Controls secured so that the indication of any scale always corresponds to the position of the control | | N/A |
| | c) Incorrect connection prevented by adequate construction when it could be separated without use of a TOOL | | N/A |
| | When torque values per Table 30 applied knobs did not rotate : | See appended Table 15.4.6 | N/A |
| | Tests conducted with no unacceptable RISK . : | See appended Table 15.4.6 | N/A |
| 15.4.6.2 | Stops on rotating/ movable parts of controls are of adequate mechanical strength : | See appended Table 15.4.6 | N/A |
| | Torque values in Table 30 applied : | See appended Table 15.4.6 | N/A |
| | No unexpected change of the controlled parameter when tested : | See appended Table 15.4.6 | N/A |
| 15.4.7 | Cord-connected HAND-HELD and foot-operated control devices | | N/A |
| 15.4.7.1 | a) HAND-HELD control devices of ME EQUIPMENT complied with 15.3.4.1 | | N/A |
| | b) Foot-operated control device supported an actuating force of 1350 N in its position of NORMAL USE with no damage : | | N/A |
| 15.4.7.2 | Control device of HAND-HELD and foot-operated control devices turned in all possible abnormal positions and placed on a flat surface : | | N/A |

| IEC 60601-1 | | | |
|-------------|---|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | No unacceptable RISK caused by changing control setting when accidentally placed in an abnormal position | | N/A |
| 15.4.7.3 | a) Foot-operated control device is at least rated IPX1 : | | N/A |
| | b) ENCLOSURE of foot operated control devices containing electrical circuits is at least IPX6.... : | | N/A |
| 15.4.8 | Aluminium wires less than 16 mm² in cross-sectional area are not used | | N/A |
| 15.4.9 | a) Oil container in PORTABLE ME EQUIPMENT allows for expansion of oil and is adequately sealed | | N/A |
| | b) Oil containers in MOBILE ME EQUIPMENT sealed to prevent loss of oil during transport | | N/A |
| | A pressure-release device operating during NORMAL USE is provided | | N/A |
| | c) Partially sealed oil-filled ME EQUIPMENT and its parts provided with means for checking the oil level to detect leakage | | N/A |
| | ME EQUIPMENT and technical description examined, and manual tests conducted to confirm compliance with above requirements | | N/A |
| 15.5 | MAINS SUPPLY TRANSFORMERS OF ME EQUIPMENT and transformers providing separation in accordance with 8.5 | | P |
| 15.5.1 | Overheating | | P |
| 15.5.1.1 | Transformers of ME EQUIPMENT are protected against overheating : | See appended Tables 15.5.1.2 and 15.5.1.3 | P |
| | During tests, windings did not open, no HAZARDOUS SITUATION occurred, and maximum temperatures of windings did not exceed values in Table 31 | | P |
| | Dielectric strength test conducted after short circuit and overload tests : | See appended Table 15.5.2 | P |
| 15.5.1.2 | Transformer output winding short circuited, and test continued until protective device operated or THERMAL STABILITY achieved : | See appended Table 15.5.1.2 | P |
| | Short circuit applied directly across output windings | | P |
| 15.5.1.3 | Multiple overload tests conducted on windings : | No more than one protective device | N/A |
| 15.5.2 | Transformers operating at a frequency above 1kHz tested according to clause 8.8.3..... : | | P |
| | Transformer windings provided with adequate insulation | | P |

| IEC 60601-1 | | | |
|---------------|---|---------------------------|----------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Dielectric strength tests were conducted : | See appended Table 15.5.2 | P |
| 15.5.3 | Transformers forming MEANS OF PROTECTION as required by 8.5 comply with : | See appended Table 8.10 | P |
| | - Means provided to prevent displacement of end turns | | P |
| | - protective earth screens with a single turn have insulated overlap | | P |
| | - Exit of wires from internal windings of toroid transformers protected with double sleeving | | P |
| | - insulation between primary and secondary windings complies with 8.8.2 | | P |
| | - CREEPAGE DISTANCES and AIR CLEARANCE comply with 8.9.4 | | P |

| | | | |
|-------------|---|---|------------|
| 16 | ME SYSTEMS | | N/A |
| 16.1 | After installation or subsequent modification, ME SYSTEM didn't result in an unacceptable RISK | Component power supply; compliance determined in the end product. | N/A |
| | RISK MANAGEMENT FILE includes an assessment of RISKS associated with installation and modification of an ME SYSTEM.....: (ISO 14971 Cl. 4.2-4.4, 5) | | N/A |
| | Only HAZARDS arising from combining various equipment to form a ME SYSTEM considered | | N/A |
| | – ME SYSTEM provides the level of safety within the PATIENT ENVIRONMENT equivalent to ME EQUIPMENT complying with this standard | | N/A |
| | – ME SYSTEM provides the level of safety outside PATIENT ENVIRONMENT equivalent to equipment complying with their respective IEC or ISO safety standards | | N/A |
| | – tests performed in NORMAL CONDITION, except as specified | | N/A |
| | – tests performed under operating conditions specified by MANUFACTURER of ME SYSTEM | | N/A |
| | Safety tests previously conducted on individual equipment of ME SYSTEM according to relevant standards not repeated | | N/A |
| | RISK MANAGEMENT methods used by MANUFACTURER of an ME SYSTEM reconfigurable by RESPONSIBLE ORGANIZATION or OPERATOR | | N/A |
| | Non-ME EQUIPMENT used in ME SYSTEM complied with applicable IEC or ISO safety standards | | N/A |

| IEC 60601-1 | | | |
|-------------|---|-----------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Equipment relying only on BASIC INSULATION for protection against electric shock not used in ME SYSTEM | | N/A |
| 16.2 | ACCOMPANYING DOCUMENTS of an ME SYSTEM | | N/A |
| | Documents containing all data necessary for ME SYSTEM to be used as intended by MANUFACTURER including a contact address accompany ME SYSTEM or modified ME SYSTEM | | N/A |
| | ACCOMPANYING DOCUMENTS regarded as a part of ME SYSTEM | | N/A |
| | a) ACCOMPANYING DOCUMENTS provided for each item of ME EQUIPMENT supplied by MANUFACTURER | | N/A |
| | b) ACCOMPANYING DOCUMENTS provided for each item of non-ME EQUIPMENT supplied by MANUFACTURER | | N/A |
| | c) the required information is provided: | | N/A |
| | – specifications, instructions for use as intended by MANUFACTURER, and a list of all items forming the ME SYSTEM | | N/A |
| | – instructions for installation, assembly, and modification of ME SYSTEM to ensure continued compliance with this standard | | N/A |
| | – instructions for cleaning and, when applicable, disinfecting and sterilizing each item of equipment or equipment part forming part of the ME SYSTEM | | N/A |
| | – additional safety measures to be applied during installation of ME SYSTEM | | N/A |
| | – identification of parts of ME SYSTEM suitable for use within the PATIENT ENVIRONMENT | | N/A |
| | – additional measures to be applied during preventive maintenance | | N/A |
| | – a warning forbidding placement of MULTIPLE SOCKET-OUTLET, when provided and it is a separate item, on the floor | | N/A |
| | – a warning indicating an additional MULTIPLE SOCKET-OUTLET or extension cord not to be connected to ME SYSTEM | | N/A |
| | – a warning to connect only items that have been specified as part of ME SYSTEM or specified as being compatible with ME SYSTEM | | N/A |
| | – maximum permissible load for any MULTIPLE SOCKET-OUTLET(S) used with ME SYSTEM | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – instructions indicating MULTIPLE SOCKET-OUTLETS provided with the ME SYSTEM to be used only for supplying power to equipment intended to form part of ME SYSTEM | | N/A |
| | – an explanation indicating RISKS of connecting non-ME EQUIPMENT supplied as a part of ME SYSTEM directly to wall outlet when non-ME EQUIPMENT is intended to be supplied via a MULTIPLE SOCKET-OUTLET with a separating transformer | | N/A |
| | – an explanation indicating RISKS of connecting any equipment supplied as a part of ME SYSTEM to MULTIPLE SOCKET-OUTLET | | N/A |
| | – permissible environmental conditions of use for ME SYSTEM including conditions for transport and storage | | N/A |
| | – instructions to OPERATOR not to, simultaneously, touch parts referred to in 16.4 and PATIENT | | N/A |
| | d) the following instructions provided for use by RESPONSIBLE ORGANIZATION: | | N/A |
| | – adjustment, cleaning, sterilization, and disinfection PROCEDURES | | N/A |
| | – assembly of ME SYSTEMS and modifications during actual service life shall be evaluated based on the requirements of this standard | | N/A |
| 16.3 | Instructions for use of ME EQUIPMENT intended to receive its power from other equipment in an ME SYSTEM, describe the other equipment to ensure compliance with these requirements | | N/A |
| | Transient currents restricted to allowable levels for the specified IPS or UPS : | | N/A |
| | Technical description and installation instructions specify the actual transient currents where an IPS or UPS is not specified | | N/A |
| 16.4 | Parts of non-ME EQUIPMENT in PATIENT ENVIRONMENT subject to contact by OPERATOR during maintenance, calibration, after removal of covers, connectors operated at a voltage ≤ voltage in 8.4.2 c) | | N/A |
| 16.5 | Safety measures incorporating a SEPARATION DEVICE applied when FUNCTIONAL CONNECTION between ME EQUIPMENT and other items of an ME SYSTEM or other systems can cause allowable values of LEAKAGE CURRENT to exceed | | N/A |
| | SEPARATION DEVICE has dielectric strength, CREEPAGE and CLEARANCES required for one MEANS OF OPERATOR PROTECTION | | N/A |

| IEC 60601-1 | | | |
|-----------------|--|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | WORKING VOLTAGE was highest voltage across SEPARATION DEVICE during a fault condition, but not less than MAXIMUM MAINS VOLTAGE (V)..... : | | N/A |
| 16.6 | LEAKAGE CURRENTS | | N/A |
| 16.6.1 | TOUCH CURRENT in NORMAL CONDITION did not exceed 100 μA..... : | See appended Table 16.6.1 | N/A |
| | TOUCH CURRENT did not exceed 500 μA in event of interruption of any non-PERMANENTLY INSTALLED PROTECTIVE EARTH CONDUCTOR..... : | See appended Table 16.6.1 | N/A |
| 16.6.2 | Current in PROTECTIVE EARTH CONDUCTOR of MULTIPLE SOCKET-OUTLET didn't exceed 5 mA : | | N/A |
| 16.6.3 | PATIENT LEAKAGE CURRENT and total PATIENT LEAKAGE CURRENT of ME SYSTEM in NORMAL CONDITION did not exceed values : | See appended Tables 8.7 8.7.4.7 and 16.6.1 | N/A |
| 16.7 | ME SYSTEM complied with applicable requirements of Clause 9..... : | See applicable appended Tables in section 9 | N/A |
| 16.8 | Interruption and restoration power to the ME SYSTEM or any part of the ME SYSTEM did not result in a loss of BASIC SAFETY or ESSENTIAL PERFORMANCE | | N/A |
| 16.9 | ME SYSTEM connections and wiring | | N/A |
| 16.9.1 | Incorrect connection of accessible connectors, removable without a TOOL, prevented where unacceptable RISK can result : | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of RISKS associated with plugs for connection of PATIENT leads or cables likely to be located in the PATIENT ENVIRONMENT : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | – Plugs for connection of PATIENT leads or PATIENT cables could not be connected to other outlets of the same ME SYSTEM likely to be located in PATIENT ENVIRONMENT, except when examination of connectors and interchanging them proved no unacceptable RISK results | | N/A |
| | Medical gas connections on the ME SYSTEM for different gasses operated in NORMAL USE are not interchangeable | | N/A |
| 16.9.2 | MAINS PARTS, components and layout | | N/A |
| 16.9.2.1 | a) – MULTIPLE SOCKET-OUTLET only allows connection using a TOOL, or | | N/A |
| | – MULTIPLE SOCKET-OUTLET is of a type that cannot accept MAINS PLUGS of any of the kinds specified in IEC/TR 60083, or | | N/A |
| | – MULTIPLE SOCKET-OUTLET is supplied via a separating transformer | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | b) – MULTIPLE SOCKET-OUTLET marked with safety sign 2 of Table D.2 visible in NORMAL USE, and | | N/A |
| | – marked either individually or in combinations, with the maximum allowed continuous output in amperes or volt-amperes, or | | N/A |
| | – marked to indicate the equipment or equipment parts it may safely be attached to | | N/A |
| | – MULTIPLE SOCKET-OUTLET is a separate item or an integral part of ME EQUIPMENT or non-ME EQUIPMENT | | N/A |
| | c) MULTIPLE SOCKET-OUTLET complied with IEC 60884-1 and the following requirements: | | N/A |
| | – CREEPAGE and CLEARANCES complied with 8.9 | | N/A |
| | – It is CLASS I, and PROTECTIVE EARTH CONDUCTOR is connected to earthing contacts in socket-outlets | | N/A |
| | – PROTECTIVE EARTH TERMINALS and PROTECTIVE EARTH CONNECTIONS comply with 8.6: | | N/A |
| | – ENCLOSURE complied with 8.4.2 d) | | N/A |
| | – MAINS TERMINAL DEVICES and wiring complied with 8.11.4, when applicable | | N/A |
| | – RATINGS of components are not in conflict with conditions of use | See appended Table 8.10 | N/A |
| | – Electrical terminals and connectors of MULTIPLE SOCKET-OUTLETS prevent incorrect connection of accessible connectors removable without a TOOL | | N/A |
| | – POWER SUPPLY CORD complied with 8.11.3 | | N/A |
| | d) Additional requirements applied when MULTIPLE SOCKET-OUTLET combined with a separating transformer: | | N/A |
| | – Separating transformer complied with this standard or IEC 61558-2-1, | See appended Table 8.10 | N/A |
| | – Separating transformer is CLASS I | | N/A |
| | – Degree of protection against ingress of water specified as in IEC 60529 | | N/A |
| | – Separating transformer assembly marked according to 7.2 and 7.3 | | N/A |
| | – MULTIPLE SOCKET-OUTLET permanently connected to separating transformer, or socket-outlet of separating transformer assembly cannot accept MAINS PLUGS as identified in IEC/TR 60083 | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 16.9.2.2 | The impedance between the protective earth pin in the MAINS PLUG and any part that is PROTECTIVELY EARTHED did not exceed 200 mΩ | | N/A |
| | Removal of any single item of equipment in ME SYSTEM will not interrupt the protective earthing of any other part without simultaneous disconnection of electrical supply to that part | | N/A |
| | Additional PROTECTIVE EARTH CONDUCTORS can be detachable only by use of a TOOL | | N/A |
| 16.9.2.3 | Conductors connecting different items within an ME SYSTEM protected against mechanical damage | | N/A |

| | | | |
|----|---|--|-----|
| 17 | ELECTROMAGNETIC COMPATIBILITY OF ME EQUIPMENT AND ME SYSTEMS | | N/A |
| | RISKS associated confirmed by review | Not applicable to component power supply system; to be determined in the end product | N/A |
| | – electromagnetic phenomena at locations where ME EQUIPMENT or ME SYSTEM is to be used as stated in ACCOMPANYING DOCUMENTS | | N/A |
| | RISK MANAGEMENT FILE includes an assessment of risks associated with the introduction of electromagnetic phenomena into the environment by the EQUIPMENT or SYSTEM..... : (ISO 14971 Cl. 4.2-4.4, 5, 6.2-6.5) | | N/A |
| | – introduction of electromagnetic phenomena into environment by ME EQUIPMENT or ME SYSTEM that might degrade performance of other devices, electrical equipment, and systems | | N/A |

| | | | |
|---------|---|--|-----|
| ANNEX G | PROTECTION AGAINST HAZARDS OF IGNITION OF FLAMMABLE ANESTHETIC MIXTURES | | N/A |
| G.2 | Locations and basic requirements | | N/A |
| G.2.1 | Parts of CATEGORY APG ME EQUIPMENT in which a FLAMMABLE ANAESTHETIC MIXTURE WITH AIR occurs are CATEGORY AP or APG ME EQUIPMENT and complied with G.3, G.4, and G.5 | Not evaluated for use with Flammable Anesthetics Mixture | N/A |
| G.2.2 | FLAMMABLE AESTHETIC MIXTURE WITH | | N/A |
| G.2.3 | A FLAMMABLE AESTHETIC MIXTURE WITH OXYGEN or NITROUS OXIDE | | N/A |
| G.2.4 | ME EQUIPMENT specified for use with FLAMMABLE AESTHETIC MIXTURE WITH AIR complied with G.4 and G.5 | | N/A |

| IEC 60601-1 | | | |
|--------------|---|------------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| G.2.5 | ME EQUIPMENT or parts thereof for use with FLAMMABLE AESTHETIC MIXTURE WITH OXYGEN OR NITROUS OXIDE comply with G.4 and G.6 | | N/A |
| | ME EQUIPMENT in G.2.4 to G.2.5 met appropriate tests of G.3-G.5 conducted after tests of 11.6.6 and 11.6.7 | | N/A |
| G.3 | Marking, ACCOMPANYING DOCUMENTS | | |
| G.3.1 | CATEGORY APG ME EQUIPMENT prominently marked "APG" (symbol 23 in Table D.1)..... : | See copies of Marking Labels | N/A |
| | Length of green-coloured band is ≥ 4 cm, and size of marking is as large as possible for particular case | | N/A |
| | When above marking not possible, relevant information included in instructions for use ... : | | N/A |
| | Marking complied with tests and criteria of 7.1.2 and 7.1.3 | | N/A |
| G.3.2 | CATEGORY AP ME EQUIPMENT prominently marked, with a green-coloured circle "AP" (symbol 22 in Table D.1)..... : | See copies of Marking Labels | N/A |
| | Marking is as large as possible for the particular case | | N/A |
| | When above marking not possible, the relevant information included in instructions for use ... : | | N/A |
| | Marking complied with tests and criteria of 7.1.2 and 7.1.3 | | N/A |
| G.3.3 | The marking placed on major part of ME EQUIPMENT for CATEGORY AP or APG parts | | N/A |
| G.3.4 | ACCOMPANYING DOCUMENTS contain an indication enabling the RESPONSIBLE ORGANIZATION to distinguish between CATEGORY AP and APG parts | | N/A |
| G.3.5 | Marking clearly indicates which parts are CATEGORY AP or APG when only certain ME EQUIPMENT parts are CATEGORY AP or APG | | N/A |
| G.4 | Common requirements for CATEGORY AP and CATEGORY APG ME EQUIPMENT | | |
| G.4.1 | a) CREEPAGE and CLEARANCES are according to Table 12 for one MEANS OF PATIENT PROTECTION | | N/A |
| | b) Connections protected against accidental disconnection | | N/A |
| | c) CATEGORY AP and APG not provided with a DETACHABLE POWER SUPPLY CORD, | | N/A |
| G.4.2 | Construction details | | |
| | a) Opening of an ENCLOSURE protecting against penetration of gases or vapours into ME EQUIPMENT or its parts possible only with a TOOL | | N/A |

| IEC 60601-1 | | | |
|--------------|--|--|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | b) ENCLOSURE complies with : | See appended Table 8.10 | N/A |
| | – no openings on top covers of ENCLOSURE, | | N/A |
| | – openings in side-covers prevented penetration of a solid cylindrical test rod | | N/A |
| | – openings in base plates prevented penetration of a solid cylindrical test | | N/A |
| | c) Short circuiting conductor(s) to a conductive part (when no explosive gasses) did not result in loss of integrity of the part, an unacceptable temperature, or any HAZARDOUS SITUATION | | N/A |
| G.4.3 | a) Electrostatic charges prevented on CATEGORY AP and APG ME EQUIPMENT by a combination of appropriate measures | | N/A |
| | – Use of antistatic materials with a limited electrical resistance : | See appended Table 8.10 | N/A |
| | – Provision of electrically conductive paths from ME EQUIPMENT or its parts to a conductive floor, protective earth or potential equalization system, or via wheels to an antistatic floor | | N/A |
| | b) Electrical resistance limits of aesthetic tubing, mattresses/ pads, castor tires & other antistatic material comply with ISO 2882 : | | N/A |
| G.4.4 | Corona cannot be produced by components or parts of ME EQUIPMENT operating at more than 2000 V a.c. or 2400 V d.c. and not included in ENCLOSURES complying with G.5.4 or G.5.5 | | N/A |
| G.5 | Requirements and tests for CATEGORY AP ME EQUIPMENT, parts and components | | |
| G.5.1 | ME EQUIPMENT, its parts or components do not ignite FLAMMABLE AESTHETIC MIXTURES WITH AIR under NORMAL USE and CONDITIONS based on compliance with G.5.2 to G.5.5 | | N/A |
| | Alternatively, ME EQUIPMENT, its parts, and components complied with requirements of IEC 60079-0 for pressurized ENCLOSURES (IEC 60079-2); for sand-filled ENCLOSURES, IEC 60079-5; or for oil immersed equipment, IEC 60079-6; and with this standard excluding G.5.2 to G.5.5 : | | N/A |
| G.5.2 | Temperature limits..... : | See appended Tables 11.1.1 and 11.2.2.1 | N/A |
| G.5.3 | ME EQUIPMENT, its parts, and components producing sparks in NORMAL USE and CONDITION complied with temperature requirements of G.5.2, and U_{max} and I_{max} occurring in their circuits, and complied as follows: | | N/A |
| | Measured $U_{max} \leq U_{zR}$ with I_{zR} as in Fig. G.1..... : | $U_{max} = __\text{V}$ $U_{zR} = __\text{V}$ $I_{zR} = __\text{A}$ | N/A |

| IEC 60601-1 | | | |
|--------------|---|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Measured $U_{max} \leq U_c$ with C_{max} as in Fig. G.2 ... : | $U_{max} = __V$ $U_c = __V$ $C_{max} = __\mu F$ | N/A |
| | Measured $I_{max} \leq I_{zR}$ with U_{zR} as in Fig G.1 : | $I_{max} = __A$ $I_{zR} = __A$ $U_{zR} = __V$ | N/A |
| | Measured $I_{max} \leq I_{zL}$ with L_{max} and a $U_{max} \leq 24 V$ as in Fig G.3 : | $I_{max} = __A$ $I_{zL} = __A$ $L_{max} = __mH$ | N/A |
| | – Combinations of currents and corresponding voltages within the limitations $I_{zR}.U_{zR} \leq 50 W$ extrapolated from Fig G.1 | | N/A |
| | No extrapolation made for voltages above 42 V | | N/A |
| | – Combinations of capacitances and corresponding voltages within limitations of $C/2U^2 \leq 1.2 mJ$ extrapolated from Fig G.2 | | N/A |
| | No extrapolation made for voltages above 242V | | N/A |
| | U_{max} determined using actual resistance R | | N/A |
| | – Combinations of currents and corresponding inductances within limitations $L/2I^2 \leq 0.3 mJ$ extrapolated from Fig G.3 | | N/A |
| | No extrapolation made for inductances larger than 900 mH | | N/A |
| | – U_{max} was the highest supply voltage occurring in circuit under investigation with sparking contact open | | N/A |
| | – I_{max} was the highest current flowing in circuit under investigation with sparking contact closed | | N/A |
| | – C_{max} and L_{max} taken as values occurring at the component under investigation producing sparks | | N/A |
| | – Peak value considered when a.c. supplied | | N/A |
| | – An equivalent circuit calculated to determine equivalent max capacitance, inductance, and equivalent U_{max} and I_{max}, either as d.c. or a.c. peak values in case of a complicated circuit... : | | N/A |
| | Temperature measurements made according to 11.1, and U_{max}, I_{max}, R, L_{max}, and C_{max} determined with application of Figs G.1-G.3 .. : | See appended Table 11.1.1 | N/A |
| | Alternatively, compliance was verified by examination of design data: | | N/A |
| G.5.4 | External ventilation with internal overpressure | | |

| IEC 60601-1 | | | |
|--------------|---|-------------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | ME EQUIPMENT, its parts, and components enclosed in an ENCLOSURE with external ventilation by means of internal overpressure complied with the following requirements: | | N/A |
| | a) FLAMMABLE AESTHETIC MIXTURES WITH AIR t removed by ventilation before EQUIPMENT energized, | | N/A |
| | b) Overpressure inside ENCLOSURE was 75 Pa, min., in NORMAL CONDITION (Pa)..... : | | N/A |
| | Overpressure maintained at the site of potential ignition | | N/A |
| | ME EQUIPMENT could be energized only after the required minimum overpressure was present long enough to ventilate the ENCLOSURE | | N/A |
| | ME EQUIPMENT energized at will or repeatedly when overpressure was continuously present | | N/A |
| | c) Ignition sources de-energized automatically when during operation overpressure dropped below 50 Pa (Pa) : | | N/A |
| | d) External surface of ENCLOSURE did not exceed 150 °C in 25 °C : | | N/A |
| G.5.5 | ENCLOSURES with restricted breathing | | |
| | ME EQUIPMENT, its parts, and components enclosed in an ENCLOSURE with restricted breathing complied with the following: | | N/A |
| | a) A FLAMMABLE AESTHETIC MIXTURE WITH AIR did not form inside ENCLOSURE with restricted breathing | | N/A |
| | b) Gasket or sealing material used to maintain tightness complied with aging test B-b of IEC 60068-2-2, Clause 15, at 70 °C ± 2 °C and 96 h : | See appended Table 8.10 | N/A |
| | c) Gas-tightness of ENCLOSURE containing inlets for flexible cords maintained | | N/A |
| | Cords are fitted with adequate anchorages to limit stresses as determined by test | | N/A |
| | Overpressure not reduced below 200 Pa | | N/A |
| | Tests waived when examination of ENCLOSURE indicated it is completely sealed or gas-tight without a doubt (100 % degree of certainty) | | N/A |
| | Operating temperature of external surface of ENCLOSURE was ≤ 150 °C in 25 °C (°C) : | | N/A |
| | Steady state operating temperature of ENCLOSURE also measured (°C) : | | N/A |
| G.6 | CATEGORY APG ME EQUIPMENT, parts and components thereof | | |

| IEC 60601-1 | | | |
|--------------|---|---|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| G.6.1 | ME EQUIPMENT, its parts, and components did not ignite FLAMMABLE AESTHETIC MIXTURE WITH OXYGEN OR NITROUS OXIDE under NORMAL USE and SINGLE FAULT CONDITION | | N/A |
| | ME EQUIPMENT, its parts, and components not complying with G.6.3 subjected to a CONTINUOUS OPERATION test | | N/A |
| G.6.2 | Parts and components of CATEGORY APG ME EQUIPMENT operating in a FLAMMABLE AESTHETIC MIXTURE WITH OXYGEN OR NITROUS OXIDE supplied from a source isolated from earth by insulation equal to one MEANS OF PATIENT PROTECTION and from electrical parts by insulation twice the MEANS OF PATIENT PROTECTION..... : | | N/A |
| G.6.3 | Test of G.6.1 waived when the following requirements were met in NORMAL USE and under NORMAL and SINGLE FAULT CONDITIONS..... : | | N/A |
| | a) no sparks produced and temperatures did not exceed 90 °C, or | See Tables 11.1.1, 11.2.2.1 and 13.2 | N/A |
| | b) a temperature limit of 90 °C not exceeded, sparks produced in NORMAL USE, and SINGLE FAULT CONDITIONS, except U_{max} and I_{max} occurring in their circuits complied with requirements, taking C_{max} and L_{max} into consideration: | See Tables 11.1.1 and 13.2 | N/A |
| | Measured $U_{max} \leq U_{zR}$ with I_{zR} as in Fig. G.4 : | $U_{max} = __V$ $U_{zR} = __V$ $I_{zR} = __A$ | N/A |
| | Measured $U_{max} \leq U_{zC}$ with C_{max} as in Fig. G.5... : | $U_{max} = __V$ $U_c = __V$ $C_{max} = __\mu F$ | N/A |
| | Measured $I_{max} \leq I_{zR}$ with U_{zR} as in Fig G.4 : | $I_{max} = __A$ $I_{zR} = __A$ $U_{zR} = __V$ | N/A |
| | Measured $I_{max} \leq I_{zL}$ with L_{max} and a $U_{max} \leq 24 V$ as in Fig G.6 : | $I_{max} = __A$ $I_{zL} = __A$ $L_{max} = __mH$ | N/A |
| | – Extrapolation from Figs G.4, G.5, and G.6 was limited to areas indicated | | N/A |
| | – U_{max} was the highest no-load voltage occurring in the circuit under investigation, taking into consideration mains voltage variations as in 4.10 | | N/A |
| | – I_{max} was the highest current flowing in the circuit under investigation, taking into account MAINS VOLTAGE variations as in 4.10 | | N/A |
| | – C_{max} and L_{max} are values occurring in relevant circuit | | N/A |

| IEC 60601-1 | | | |
|-------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – U_{max} additionally determined with actual resistance R when equivalent resistance R in Fig G.5 was less than 8000 Ω | | N/A |
| | – Peak value considered when a.c. supplied | | N/A |
| | – An equivalent circuit calculated to determine max capacitance, inductance, and U_{max} and I_{max} , either as d.c. or a.c. peak values in case of a complicated circuit | | N/A |
| | – When energy produced in an inductance or capacitance in a circuit is limited by voltage or current-limiting devices, two independent components applied, to obtain the required limitation even when a first fault (short or open circuit) in one of these components | | N/A |
| | - requirement not applied to transformers complying with this standard | | N/A |
| | - requirement not applied to wire-wound current-limiting resistors provided with a protection against unwinding of the wire in case of rupture | | N/A |
| | Compliance verified by examination of CATEGORY APG ME EQUIPMENT, parts, and components , or | | N/A |
| | Temperature measurements made in accordance with 11.1..... | See Table 11.1.1 | N/A |
| | - or U_{max} , I_{max} , R, L_{max} and C_{max} determined together with application of Figs G.4-G.6 | $U_{max} = __V$ $I_{max} = __A$ $R = __\Omega$ $L_{max} = __mH$ $C_{max} = __\mu F$ | N/A |
| | Alternatively, compliance verified by comparison with design data | | N/A |
| G.6.4 | ME EQUIPMENT, its parts, and components heating a FLAMMABLE AESTHETIC MIXTURE WITH OXYGEN OR NITROUS OXIDE provided with a non-SELF-RESETTING THERMAL CUT-OUT and complied with 15.4.2.1 | See appended Table 8.10 | N/A |
| | Current-carrying part of heating element is not in direct contact with FLAMMABLE AESTHETIC MIXTURE WITH OXYGEN OR NITROUS OXIDE | | N/A |
| G.7 | Test apparatus for flammable mixtures according to this Clause and Fig G.7 | | N/A |
| ANNEX L | INSULATED WINDING WIRES FOR USE WITHOUT INTERLEAVED INSULATION | | N/A |

| IEC 60601-1 | | | |
|-------------|--|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| L.1 | BASIC, SUPPLEMENTARY, DOUBLE, and REINFORCED INSULATION in wound components without interleaved insulation complied with this Annex | Approved TIW is used in mains transformer. | N/A |
| L.2 | Wire construction | | |
| | Overlap of layers when wire is insulated with two or more spirally wrapped layers of tape is adequate to ensure continued overlap during manufacture of wound component | Approved TIW is used in mains transformer. | N/A |
| | Layers of spirally wrapped wire insulation are sufficiently secured to maintain the overlap | | N/A |
| L.3 | Type Test | | |
| | The wire subjected to tests of L.3.1 to L.3.4 at a temperature and a relative humidity specified | Approved TIW is used in mains transformer. | N/A |
| | Temperature (°C)..... : | | N/A |
| | Humidity (%)..... : | | N/A |
| L.3.1 | Dielectric strength | | |
| | Dielectric strength test of Clause 8.8.3 for the appropriate type and number of MOP(s) conducted with no breakdown: | Approved TIW is used in mains transformer. | N/A |
| | – 3000 V for BASIC and SUPPLEMENTARY INSULATION (V)..... : | | N/A |
| | – 6000 V for REINFORCED INSULATION (V) : | | N/A |
| L.3.2 | Flexibility and adherence | | |
| | Sample subjected to flexibility and adherence | Approved TIW is used in mains transformer. | N/A |
| | Sample examined per IEC 60851-3: 1997, cl. 5.1.1.4, followed by dielectric test of cl. 8.8.3, with no breakdown | | N/A |
| | Test voltage was at least the voltage in Tables 6 and 7 but not less than the following: | | N/A |
| | – 1500 V for BASIC and SUPPLEMENTARY INSULATION (V)..... : | | N/A |
| | – 3000 V for REINFORCED INSULATION (V) : | | N/A |
| | Tension applied to wire during winding on mandrel calculated from the wire diameter equivalent to 118 MPa ± 11.8 MPa : | | N/A |
| L.3.3 | Heat Shock | | |
| | Sample subjected to heat shock test 9 of IEC 60851-6:1996, followed by dielectric strength test of clause 8.8.3 | Approved TIW is used in mains transformer. | N/A |
| | Test voltage was at least the voltage in Tables 6 and 7, but not less than the following: | | N/A |

| IEC 60601-1 | | | |
|--------------|--|--|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | – 1500 V for BASIC and SUPPLEMENTARY INSULATION (V)..... : | | N/A |
| | – 3000 V for REINFORCED INSULATION (V) : | | N/A |
| | Oven temperature based on Table L.2 (°C)..... : | | N/A |
| | Mandrel diameter and tension applied as in clause L.3.2, (MPa; N/mm ²) : | | N/A |
| | Dielectric strength test conducted at room temperature after removal from the oven | | N/A |
| L.3.4 | Retention of electric strength after bending | | |
| | Five samples prepared as in L.3.2 subjected to dielectric strength and bending tests | Approved TIW is used in mains transformer. | N/A |
| | Test voltage was at least the voltage in Tables 6 and 7, but not less than the following: | | N/A |
| | – 1500 V for BASIC and SUPPLEMENTARY INSULATION (V)..... : | | N/A |
| | – 3000 V for REINFORCED INSULATION (V) : | | N/A |
| | Test voltage applied between the shot and conductor | | N/A |
| | Mandrel diameter and tension applied as in L.3.2, (MPa; N/mm ²) : | | N/A |
| L.4 | Tests during manufacture | | |
| L.4.1 | Production line dielectric strength tests done by the manufacture per L.4.2 and L.4.3 | See attached manufacturer's routine testing verification | N/A |
| L.4.2 | Test voltage for routine testing (100 % testing) is at least the voltage in Tables 6 and 7 but not less than the following: | | N/A |
| | – 1500 V r.m.s. or 2100 V peak for BASIC and SUPPLEMENTARY INSULATION (V)..... : | See manufacturer's routine testing verification | N/A |
| | – 3000 V r.m.s. or 4200 V peak for REINFORCED INSULATION (V) : | See manufacturer's routine testing verification | N/A |
| L.4.3 | Sampling tests conducted using twisted pair samples (IEC 60851-5:1996, clause 4.4.1) | See manufacturer's routine testing verification | N/A |
| | Minimum breakdown test voltage at least twice the voltage in Tables 6 and 7 but not less than: | | N/A |
| | – 3000 V r.m.s. or 4200 V peak for BASIC and SUPPLEMENTARY INSULATION..... : | See manufacturer's routine testing verification | N/A |
| | – 6000 V r.m.s. or 8400 V peak for REINFORCED INSULATION : | See manufacturer's routine testing verification | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | |
|-------|--|-----|
| 4.2.2 | RM RESULTS TABLE: General requirements for RISK MANAGEMENT | N/A |
|-------|--|-----|

| | | |
|-----|------------------------------|-----|
| 4.3 | TABLE: ESSENTIAL PERFORMANCE | N/A |
|-----|------------------------------|-----|

| | | |
|-----|---|-----|
| 4.3 | RM RESULTS TABLE: Essential Performance | N/A |
|-----|---|-----|

| | | |
|-----|---|-----|
| 4.5 | RM RESULTS TABLE: Equivalent Safety for ME Equipment of ME System | N/A |
|-----|---|-----|

| | | |
|-----|---|-----|
| 4.6 | RM RESULTS TABLE: ME Equipment or system parts contacting the patient | N/A |
|-----|---|-----|

| | | |
|-----|---|-----|
| 4.7 | RM RESULTS TABLE: Single Fault Condition for ME Equipment | N/A |
|-----|---|-----|

| | | |
|-----|--|-----|
| 4.8 | RM RESULTS TABLE: Components of ME Equipment | N/A |
|-----|--|-----|

| | | |
|-----|---|-----|
| 4.9 | RM RESULTS TABLE: Use of components with high-integrity characteristics | N/A |
|-----|---|-----|

| 4.11 | TABLE: Power Input | | | | | P |
|--------------------------------|--------------------|-------------|----------------|-------------|-----------------|----------------------------|
| Operating Conditions / Ratings | | Voltage (V) | Frequency (Hz) | Current (A) | Power (W or VA) | Power factor (cos ϕ) |
| Model: GT*96225*P22512***_* | | | | | | |
| Normal condition | | 85 | 50 | 2.9979 | 255.6 | <0.9 |
| Normal condition | | 90 | 50 | 2.8351 | 254.2 | <0.9 |
| Normal condition | | 90 | 60 | 2.8354 | 254.4 | <0.9 |
| Normal condition | | 100 | 50 | 2.5139 | 251.8 | <0.9 |
| Normal condition | | 100 | 60 | 2.5142 | 251.9 | <0.9 |
| Normal condition | | 240 | 50 | 1.0700 | 244.1 | <0.9 |
| Normal condition | | 240 | 60 | 1.0704 | 244.3 | <0.9 |
| Normal condition | | 264 | 50 | 0.9764 | 243.7 | <0.9 |
| Normal condition | | 264 | 60 | 0.9768 | 243.8 | <0.9 |
| Model: GT*96225*P14012***_* | | | | | | |
| Normal condition | | 85 | 50 | 1.7822 | 156.23 | <0.9 |
| Normal condition | | 90 | 50 | 1.7340 | 155.66 | <0.9 |
| Normal condition | | 90 | 60 | 1.7363 | 155.72 | <0.9 |
| Normal condition | | 100 | 50 | 1.5732 | 155.27 | <0.9 |
| Normal condition | | 100 | 60 | 1.5745 | 155.33 | <0.9 |
| Normal condition | | 240 | 50 | 0.6916 | 152.16 | <0.9 |

| IEC 60601-1 | | | | | |
|-------------|--------------------|--|-----------------|--|---------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |

| | | | | | |
|------------------------------------|-----|----|--------|--------|------|
| Normal condition | 240 | 60 | 0.6941 | 152.42 | <0.9 |
| Normal condition | 264 | 50 | 0.6317 | 151.46 | <0.9 |
| Normal condition | 264 | 60 | 0.6325 | 151.65 | <0.9 |
| Model: GT*96225*P22524***_* | | | | | |
| Normal condition | 85 | 50 | 2.9028 | 247.30 | <0.9 |
| Normal condition | 90 | 50 | 2.7318 | 245.50 | <0.9 |
| Normal condition | 90 | 60 | 2.7319 | 245.54 | <0.9 |
| Normal condition | 100 | 50 | 2.4408 | 243.50 | <0.9 |
| Normal condition | 100 | 60 | 2.4410 | 243.53 | <0.9 |
| Normal condition | 240 | 50 | 1.0347 | 236.28 | <0.9 |
| Normal condition | 240 | 60 | 1.0349 | 236.31 | <0.9 |
| Normal condition | 264 | 50 | 0.9446 | 253.47 | <0.9 |
| Normal condition | 264 | 60 | 0.9448 | 253.49 | <0.9 |
| Model: GT*96225*P14024***_* | | | | | |
| Normal condition | 85 | 50 | 1.7857 | 157.32 | <0.9 |
| Normal condition | 90 | 50 | 1.7234 | 155.12 | <0.9 |
| Normal condition | 90 | 60 | 1.7236 | 155.20 | <0.9 |
| Normal condition | 100 | 50 | 1.5617 | 154.66 | <0.9 |
| Normal condition | 100 | 60 | 1.5620 | 154.68 | <0.9 |
| Normal condition | 240 | 50 | 0.6848 | 151.45 | <0.9 |
| Normal condition | 240 | 60 | 0.6850 | 151.47 | <0.9 |
| Normal condition | 264 | 50 | 0.6278 | 151.15 | <0.9 |
| Normal condition | 264 | 60 | 0.6281 | 151.32 | <0.9 |
| Model: GT*96225*P22538***_* | | | | | |
| Normal condition | 85 | 50 | 2.9450 | 251.0 | <0.9 |
| Normal condition | 90 | 50 | 2.8136 | 252.9 | <0.9 |
| Normal condition | 90 | 60 | 2.8138 | 253.1 | <0.9 |
| Normal condition | 100 | 50 | 2.4952 | 250.7 | <0.9 |
| Normal condition | 100 | 60 | 2.4955 | 250.9 | <0.9 |
| Normal condition | 240 | 50 | 1.0588 | 242.2 | <0.9 |
| Normal condition | 240 | 60 | 1.0590 | 242.4 | <0.9 |
| Normal condition | 264 | 50 | 0.9718 | 242.5 | <0.9 |
| Normal condition | 264 | 60 | 0.9721 | 242.7 | <0.9 |
| Model: GT*96225*P14038***_* | | | | | |
| Normal condition | 85 | 50 | 1.7743 | 155.24 | <0.9 |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | | | |
|-----------------------------|-----|----|--------|--------|------|
| Normal condition | 90 | 50 | 1.7088 | 153.41 | <0.9 |
| Normal condition | 90 | 60 | 1.7112 | 153.55 | <0.9 |
| Normal condition | 100 | 50 | 1.5464 | 152.70 | <0.9 |
| Normal condition | 100 | 60 | 1.5479 | 152.77 | <0.9 |
| Normal condition | 240 | 50 | 0.6794 | 149.43 | <0.9 |
| Normal condition | 240 | 60 | 0.6806 | 149.65 | <0.9 |
| Normal condition | 264 | 50 | 0.6215 | 149.33 | <0.9 |
| Normal condition | 264 | 60 | 0.6231 | 149.58 | <0.9 |
| Model: GT*96225*P22554***-* | | | | | |
| Normal condition | 85 | 50 | 2.9159 | 248.8 | <0.9 |
| Normal condition | 90 | 50 | 2.7493 | 247.2 | <0.9 |
| Normal condition | 90 | 60 | 2.7498 | 247.3 | <0.9 |
| Normal condition | 100 | 50 | 2.4568 | 244.9 | <0.9 |
| Normal condition | 100 | 60 | 2.4571 | 245.1 | <0.9 |
| Normal condition | 240 | 50 | 1.0359 | 236.7 | <0.9 |
| Normal condition | 240 | 60 | 1.0360 | 236.8 | <0.9 |
| Normal condition | 264 | 50 | 0.9475 | 236.3 | <0.9 |
| Normal condition | 264 | 60 | 0.9476 | 236.4 | <0.9 |
| Model: GT*96225*P14054***-* | | | | | |
| Normal condition | 85 | 50 | 1.7033 | 153.11 | <0.9 |
| Normal condition | 90 | 50 | 1.6915 | 151.80 | <0.9 |
| Normal condition | 90 | 60 | 1.6920 | 151.95 | <0.9 |
| Normal condition | 100 | 50 | 1.5199 | 150.82 | <0.9 |
| Normal condition | 100 | 60 | 1.5211 | 151.07 | <0.9 |
| Normal condition | 240 | 50 | 0.6737 | 148.24 | <0.9 |
| Normal condition | 240 | 60 | 0.6740 | 148.87 | <0.9 |
| Normal condition | 264 | 50 | 0.6192 | 148.79 | <0.9 |
| Normal condition | 264 | 60 | 0.6195 | 148.02 | <0.9 |
| Supplementary Information: | | | | | |

| | | |
|--------|--|-----|
| 5.1 | RM RESULTS TABLE: Type Tests | N/A |
| 5.4 a) | RM RESULTS TABLE: Other Conditions | N/A |
| 5.7 | RM RESULTS TABLE: Humidity preconditioning treatment | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|--|--|------------------------------|--------------|
| 5.9.2 | TABLE: Determination of ACCESSIBLE parts | | P |
| Location | | Determination method (NOTE1) | Comments |
| Enclosure for potted models | | Test finger, test hook | Can't insert |
| Supplementary information: | | | |
| 1) NOTE: The determination methods are: visual; rigid test finger; jointed test finger; test hook. | | | |

| | | |
|----------------|---|------------|
| 5.9.2.3 | RM RESULTS TABLE: Actuating mechanisms | N/A |
|----------------|---|------------|

| | | | |
|---|------------------------------|--------------------------|----------|
| 7.1.2 | TABLE: Legibility of Marking | | P |
| Markings tested | | Ambient Illuminance (lx) | Remarks |
| Outside Markings (Clause 7.2) : | | 100-1500 lx | Readable |
| Inside Markings (Clause 7.3) : | | - | N/A |
| Controls & Instruments (Clause 7.4) : | | - | N/A |
| Safety Signs (Clause 7.5)..... : | | - | N/A |
| Symbols (Clause 7.6) : | | - | N/A |
| Supplementary information: | | | |
| Observer, with a visual acuity of 0 on the log Minimum Angle of Resolution (log MAR) scale or 6/6 (20/20) and is able to read N6 of the Jaeger test card in normal room lighting condition (~500lx), reads marking at ambient illuminance least favourable level in the range of 100 lx to 1,500 lx. The ME EQUIPMENT or its part was positioned so that the viewpoint was the intended position of the OPERATOR or if not defined at any point within the base of a cone subtended by an angle of 30° to the axis normal to the centre of the plane of the marking and at a distance of 1 m. | | | |

| | | | |
|--|-----------------------------------|------|---------|
| 7.1.3 | TABLE: Durability of marking test | | P |
| Characteristics of the Marking Label tested: | | | Remarks |
| Material of Marking Label | See Table 8.10 | Pass | |
| Ink/other printing material or process | See Table 8.10 | Pass | |
| Material (composition) of Warning Label | - | N/A | |
| Ink/other printing material or process | - | N/A | |
| Other | - | N/A | |
| Supplementary information: | | | |
| Marking rubbed by hand, first for 15 s with a cloth rag soaked with distilled water, then for 15 s with a cloth rag soaked with methylated spirit, and then for 15 s with a cloth rag soaked with isopropyl alcohol. | | | |

| | | |
|--------------|---|------------|
| 7.2.2 | RM RESULTS TABLE: Identification | N/A |
|--------------|---|------------|

| | | |
|--------------|--|------------|
| 7.2.5 | RM RESULTS TABLE: ME EQUIPMENT powered from other equipment | N/A |
|--------------|--|------------|

| | | |
|---------------|---|------------|
| 7.2.13 | RM RESULTS TABLE: Physiological effects (safety signs and warning) | N/A |
|---------------|---|------------|

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.2.17 | RM RESULTS TABLE: Protective packaging | | N/A |
| 7.3.3 | RM RESULTS TABLE: Batteries | | N/A |
| 7.3.7 | RM RESULTS TABLE: Supply terminals | | N/A |
| 7.4.2 | RM RESULTS TABLE: Control devices | | N/A |
| 7.5 | RM RESULTS TABLE: Safety signs | | N/A |
| 7.9.1 | RM RESULTS TABLE: General accompanying documents (See Table C.4) | | N/A |
| 7.9.2.4 | RM RESULTS TABLE: Electrical power source | | N/A |
| 7.9.3.2 | RM RESULTS TABLE: Replacement of fuses, power supply cords, other parts | | N/A |
| 8.1 b(1) | RM RESULTS TABLE: Fundamental rule of protection against electric shock - interruption of any one power-carrying conductor | | N/A |
| 8.1 b(2) | RM RESULTS TABLE: Fundamental rule of protection against electric shock - unintended movement of a component | | N/A |
| 8.1 b(3) | RM RESULTS TABLE: Fundamental rule of protection against electric shock - accidental detachment of conductors and connectors | | N/A |
| 8.2.2 | RM RESULTS TABLE: Connection to an external d.c. power sources | | N/A |
| 8.3 d | RM RESULTS TABLE: Requirements of Type BF or CF Applied Parts | | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 8.4.2/8.5.4 | TABLE: TABLE: Working Voltage / Power Measurement | | | | | P |
|---|---|---------------|---------------------------------------|---------------|---------------|----------------|
| Test supply voltage/frequency (V/Hz) ¹⁾ : | | | | | 264V/50Hz | |
| Location From/To | Measured values | | | | | Remarks |
| | Vrms | Vpk or Vdc | Peak-to- peak ripple ²⁾ | Power W/VA | Energy (J) | |
| Transformer, primary to secondary | Max. 352Vrms | -- | -- | -- | -- | For all models |
| Optocoupler primary to secondary | Max. 240Vrms | -- | -- | -- | -- | For all models |
| Y capacitor primary to secondary | Max. 240Vrms | -- | -- | -- | -- | For all models |
| Secondary output connector | -- | <60Vdc | <10% | -- | -- | For all models |
| Supplementary Information: | | | | | | |
| 1)The input supply voltage to the ME EQUIPMENT was the RATED voltage or the voltage within the RATED voltage range which results in the highest measured value. See clause 8.5.4. | | | | | | |
| 2). If the d.c peak-to-peak ripple >10%, waveform considered as a.c. See clause 8.4.2.2 | | | | | | |

| | | |
|---------|---|------------|
| 8.4.2 c | RM RESULTS TABLE: Accessible parts including applied parts | N/A |
|---------|---|------------|

| | | | | | | | | | | |
|--------------------------------------|---|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| 8.4.3 | TABLE: ME EQUIPMENT for connection to a power source by a plug - measurement of voltage or calculation of stored charge 1 s after disconnection of plug from mains supply | | | | | | | | | P |
| Maximum allowable voltage (V): | | | | | | | | | 60 | |
| Voltage measured (V) | | | | | | | | | | |
| Voltage Measured Between: | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| Connector pins 1 and 2 | | | | | | | | | | |
| 54Vdc/4.16A model | 33 | 32 | 37 | 36 | 36 | 38 | 34 | 39 | 33 | 35 |
| 38Vdc/5.92A model | 35 | 33 | 36 | 36 | 34 | 32 | 37 | 35 | 34 | 33 |
| 24Vdc/9.37A model | 35 | 34 | 32 | 33 | 34 | 36 | 35 | 33 | 32 | 34 |
| 12Vdc/18.75A model | 34 | 34 | 37 | 36 | 38 | 34 | 33 | 32 | 34 | 33 |
| Plug pin 1 and plug earth pin | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ |
| Plug pin 2 and plug earth pin | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ | -- ¹ |
| Plug pin 1 and enclosure | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | | | | | | | | |
|--|----|----|----|----|----|----|----|----|----|----|
| Plug pin 2 and enclosure | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- |
| Maximum allowable stored charge when measured voltage exceeded 60 v (μc) : | | | | | | | | 45 | | |
| Calculated stored charge (μc) | | | | | | | | | | |
| Voltage Measured Between: | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| Plug pins 1 and 2 | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- |
| Plug pin 1 and plug earth pin | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- |
| Plug pin 2 and plug earth pin | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- |
| Plug pin 1 and enclosure | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- |
| Plug pin 2 and enclosure | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- |
| Supplementary information: | | | | | | | | | | |
| 1) Only Class I model series are in consideration. There are no storage capacitors between either of supply pins and earth pin. So the measurement is not necessary. | | | | | | | | | | |

| | | | | |
|---|--|-------------------------------|-------------------------------|---------|
| 8.4.4 | TABLE: Internal capacitive circuits – measurement of residual voltage or calculation of the stored charge in capacitive circuits (i.e., accessible capacitors or circuit parts) after de-energizing ME EQUIPMENT | | | N/A |
| Maximum allowable residual voltage (V) : | | | | 60 V |
| Maximum allowable stored charge when residual voltage exceeded 60 V..... : | | | | 45 μC |
| Description of the capacitive circuit (i.e., accessible capacitor or circuit parts) | | Measured residual voltage (V) | Calculated stored charge (μC) | Remarks |
| Supplementary information: | | | | |

| | | |
|---------|--|-----|
| 8.5.2.2 | RM RESULTS TABLE: Type B applied parts | N/A |
|---------|--|-----|

| | | |
|---------|---------------------------------|-----|
| 8.5.2.3 | RM RESULTS TABLE: PATIENT Leads | N/A |
|---------|---------------------------------|-----|

| | | | | | | |
|---------------------------------|--|--------------------------------|-----------------------|---|---------|-----|
| 8.5.5.1a | TABLE: defibrillation-proof applied parts – measurement of hazardous electrical energies | | | | | N/A |
| Test Condition: Figs. 9 & 10 | Measurement made on accessible part | Applied part with test voltage | Test voltage polarity | Measured voltage between Y1 and Y2 (mV) | Remarks | |
| Supplementary information: | | | | | | |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | | | |
|--------------------------------|---|----------------------------------|----------------------------|---------|-----|
| 8.5.5.1b | TABLE: defibrillation-proof applied parts – verification of recovery time | | | | N/A |
| Applied part with test voltage | Test voltage polarity | Recovery time from documents (s) | Measured recovery time (s) | Remarks | |
| Supplementary information: | | | | | |

| | | | | |
|---|---|-------------------------|-------------------------|--------------------------|
| 8.5.5.2 | TABLE: DEFIBRILLATION-PROOF APPLIED PARTS or PATIENT CONNECTIONS of DEFIBRILLATION-PROOF APPLIED PARTS - Energy reduction test –measurement of Energy delivered to a 100 Ω load | | | N/A |
| Test Voltage applied to | | Measured Energy E1 (mJ) | Measured Energy E2 (mJ) | Energy E1 as % of E2 (%) |
| PATIENT CONNECTION 1 or APPLIED PART with PATIENT CONNECTIONS 2, 3, and 4 of the same APPLIED PART connected to earth | | | | |
| PATIENT CONNECTION 2 or APPLIED PART with PATIENT CONNECTIONS 1, 3, and 4 of the same APPLIED PART connected to earth | | | | |
| PATIENT CONNECTION 3 or APPLIED PART with PATIENT CONNECTIONS 1, 2, and 4 of the same APPLIED PART connected to earth | | | | |
| PATIENT CONNECTION 4 or APPLIED PART with PATIENT CONNECTIONS 1, 2, and 3 of the same APPLIED PART connected to earth | | | | |
| Supplementary information: For compliance: E1 must at least 90% of E2 E1= Measured energy delivered to 100 Ω with ME Equipment connected; E2= Measured energy delivered to 100 Ω without ME equipment connected. | | | | |

| | | |
|--------------|--|------------|
| 8.6.3 | RM RESULTS TABLE: Protective earthing of moving parts | N/A |
|--------------|--|------------|

| 8.6.4 | TABLE: Impedance and current-carrying capability of PROTECTIVE EARTH CONNECTIONS | | | | P |
|--|---|---|-----------------------------------|----------------------------------|----------|
| Type of ME EQUIPMENT & impedance measured between parts | Test current (A) /Duration (s) | Voltage drop measured between parts (V) | Maximum calculated impedance (mΩ) | Maximum allowable impedance (mΩ) | |
| PERMANENTLY INSTALLED ME EQUIPMENT, impedance between PROTECTIVE EARTH TERMINAL and a PROTECTIVELY EARTHED part | -- | -- | -- | 100 | |
| ME EQUIPMENT with an APPLIANCE INLET, impedance between earth pin in the APPLIANCE INLET and a PROTECTIVELY EARTHED part | 40A/ 120s | 0.4 | 16 | 100 | |
| ME EQUIPMENT with a non-DETACHABLE | -- | -- | -- | 200 | |

| IEC 60601-1 | | | | |
|--|--|--|-----------------|---------|
| Clause | Requirement + Test | | Result - Remark | Verdict |
| 8.6.4 | TABLE: Impedance and current-carrying capability of PROTECTIVE EARTH CONNECTIONS | | | P |
| POWER SUPPLY CORD, impedance between the protective earth pin in the MAINS PLUG and a PROTECTIVELY EARTHED part | | | | |
| Supplementary information: | | | | |
| Only Class I model series are in consideration. The result under the worst condition was recorded in the report. | | | | |

| 8.7 | TABLE: leakage current | | | | P |
|--|-------------------------------|--------------------|-----------------------|--------------------------|---|
| Type of leakage current and test condition (including single faults) | | Supply voltage (V) | Supply frequency (Hz) | Measured max. value (μA) | Remarks |
| Fig. 13 - Earth Leakage (ER) | | — | — | — | Maximum allowed values: 5 mA NC; 10 mA SFC |
| NC | | 264 | 60 | 10.5 | For Class I potted model |
| SFC, interrupt one supply conductor | | 264 | 60 | 12.1 | |
| SFC, one Y1 capacitor is short circuited. | | 264 | 60 | 19.7 | |
| Fig. 14 - Touch Current (TC) | | — | — | — | Maximum allowed values: 100 μA NC; 500 μA SFC |
| NC | | 264 | 60 | 9.2 | For Class I potted model, from L/N to accessible enclosure |
| SFC, interrupt grounding conductor | | 264 | 60 | 9.4 | |
| SFC, interrupt one supply conductor | | 264 | 60 | 10.4 | |
| SFC, one Y1 capacitor is short circuited. | | 264 | 60 | 9.4 | |
| NC | | ___Note 4 | ___Note 4 | ___Note 4 | For Class I potted model, from L/N to accessible output terminal |
| SFC, interrupt grounding conductor | | ___Note 4 | ___Note 4 | ___Note 4 | |
| SFC, interrupt one supply conductor | | ___Note 4 | ___Note 4 | ___Note 4 | |
| SFC, one Y1 capacitor is short circuited. | | ___Note 4 | ___Note 4 | ___Note 4 | |
| NC | | 264 | 60 | 8.4 | For Class II potted model, from L/N to accessible enclosure |
| SFC, interrupt one supply conductor | | 264 | 60 | 9.4 | |
| SFC, one Y1 capacitor is short circuited. | | 264 | 60 | 10.5 | |
| NC | | 264 | 60 | 53.2 | For Class II potted model, from L/N to accessible output terminal |
| SFC, interrupt one supply conductor | | 264 | 60 | 56.8 | |
| SFC, one Y1 capacitor is short circuited. | | 264 | 60 | 69.7 | |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

Supplementary information:

Note 1: For EARTH LEAKAGE CURRENT see 8.7.3 d) and 8.7.4.5;

Note 2: For TOUCH CURRENT see 8.7.3 c) and 8.7.4.6;

Note 3: In addition to conditions indicated in the Table, tests conducted at operating temperature and after humidity preconditioning of 5.7, EQUIPMENT energized in stand-by condition and fully operating, max rated supply frequency, at 110 % of the max RATED MAINS VOLTAGE, and after relevant tests of Clause 11.6 (i.e., overflow, spillage, leakage, ingress of water and particulate matter, cleaning & disinfection, & sterilization).

Note 4: Secondary output terminal(-) is grounded, no voltage to earth or to other accessible parts exceeds 42,4 V peak a.c. or 60 V d.c. No energy exceeds 240 VA for longer than 60 s or no stored energy exceeds 20J.

ER - Earth leakage current

TC – Touch current

MD - Measuring device

NC - Normal condition

SFC - Single fault condition

A - After humidity conditioning

B - Before humidity conditioning

1 - Switch closed or set to normal polarity

0 - Switch open or set to reversed polarity

| 8.8.3 | TABLE: Dielectric strength test of solid insulating materials with safety function – MEANS OF OPERATOR PROTECTION (MOOP) / MEANS OF PATIENT PROTECTION (MOPP) | | | | P |
|---|---|---|------------------------------------|---|---|
| Insulation under test (area from insulation diagram) | Insulation Type (1 or 2 MOOP/MOPP) | Reference Voltage | | A.C. test voltages in V r.m.s. ¹ | Dielectric breakdown after 1 minute Yes/No ² |
| | | PEAK WORKING VOLTAGE (U) V _{peak} | PEAK WORKING VOLTAGE (U) V d.c. | | |
| A (Opposite polarity of mains part) (Fuse opened) | 1MOOP | 340 | -- | 1500 | No breakdown |
| B (Line/Neutral to PE terminal trace) | 1MOOP | 340 | -- | 1500 | No breakdown |
| B ¹ (Mains parts to PE terminal) | 1 MOPP | 340 | -- | 1500 | No breakdown |
| C (Mains parts to secondary circuit) (On optocoupler) | 2 MOPP | 340 | -- | 4000 | No breakdown |
| D (Mains part to secondary circuits) (Transformer) | 2 MOPP | 340 | -- | 4000 | No breakdown |
| D ¹ (Core to secondary circuits) (Transformer) | 2 MOPP | 630 | -- | 4800 | No breakdown |
| E Mains parts to secondary circuits (PCB trace) | 2 MOPP | 340 | -- | 4000 | No breakdown |
| F (Mains parts to secondary pin-out) (On Y capacitor x 2) | 2 MOPP | 340 | -- | 4000 | No breakdown |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

Supplementary information:

¹ Alternatively, per the Table (i.e., ___dc), a d.c. test voltage equal to the peak value of the a.c. test voltage used.

² A) Immediately after humidity treatment of 5.7, ME EQUIPMENT de-energized, B) after required sterilization PROCEDURE, ME EQUIPMENT de-energized, C) after reaching steady state operating temperature as during heating test of 11.1.1, and D) after relevant tests of 11.6 (i.e., overflow, spillage, leakage, ingress of water, cleaning, disinfection, and sterilization).

| 8.8.4.1 | TABLE: Resistance to heat - Ball pressure test of thermoplastic parts | | P |
|---|--|-----------------------|--------------------------|
| | Allowed impression diameter (mm) | ≤ 2 mm | — |
| | Force (N) | 20 | — |
| Part/material | | Test temperature (°C) | Impression diameter (mm) |
| Enclosure | | | |
| SE1X (125°C ball pressure test is passed by UL) | | -- | -- |
| C2950 | | 75 | 1.1 |
| CX7211 | | 75 | 1.1 |
| LN-1250P | | 75 | 1.0 |
| PA-765A | | 75 | 1.1 |
| EXCY0098 | | 75 | 1.0 |
| LN-1250G | | 75 | 1.0 |
| PC-540 | | 75 | 1.1 |
| Bobbin of Mains transformer | | | |
| T375J | | 125 | 1.3 |
| T375H | | 125 | 1.3 |
| PM-9820 | | 125 | 1.3 |
| CP-J-8800 | | 125 | 1.4 |
| Supplementary information: | | | |

| | | |
|----------------|---|------------|
| 8.8.4.1 | RM RESULTS TABLE: Mechanical strength and resistance to heat | N/A |
|----------------|---|------------|

| | | |
|--------------|---|------------|
| 8.9.2 | TABLE: Short circuiting of each single one of the CREEPAGE DISTANCES and AIR CLEARANCES for insulation in the MAINS PART between parts of opposite polarity in lieu of complying with the required measurements in 8.9.4 | N/A |
|--------------|---|------------|

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| Specific areas of circuits short-circuited and test conditions | Test in lieu of CREEPAGE DISTANCE OR AIR CLEARANCE ¹⁾ | HAZARDOUS SITUATION observed (i.e., fire hazard, shock hazard, explosion, discharge of parts, etc.)? Yes/No | Remarks |
|--|--|---|---------|
|--|--|---|---------|

Supplementary information:

¹⁾Note: AC - AIR CLEARANCE CD - CREEPAGE DISTANCE

| 8.9.3.2 | Table: Thermal cycling tests on one sample of insulating compound forming solid insulation between conductive parts | | | N/A |
|-----------|--|-------------------------|---|---|
| Part Test | 8.9.3.4 - Test duration and temperature for 10 cycles after which the sample was subjected to Humidity Preconditioning per Cl. 5.7 | Dielectric test voltage | Dielectric strength test after humidity preconditioning per cl. 5.7 except for 48 h only, Breakdown: Yes/No | Crack or voids in the insulating compound: Yes/No |
| | 68 h at $T1 \pm 2\text{ }^{\circ}\text{C} = \text{ }^{\circ}\text{C}$ ¹⁾ | | | |
| | 1 h at $25\text{ }^{\circ}\text{C} \pm 2\text{ }^{\circ}\text{C}$ | | | |
| | 2 h at $0\text{ }^{\circ}\text{C} \pm 2\text{ }^{\circ}\text{C}$ | | | |
| | 1 or more h at $25\text{ }^{\circ}\text{C} \pm 2\text{ }^{\circ}\text{C}$ | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Supplementary information:

¹⁾ T1 = 10 °C above the maximum temperature of relevant part determined per 11.1.1, or 85 °C, the higher of the two. 10 °C not added to T1 when temperature measured by an embedded thermocouple. Used gradual transition from one temperature to another.

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 8.9.3.3 | Table: Thermal cycling tests on one sample of cemented joint with other insulating parts (see 8.9.3.3) | | | N/A |
|----------------|---|---|-------------------------|--|
| Part tested | Sample | Each test duration and temperature | Dielectric test voltage | Dielectric strength test Breakdown: Yes/No |
| | 1 | 10 Cycles conducted of the following: | | |
| | | 1 - 68 h at $T1 \pm 2\text{ }^{\circ}\text{C} = \text{ }^{\circ}\text{C}^1$ | | |
| | | 2 - 1 h at $25\text{ }^{\circ}\text{C} \pm 2\text{ }^{\circ}\text{C}$ | | |
| | | 3 - 2 h at $0\text{ }^{\circ}\text{C} \pm 2\text{ }^{\circ}\text{C}$ | | |
| | | 4 - 1 or more h at $25\text{ }^{\circ}\text{C} \pm 2\text{ }^{\circ}\text{C}$ | | |
| | 2 | Humidity Conditioning per 5.7 | | |
| | 3 | Humidity Conditioning per 5.7 | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Supplementary information:

¹⁾ T1 = 10 °C above the maximum temperature of relevant part determined per 11.1.1, or 85 °C, the higher of the two. 10 °C not added to T1 when temperature measured by an embedded thermocouple. Used gradual transition from one temperature to another.

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 8.10 | TABLE: List of critical components | | | | P |
|---|------------------------------------|-----------------|--|--|-------------------------------------|
| Object / part No. | Manufacturer/ trademark | Type / model | Technical data | Standard | Mark(s) of conformity ¹ |
| Plastic cover (For model GTM962253P *****_*) | SABIC INNOVATIVE PLASTICS B V | SE1X, SE1 | PPE+PS, Min. V-1, Min. thickness: 2.0mm, 105°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E45329 |
| Alt. use | SABIC INNOVATIVE PLASTICS B V | SE100 | PPE+PS, Min. V-1, Min. thickness: 2.0mm, 95°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E45329 |
| Alt. use | SABIC INNOVATIVE PLASTICS B V | C2950 | PC/ABS, Min. V-0, Min. thickness: 2.0mm, 105°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E45329 |
| Alt. use | SABIC INNOVATIVE PLASTICS B V | CX7211 EXCY0098 | PC/ABS, Min. V-0, Min. thickness: 2.0mm, 90°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E45329 |
| Alt. use | SABIC INNOVATIVE PLASTICS B V | 945 940 | PC, Min. V-0, Min. thickness: 2.0mm, 120°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E45329 |
| Alt. use | SABIC INNOVATIVE PLASTICS B V | HF500R | PC, V-0, Min. thickness: 2.0mm, 125°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E45329 |
| Alt. use | SABIC JAPAN L L C | SE1X, SE1 | PPE+PS, Min. V-1, Min. thickness: 2.0mm, 105°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E207780 |
| Alt. use | SABIC JAPAN L L C | C2950 | PC/ABS, Min. V-0, Min. thickness: 2.0mm, 105°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E207780 |
| Alt. use | SABIC JAPAN L L C | CX7211 | PC/ABS, Min. V-0, Min. thickness: 2.0mm, 90°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E207780 |
| Alt. use | SABIC JAPAN L L C | 945 940 | PC, Min. V-0, Min. thickness: 2.0mm, 120°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E207780 |
| Alt. use | SABIC JAPAN L L C | HF500R | PC, V-0, Min. thickness: 2.0mm, 125°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E207780 |

| IEC 60601-1 | | | | | |
|--------------------------------------|--|----------------------|---|---|--|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| Alt. use | COVESTRO DEUTSCHLAND AG [PC RESINS | 6485+ | PC, Min. V-0, Min. thickness: 2.0mm, 115°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E41613 |
| Alt. use | TEIJIN CHEMICALS LTD | LN-1250P LN-1250G | PC, Min. V-0, Min. thickness: 2.0mm, 115°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E50075 |
| Alt. use | CHI MEI CORPORATION | PA-765A | ABS, Min. V-0, Min. thickness: 2.0mm, 85°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E56070 |
| Alt. use | CHI MEI CORPORATION | PC-540 | PC/ABS, Min. V-0, Min. thickness: 2.0mm, 70°C | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E56070 |
| PCB | JIANGXI ZHONG XIN HUA ELECTRONICS INDUSTRY CO LTD | ZXH-2 | Min.1.6 mm thickness, min. V-0, 130°C | IEC 60601-1 UL94 UL 796 | Tested with appliance UL E331298 |
| Alt. use | SHUANG MING INDUSTRY CO LTD | T005V0 T015V0 | Min.1.6 mm thickness, min. V-0, 130°C | IEC 60601-1 UL 94 UL 796 | Tested within appliance UL E78017 |
| Alt. use | SHANGHAI H- FAST ELECTRONICS CO LTD | 211001 | Min.1.6 mm thickness, min. V-0, 130°C | IEC 60601-1 UL 94 UL 796 | Tested within appliance UL E337862 |
| Alt. use | GUANGDE BOYA XINXING ELECTRONIC TECHNOLOGY CO LTD | BY-1 | Min. 1.6 mm thickness, min. V-0, 130°C | IEC 60601-1 UL 796 | Tested with appliance UL E475783 |
| Alt. use | SHENZHEN GOLDEN BOARD CIRCUIT | JYH-2 | Min. 1.6 mm thickness, min. V-0, 130°C | IEC 60601-1 UL 796 | Tested with appliance UL E489124 |
| Alt. use | ZHEJIANG WANZHENG ELECTRONICS SCIENCE & TECHNOLOGY CO LTD | JWZ-2 | Min. 1.6 mm thickness, min. V-0, 130°C | IEC 60601-1 UL 796 | Tested with appliance UL E302598 |
| Fuse (F1, F2) (F2 is optional) | Conquer Electronics Co., Ltd. | UDA series | T4A, AC250V, | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40008022 UL E82636 |

| IEC 60601-1 | | | | | |
|-------------|--|---------------|-----------------|---|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| Alt. use | Suzhou Walter Electronic Co. Ltd. | TSC Series | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40016670 UL E56092 |
| Alt. use | Littelfuse Inc | 215-Serie(s) | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40013521 UL E10480 |
| Alt. use | Conquer Electronics Co., Ltd. | MST | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40017118 UL E82636 |
| Alt. use | Suzhou Walter Electronic Co. Ltd. | 2010 Serie(s) | T4A, AC250V | IEC 60127-1 IEC 60127-3 | VDE 40018781 |
| Alt. use | Bel Fuse Ltd. | RST | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40011144 UL E20624 |
| Alt. use | Cooper Bussmann LLC | SS-5 | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40015513 UL E19180 |
| Alt. use | Shenzhen Lanson Electronics Co. Ltd. | SMT | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40012592 UL E221465 |
| Alt. use | Dongguan Better Electronics Technology Co., Ltd. | 932 | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40033369 UL E300003 |
| Alt. use | Hollyland Company Limited | 5ET | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40015669 UL E156471 |
| Alt. use | Sunny East Enterprise Co. Ltd. | CFD | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40030246 UL E133774 |

| IEC 60601-1 | | | | | |
|---|--|--------------------------------------|------------------|---|---------------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| Alt. use | Conquer Electronics Co., Ltd | MET | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40017157 UL E82636 |
| Alt. use | Zhongshan Lanbao Electrical Appliances Co., Ltd. | RTI-10 | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40017009 UL E213695 |
| Alt. use | Suzhou Walter Electronic Co. Ltd. | ICP-Series | T4A, AC250V | IEC 60127-1 IEC 60127-3 UL 248-1 UL 248-14 | VDE 40012824 UL E220181 |
| Alt. use | Suzhou Walter Electronic Co. Ltd. | 2020 | T4A, AC250V | IEC 60127-1 IEC 60127-3 | VDE 40042706 |
| Alt. use | Conquer Electronics Co., Ltd | MMT | T4A, AC250V | IEC 60127-1 IEC 60127-3 | TUV RH R50304067 |
| Alt. use | Bel Fuse Ltd. | RSTA | T4A, AC250V | IEC 60127-1 IEC 60127-3 | VDE 40039089 |
| Alt. use | Littelfuse Inc. | TE5 400 | T4A, AC250V | IEC 60127-1 IEC 60127-3 | VDE 40026355 |
| Heat shrinkable tubing used on F1 and F2 (Optional) | SHENZHEN WOER HEAT-SHRINKABLE MATERIAL CO LTD | RSFR RSFR-H RSFR-HPF | 600V, 125°C | IEC/EN 60601-1 UL 224 | Tested within appliance UL E203950 |
| Alt. use | QIFURUI ELECTRONICS CO | QFR-h | 600V, 125°C | IEC/EN 60601-1 UL 224 | Tested within appliance UL E225897 |
| Alt. use | DONGGUAN SALIPT CO LTD | SALIPT S-901-300 SALIPT S-901-600 | Min. 300V, 125°C | IEC/EN 60601-1 UL 224 | Tested within appliance UL E209436 |
| Alt. use | GUANGZHOU KAIHENG ENTERPRISE GROUP | K-2 (+) K-2 (CB) | Min. 300V, 125°C | IEC/EN 60601-1 UL 224 | Tested within appliance UL E214175 |
| Alt. use | CHANGYUAN ELECTRONICS (SHENZHEN) CO LTD | CB-HFT | Min. 300V, 125°C | IEC/EN 60601-1 UL 224 | Tested within appliance UL E180908 |

| IEC 60601-1 | | | | | |
|------------------------------|---|--------------|---|---|----------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| X capacitor (CX1) (Optional) | Shantou High-New Technology Dev. Zone Songtian Enterprise Co., Ltd. | MPX | Max 0.68μF, Min.250V,110°C X2 | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40034679 UL E208107 |
| Alt. use | Tenta Electric Industrial Co. Ltd. | MEX | Max. 0.68μF, Min. 250V, X2 40/100/21/B | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 119119 UL E222911 |
| Alt. use | Joey Electronics (Dong Guan) Co., Ltd. | MPX | Max. 0.68μF, Min. 275V, X2 40/105/21/B | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40032481 UL E216807 |
| Alt. use | Ultra Tech Xiphi Enterprise Co. Ltd. | HQX | Max. 0.68μF, Min. 250V, X2 40/110/56/B | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40015608 UL E183780 |
| Alt. use | Yuan Yu Electronics Co. Ltd. | MPX | Max. 0.68μF, Min. 250V, X2 40/100/21/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40032392 UL E200119 |
| Alt. use | Sinhua Electronics (Huzhou) Co., Ltd. | MPX | Max. 0.68μF, Min. 250V, X2 40/100/21/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40014686 UL E237560 |
| Alt. use | Cheng Tung Industrial Co., Ltd. | CTX | Max. 0.68μF, Min. 250V, 110°C X1 or X2 | UL 60384-14 UL 1414 | VDE 40022642 UL E193049 |
| Alt. use | Dain Electronics Co., Ltd. | MEX | Max. 0.68μF, Min. 250V, X2 40/100/21/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40018798 UL E147776 |
| Alt. use | Dain Electronics Co., Ltd. | MPX | Max. 0.68μF, Min. 250V, X2 40/100/21/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40018798 UL E147776 |
| Alt. use | Dain Electronics Co., Ltd. | NPX | Max. 0.68μF, Min. 250V, X2 40/100/21/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40018798 UL E147776 |
| Alt. use | Jiangsu Xinghua Huayu Electronics Co., Ltd. | MPX - Series | Max. 0.68μF, Min. 250V, X2 40/100/21/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40022417 UL E311166 |

| IEC 60601-1 | | | | | |
|-----------------------------------|--|-----------------|--|---|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| Alt. use | Shenzhen Jinghao Capacitor Co., Ltd. | CBB62B | Max 0.68 μ F, Min.250V,110°C X2 | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40018690 UL E252286 |
| Alt. use | DONG GUAN AJC INDUSTRIAL CO., LTD | MPX/MKP | Max 0.68 μ F, Min.250V,100°C X2 | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40045532 UL E477850 |
| Alt. use | Foshan Shunde Chuang Ge Electronic Industrial Co., Ltd. | MKP-X2 | Max 0.68 μ F, Min.250V,100°C X2 | IEC/EN 60384-14 | VDE 40008922 |
| Alt. use | Okaya Electric Industries Co. LTD | RE-Series | Max 0.68 μ F, Min.250V,100°C X2 | IEC/EN 60384-14 | VDE 40028657 |
| Alt. use | Hongzhi Enterprises Ltd. | MPX (X2) | Max 0.68 μ F, Min.250V,100°C X2 | IEC/EN 60384-14 | VDE 40023936 |
| Alt. use | Foshan Shunde Beijiao Hua Da Electric Industrial Co., Ltd. | HD MKP series | Max 0.68 μ F, Min.250V,100°C X2 | IEC/EN 60384-14 | VDE 40027182 |
| Alt. use | Vishay Electrónica Portugal, Lda | F 1772 Serie(s) | Max 0.68 μ F, Min.250V,100°C X2 | IEC/EN 60384-14 | VDE 40005095 |
| Alt. use | WINDAY ELECTRONIC (DONG GUAN) CO., LTD | MPX series | Max 0.68 μ F, Min.250V,100°C X2 | IEC/EN 60384-14 | VDE 40018071 |
| Alt. use | Hua Jung Components Co., Ltd. | MKP | Max 0.68 μ F, Min.250V,100°C X2 | IEC/EN 60384-14 | ENEC SE/0252-5E |
| Y capacitor (CY3, CY4) (Optional) | TDK Corporation | CD | Y1, Min.250VAC, max. 1500pF, 25/125/21/B | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40029780 UL E37861 |
| Alt. use | Success Electronics Co., Ltd. | SE | Y1, min.250VAC, max. 1500pF, 40/125/56/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40037211 UL E114280 |
| Alt. use | Success Electronics Co., Ltd. | SB | Y1, min.250VAC, max. 1500pF, 40/125/56/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40037221 UL E114280 |

| IEC 60601-1 | | | | | |
|------------------------------|-----------------------------------|--|---|---|----------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| Alt. use | Walsin Technology Corp. | AH | Y1, min.250VAC, max. 1500pF, 40/125/21/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40001804 UL E146544 |
| Alt. use | Haohua Electronic Co. | CT 7 | Y1, min.250VAC, max. 1500pF, 30/125/56/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40003902 UL E233106 |
| Alt. use | Murata Mfg. Co., Ltd. | KX | Y1, min.250VAC, max. 1500pF, 40/125/21/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40002831 UL E37921 |
| Alt. use | Jyh Chung Electronic Co., Ltd. | JD | Y1, min.250VAC, max. 1500pF, 40/125/21/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 137027 UL E187963 |
| Alt. use | WELSON INDUSTRIAL CO LTD | WD | Y1, min.250VAC, max. 1500pF, 55/125/21/C | IEC/EN 60384-14 | VDE 40016157 UL E104572 |
| Alt. use | JYA-NAY Co., Ltd. | JN | Y1, AC250V, max. 1500pF, 30/125/56/C | IEC/EN 60384-14 UL 60384-14 UL 1414 | VDE 40001831 UL E201384 |
| Line filter (LF1) (Optional) | GlobTek/Zhong Tong/HEJIA/BOAM/ENG | LF045 | 130°C | IEC 60601-1 | Tested with appliance |
| Line filter (LF2) (Optional) | GlobTek/ZhongTong/HEJIA/BOAM/ENG | LF046 | 130°C | IEC 60601-1 | Tested with appliance |
| Line filter (L1) (Optional) | GlobTek/ZhongTong/HEJIA/BOAM/ENG | LF047 | 130°C | IEC 60601-1 | Tested with appliance |
| Transformer (T1) | GlobTek / ENG / BOAM / HAOPUWEI | TF094 for 12-14.9V TF095 for 15-18.9V TF096 for 19-23.9V TF097 for 24-31.9V TF098 for 32-41.9V TF099 for 42-54V | Class B, with critical component listed below | IEC 60601-1 | Tested with appliance |

| IEC 60601-1 | | | | | |
|--------------------------------|---|------------------------|---|--------------------------------------|-------------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| - Insulation system used in T1 | ENG | ENG130-1 | Class 130 (B) | IEC 60601-1 | Tested with appliance |
| Alt. use | GlobTek | GTX-130-TM | Class 130 (B) | IEC 60601-1 | Tested with appliance |
| Alt. use | SHAN DONG BOAM ELECTRIC CO LTD | BOAM-01 | Class 130 (B) | IEC 60601-1 | Tested with appliance |
| Alt. use | SHAN DONG BOAM ELECTRIC CO LTD | B1 | Class 130 (B) | IEC 60601-1 | Tested with appliance |
| Alt. use | WUXI HAOPUWEI ELECTRONICS CO LTD | ZT-130 | Class 130 (B) | IEC 60601-1 | Tested with appliance |
| - Triple-insulated wire | Great Leoflon Industrial Co., Ltd. | TRW (B) Serie(s) | Class B, reinforced insulation | IEC 60950-1 UL 2353 UL 60601-1 | VDE 136581 UL E211989 |
| Alt. use | COSMOLINK CO. Ltd. | TIW-M Serie(s) | Class B, reinforced insulation | IEC 60950-1 UL 2353 UL 60601-1 | VDE 138053 UL E213764 |
| Alt. use | Furukawa Electric Co., Ltd. Electronics & Automotive Systems Company Global Business Development Division | TEX-E | Class B, reinforced insulation | IEC 60950-1 UL 2353 UL 60601-1 | VDE 006735 UL E206440 |
| Alt. use | TOTOKU ELECTRIC CO LTD | TIW-2 | Reinforced insulation, rated 130° C (Class B) | IEC 60950-1 UL 2353 UL 60601-1 | VDE 40005152 UL E249037 |
| Alt. use | E&B TECHNOLOGY CO LTD | E&B-XXXB E&B-XXXB-1 | Reinforced insulation, Class B | IEC 60950-1 UL 2353 UL 60601-1 | VDE 40023473 UL E315265 |
| Alt. use | CHANGYUAN ELECTRONICS (SHENZHEN) CO LTD | CB-TIW | Reinforced insulation, Class B | IEC 60950-1 UL 2353 UL 60601-1 | Tested with appliance UL E249037 |

| IEC 60601-1 | | | | | |
|----------------------|--|--------------------------|---------------------------------------|--|--|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| Alt. use | SHENZHEN JIUDING NEW MATERIAL CO LTD | DTIW-B | Reinforced insulation, Class B | IEC 60950-1 UL 2353 UL 60601-1 | VDE 40037495 UL E357999 |
| - Bobbin | CHANG CHUN PLASTICS CO LTD | T375J T375HF | V-0, 150°C, thickness 0.45 mm min. | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E59481 |
| Alt. use | CHANG CHUN PLASTICS CO LTD | 4130 | V-0, 140°C, thickness 0.74 mm min. | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E59481 |
| Alt. use | SUMITOMO BAKELITE CO LTD | PM-9820 PM-9830 | V-0, 150°C, thickness 0.45 mm min. | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E41429 |
| Alt. use | HITACHI CHEMICAL CO LTD | CP-J-8800 | V-0, 150°C, thickness 0.45 mm min. | IEC 60601-1 UL 94 UL 746 A/B/C/D | Tested with appliance UL E42956 |
| - Insulating tape | 3M COMPANY ELECTRICAL MARKETS DIV (EMD) | 1350F-1 1350T-1 44 | Min.130°C | IEC 60601-1 UL 510 | Tested with appliance UL E17385 |
| Alt. use | BONDTEC PACIFIC CO LTD | 370S(b) | Min.130°C | IEC 60601-1 UL 510 | Tested with appliance UL E175868 |
| Alt. use | JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD | PZ CT WF | Min.130°C | IEC 60601-1 UL 510 | Tested with appliance UL E165111 |
| Alt. use | JINGJIANG JINGYI ADHESIVE PRODUCT CO LTD | JY25-A(b) | Min.130°C | IEC 60601-1 UL 510 | Tested with appliance UL E246950 |
| Alt. use | CHANG SHU LIANG YI TAPE INDUSTRY CO LTD | LY-XX(a)(b) | Min.130°C | IEC 60601-1 UL 510 | Tested with appliance UL E246820 |
| - PTFE tubing | GREAT HOLDING INDUSTRIAL CO LTD | TFT / TFS | Min. 300V, 200°C | IEC 60601-1 | Tested with appliance UL E156256 |

| IEC 60601-1 | | | | | |
|--------------------------|---|--------------------------|--|---|-------------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| Alt. use | SHENZHEN WOER HEAT-SHRINKABLE MATERIAL CO LTD | WF | 600V, 200°C | IEC 60601-1 | Tested with appliance UL E203950 |
| Alt. use | CHANGYUAN ELECTRONICS (SHENZHEN) CO LTD | CB-TT-T / CB-TT-S | Min. 300V, 200°C | IEC 60601-1 | Tested with appliance UL E180908 |
| Alt. use | DONGGUAN LING FREE HARDWARE PLASTICS PRODUCT CO LTD | LING FREE PTFE TUBE | 600V, 200°C | IEC 60601-1 | Tested with appliance UL E352366 |
| Varistor MOV1 (Optional) | CENTRA SCIENCE CORP | CNR-10D471K, CNR-14D471K | Max. Continuous voltage: min 300Vac(rms), 85°C, The coating is V-0 | IEC 61051-1 IEC 61051-2 IEC 61051-2-2 | VDE 40008220 |
| Alt. use | Thinking Electronic Industrial Co., Ltd. | TVR10471K, TVR14471K | Max. Continuous voltage: min 300Vac(rms), 85°C, The coating is V-0 | IEC 61051-1 IEC 61051-2 IEC 61051-2-2 | VDE 005944 |
| Alt. use | SUCCESS ELECTRONICS CO LTD | SVR10D471K SVR14D471K | Max. Continuous voltage: min 300Vac(rms), 85°C, The coating is V-0 | IEC 61051-1 IEC 61051-2 IEC 61051-2-2 | VDE 40030401 |
| Alt. use | Lien Shun Electronics Co., Ltd. | 10D471K 14D471K | Max. Continuous voltage: min 300Vac(rms), 85°C, The coating is V-0 | IEC 61051-1 IEC 61051-2 IEC 61051-2-2 | VDE 40005858 |
| Alt. use | CERAMATE TECHNICAL CO LTD | GNR10D471K GNR14D471K | Max. Continuous voltage: min 300Vac(rms), 85°C, The coating is V-0 | IEC 61051-1 IEC 61051-2 IEC 61051-2-2 | VDE 40031745 |
| Alt. use | BRIGHTKING (SHENZHEN) CO LTD | 14D471K 10D471K | Max. Continuous voltage: min 300Vac(rms), 85°C, The coating is V-0 | IEC 61051-1 IEC 61051-2 IEC 61051-2-2 | VDE 40027827 |
| Alt. use | JOYIN CO LTD | 10N471K 14N471K | Max. Continuous voltage: min 300Vac(rms), 85°C, The coating is V-0 | IEC 61051-1 IEC 61051-2 IEC 61051-2-2 | VDE 005937 |
| Alt. use | Walsin Technology Co., Ltd. | SR471K10D SR471K14D | Max. Continuous voltage: min 300Vac(rms), 85°C, The coating is V-0 | IEC 61051-1 IEC 61051-2 IEC 61051-2-2 | VDE 40010090 |

| IEC 60601-1 | | | | | |
|--|---|------------------------------|---|------------------|-------------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| Photo coupler (U4) | VISHAY Semiconductor GmbH. | TCLT1009 VOL618A | Dti=0.5mm Int. , dcr=6.0mm EXT.dcr=7.7mm, thermal cycling test,110°C | IEC/EN 60747-5-2 | VDE 132473 |
| Alt. use | Everlight Electronics Co., Ltd. | EL1019 | Dti=0.5mm Int. , dcr=6.0mm EXT.dcr=7.7mm, thermal cycling test,110°C | IEC/EN 60747-5-2 | VDE 40028391 |
| Alt. use | COSMO Electronics Corporation | KT1019 | Dti=0.6mm Int. , dcr=4.0mm EXT.dcr=5.0mm, thermal cycling test,115°C | IEC/EN 60747-5-2 | VDE 40031267 |
| Alt. use | Lite-On Technology Corporation | LTV-1009 | Dti=0.8mm Int. , EXT.dcr=7.8mm, thermal cycling test,110°C | IEC/EN 60747-5-2 | VDE 138213 |
| Connector (J1 and J2) (Not for potted models used) | JAPAN SOLDERLESS TERMINAL MFG CO LTD | VH series | Min. 240V; | IEC 60601-1 | Tested with appliance UL E60389 |
| Alt. use | JOINT TECH ELECTRONIC INDUSTRIAL CO LTD | A7920 series A3960 series | Min. 250V; | IEC 60601-1 | Tested with appliance UL E179987 |
| Alt. use | ZHEJIANG HONGXING ELECTRICAL CO LTD | HX396XX-YYY series | Min. 250V; | IEC 60601-1 | Tested with appliance UL E228500 |
| Alt. use | MOLEX L L C | 41791 series | Min. 240V; | IEC 60601-1 | Tested with appliance UL E29179 |
| Supplementary information: 1) Provided evidence ensures the agreed level of compliance. See OD-CB2039. 2) For all transformers under all manufacturers. | | | | | |

| | | |
|--------|--|-----|
| 8.10.1 | RM RESULTS TABLE: Fixing of components | N/A |
| 8.10.2 | RM RESULTS TABLE: Fixing of wiring | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|--------|--|--|------------|
| 8.10.5 | RM RESULTS TABLE: Mechanical protection of wiring | | N/A |
|--------|--|--|------------|

| 8.11.3.5 | TABLE: Cord anchorages | | | N/A |
|----------------------------|-------------------------------|----------|------------|------------|
| Cord under test | Mass of equipment (kg) | Pull (N) | Torque Nm) | Remarks |
| -- | -- | -- | -- | -- |
| Supplementary information: | | | | |

| | | | | |
|----------------------------|-------------------|--------------------|---------|-----|
| 8.11.3.6 | TABLE: Cord guard | | | N/A |
| Cord under test | Test mass | Measured curvature | Remarks | |
| -- | -- | -- | -- | |
| Supplementary information: | | | | |

| | | | |
|--------|--|--|------------|
| 8.11.5 | RM RESULTS TABLE: Mains fuses and over-current releases | | N/A |
|--------|--|--|------------|

| | | | |
|-------|---|--|------------|
| 9.2.1 | RM RESULTS TABLE: HAZARDS associated with moving parts - General | | N/A |
|-------|---|--|------------|

| 9.2.2.2 | TABLE: Measurement of gap "a" according to Table 20 (ISO 13852: 1996) | | | N/A |
|--|--|------------------------|---|---------------------------|
| Part of body | Allowable adult gap ¹⁾ , mm | Measured adult gap, mm | Allowable children gap ¹⁾ , mm | Measured children gap, mm |
| Body | > 500 | | > 500 | |
| Head | > 300 or < 120 | | > 300 or < 60 | |
| Leg | > 180 | | > 180 | |
| Foot | > 120 or < 35 | | > 120 or < 25 | |
| Toes | > 50 | | > 50 | |
| Arm | > 120 | | > 120 | |
| Hand, wrist, fist | > 100 | | > 100 | |
| Finger | > 25 or < 8 | | > 25 or < 4 | |
| Supplementary information: ¹⁾ In general, gaps for adults used, except when the device is specifically designed for use with children, values for children applied. | | | | |

| | | | |
|---------|---|--|------------|
| 9.2.3.2 | TABLE: Over-travel End Stop Test | | N/A |
|---------|---|--|------------|

| | | | |
|-------|---|--|------------|
| 9.2.4 | RM RESULTS TABLE: Emergency stopping devices | | N/A |
|-------|---|--|------------|

| | | | |
|-------|---|--|------------|
| 9.2.5 | RM RESULTS TABLE: Release of patient | | N/A |
|-------|---|--|------------|

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 9.4.2.1 | TABLE: Instability—overbalance in transport position | | N/A |
| 9.4.2.2 | TABLE: Instability—overbalance excluding transport position | | N/A |
| 9.4.2.3 | TABLE: Instability—overbalance from horizontal and vertical forces | | N/A |
| 9.4.2.4.2 | TABLE: Castors and wheels – Force for propulsion | | N/A |
| 9.4.2.4.3 | TABLE: Castors and wheels – Movement over a threshold | | N/A |
| 9.4.3.1 | TABLE: Instability from unwanted lateral movement (including sliding) in transport position | | N/A |
| 9.4.3.2 | TABLE: Instability from unwanted lateral movement (including sliding) excluding transport position | | N/A |
| 9.4.4 | TABLE: Grips and other handling devices | | N/A |
| 9.5.1 | RM RESULTS TABLE: Protective means | | N/A |
| 9.6.1 | RM RESULTS TABLE: Acoustic energy - General | | N/A |
| 9.6.2.2 | RM RESULTS TABLE: Infrasound and ultrasound energy | | N/A |
| 9.7.2 | RM RESULTS TABLE: Pneumatic and hydraulic parts | | N/A |
| 9.7.4 | RM RESULTS TABLE: Pressure rating of ME equipment parts | | N/A |
| 9.7.5 | TABLE: Pressure vessels | | N/A |
| 9.7.6 | RM RESULTS TABLE: Pressure-control device | | N/A |
| 9.7.7 | RM RESULTS TABLE: Pressure-relief device | | N/A |
| 9.8.1 | RM RESULTS TABLE: Hazards associated with support systems - General | | N/A |
| 9.8.2 | RM RESULTS TABLE: Tensile safety factor | | N/A |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 9.8.3.1 | RM RESULTS TABLE: Strength of patient or operator support or suspension systems - General | | N/A |
| 9.8.3.2 | TABLE: PATIENT support/suspension system - Static forces | | N/A |
| 9.8.3.3 | TABLE: Support/Suspension System – Dynamic forces due to loading from persons | | N/A |
| 9.8.4.1 | RM RESULTS TABLE: Systems with mechanical protective devices - General | | N/A |
| 9.8.4.3 | RM RESULTS TABLE: Mechanical protective device for single activation | | N/A |
| 9.8.5 | RM RESULTS TABLE: Systems without mechanical protective devices | | N/A |
| 10.1.1 | TABLE: Measurement of X - radiation | | N/A |
| 10.2 | RM RESULTS TABLE: Alpha, beta, gamma, neutron & other particle radiation | | N/A |
| 10.3 | RM RESULTS TABLE: Microwave radiation | | N/A |
| 10.5 | RM RESULTS TABLE: Other visible electromagnetic radiation | | N/A |
| 10.6 | RM RESULTS TABLE: RISK associated with infrared radiation other than emitted by lasers and LEDs | | N/A |
| 10.7 | RM RESULTS TABLE: RISK associated with ultraviolet radiation other than emitted by lasers and LEDs | | N/A |

| IEC 60601-1 | | | | |
|---|--|---|-----------------|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | P |
| | Supply voltage (V) | 85 | 90 | 264 |
| | Ambient T _{min} (°C) | 24 | 24 | 24 |
| | Model | GTM962250P22512*-FW GTM962250P22512*-F | | — |
| Maximum measured temperature T of part/at.....: | | T (°C) | | Allowed T _{max} (°C) |
| 1.AC Quick Connector | | 34 | 32 | 26 |
| 2.Line chock of LF1 | | 75 | 74 | 35 |
| 3.Varistor MOV1 | | 51 | 48 | 29 |
| 4.E-capacitor | | 60 | 57 | 46 |
| 5.X-capacitor (CX1) | | 44 | 42 | 30 |
| 6.Line chock of L2 | | 68 | 67 | 44 |
| 7.PCB under BD1 | | 49 | 48 | 33 |
| 8.PCB near T1 | | 93 | 94 | 96 |
| 9.Output Quick Connector | | 54 | 53 | 55 |
| 10.Transformer (T1) Winding | | 77 | 75 | 73 |
| 11.Transformer (T1) Core | | 74 | 73 | 71 |
| 12.Optocoupler U4 | | 56 | 55 | 52 |
| 13.CY3 body | | 71 | 70 | 70 |
| Supplementary information: The maximum ambient temperature is 50°C. In the course of practical use, a fan used to provide approximately 10CFM. | | | | |

| IEC 60601-1 | | | | | |
|---|---|---|-----------------|-----|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | | P |
| | Supply voltage (V) | 85 | 90 | 264 | — |
| | Ambient T _{min} (°C) | 24 | 24 | 24 | — |
| | Model | GTM962250P14012*-FW GTM962250P14012*-F | | | — |
| Maximum measured temperature T of part/at.....: | | T (°C) | | | Allowed T _{max} (°C) |
| 1.AC Quick Connector | | 45 | 42 | 34 | 70 |
| 2.Line chock of LF1 | | 81 | 80 | 53 | 85 |
| 3.Varistor MOV1 | | 57 | 55 | 39 | 60 |
| 4.E-capacitor | | 75 | 73 | 60 | 80 |
| 5.X-capacitor (CX1) | | 59 | 57 | 43 | 75 |
| 6.Line chock of L2 | | 79 | 78 | 59 | 85 |
| 7.PCB under BD1 | | 77 | 75 | 52 | 105 |
| 8.PCB near T1 | | 79 | 75 | 75 | 105 |
| 9.Output Quick Connector | | 66 | 65 | 61 | 70 |
| 10.Transformer (T1) Winding | | 82 | 83 | 80 | 85 |
| 11.Transformer (T1) Core | | 79 | 82 | 78 | Ref. |
| 12.Optocoupler U4 | | 73 | 72 | 66 | 85 |
| 13.CY3 body | | 88 | 87 | 78 | 100 |
| Supplementary information: The maximum ambient temperature is 50°C. | | | | | |

| IEC 60601-1 | | | | | |
|---|---|---|-----------------|-----|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | | P |
| | Supply voltage (V) | 85 | 90 | 264 | — |
| | Ambient T _{min} (°C) | 24 | 24 | 24 | — |
| | Model | GTM962250P22524*-FW GTM962250P22524*-F | | | — |
| Maximum measured temperature T of part/at.....: | | T (°C) | | | Allowed T _{max} (°C) |
| 1.AC Quick Connector | | 31 | 30 | 26 | 70 |
| 2.Line chock of LF1 | | 78 | 75 | 34 | 85 |
| 3.Varistor MOV1 | | 50 | 49 | 29 | 60 |
| 4.E-capacitor | | 56 | 54 | 42 | 80 |
| 5.X-capacitor (CX1) | | 41 | 39 | 29 | 75 |
| 6.Line chock of L2 | | 49 | 47 | 34 | 85 |
| 7.PCB under BD1 | | 49 | 46 | 31 | 105 |
| 8.PCB near T1 | | 62 | 61 | 60 | 105 |
| 9.Output Quick Connector | | 32 | 31 | 31 | 70 |
| 10.Transformer (T1) Winding | | 66 | 64 | 62 | 85 |
| 11.Transformer (T1) Core | | 67 | 64 | 61 | Ref. |
| 12.Optocoupler U4 | | 53 | 51 | 46 | 85 |
| 13.CY3 body | | 46 | 47 | 45 | 100 |
| Supplementary information: The maximum ambient temperature is 50°C. In the course of practical use, a fan used to provide approximately 10CFM. | | | | | |

| IEC 60601-1 | | | | |
|---|--|---|-----------------|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | P |
| | Supply voltage (V) | 85 | 90 | 264 |
| | Ambient T _{min} (°C) | 24 | 24 | 24 |
| | Model | GTM962250P14024*-FW GTM962250P14024*-F | | — |
| Maximum measured temperature T of part/at.....: | | T (°C) | | Allowed T _{max} (°C) |
| 1.AC Quick Connector | | 41 | 41 | 36 |
| 2.Line chock of LF1 | | 80 | 80 | 54 |
| 3.Varistor MOV1 | | 55 | 54 | 42 |
| 4.E-capacitor | | 73 | 71 | 59 |
| 5.X-capacitor (CX1) | | 57 | 55 | 42 |
| 6.Line chock of L2 | | 82 | 81 | 64 |
| 7.PCB under BD1 | | 73 | 72 | 53 |
| 8.PCB near T1 | | 63 | 60 | 55 |
| 9.Output Quick Connector | | 44 | 43 | 42 |
| 10.Transformer (T1) Winding | | 81 | 80 | 76 |
| 11.Transformer (T1) Core | | 79 | 78 | 72 |
| 12.Optocoupler U4 | | 70 | 68 | 61 |
| 13.CY3 body | | 75 | 73 | 64 |
| Supplementary information: The maximum ambient temperature is 50°C. | | | | |

| IEC 60601-1 | | | | | |
|---|---|---|-----------------|-----|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | | P |
| | Supply voltage (V) | 85 | 90 | 264 | — |
| | Ambient T _{min} (°C) | 24 | 24 | 24 | — |
| | Model | GTM962250P22538*-FW GTM962250P22538*-F | | | — |
| Maximum measured temperature T of part/at.....: | | T (°C) | | | Allowed T _{max} (°C) |
| 1.AC Quick Connector | | 33 | 30 | 25 | 70 |
| 2.Line chock of LF1 | | 74 | 71 | 33 | 85 |
| 3.Varistor MOV1 | | 46 | 45 | 28 | 60 |
| 4.E-capacitor | | 49 | 47 | 37 | 80 |
| 5.X-capacitor (CX1) | | 42 | 40 | 29 | 75 |
| 6.Line chock of L2 | | 67 | 66 | 41 | 85 |
| 7.PCB under BD1 | | 48 | 46 | 31 | 105 |
| 8.PCB near T1 | | 55 | 54 | 52 | 105 |
| 9.Output Quick Connector | | 34 | 33 | 33 | 70 |
| 10.Transformer (T1) Winding | | 77 | 75 | 72 | 85 |
| 11.Transformer (T1) Core | | 70 | 68 | 64 | Ref. |
| 12.Optocoupler U4 | | 50 | 49 | 45 | 85 |
| 13.CY3 body | | 42 | 41 | 40 | 100 |
| Supplementary information: The maximum ambient temperature is 50°C. In the course of practical use, a fan used to provide approximately 10CFM. | | | | | |

| IEC 60601-1 | | | | | |
|---|---|---|-----------------|-----|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | | P |
| | Supply voltage (V) | 85 | 90 | 264 | — |
| | Ambient T _{min} (°C) | 24 | 24 | 24 | — |
| | Model | GTM962250P14038*-FW GTM962250P14038*-F | | | — |
| Maximum measured temperature T of part/at.....: | | T (°C) | | | Allowed T _{max} (°C) |
| 1.AC Quick Connector | | 42 | 40 | 33 | 70 |
| 2.Line chock of LF1 | | 81 | 80 | 50 | 85 |
| 3.Varistor MOV1 | | 57 | 61 | 40 | 60 |
| 4.E-capacitor | | 72 | 71 | 56 | 80 |
| 5.X-capacitor (CX1) | | 56 | 53 | 41 | 75 |
| 6.Line chock of L2 | | 81 | 81 | 60 | 85 |
| 7.PCB under BD1 | | 71 | 69 | 49 | 105 |
| 8.PCB near T1 | | 54 | 53 | 52 | 105 |
| 9.Output Quick Connector | | 41 | 40 | 41 | 70 |
| 10.Transformer (T1) Winding | | 82 | 82 | 77 | 85 |
| 11.Transformer (T1) Core | | 75 | 73 | 68 | Ref. |
| 12.Optocoupler U4 | | 64 | 60 | 55 | 85 |
| 13.CY3 body | | 66 | 63 | 59 | 100 |
| Supplementary information: The maximum ambient temperature is 50°C. | | | | | |

| IEC 60601-1 | | | | | |
|---|---|---|-----------------|-----|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | | P |
| | Supply voltage (V) | 85 | 90 | 264 | — |
| | Ambient T _{min} (°C) | 24 | 24 | 24 | — |
| | Model | GTM962252P22554*-FW GTM962252P22554*-F | | | — |
| Maximum measured temperature T of part/at.....: | | T (°C) | | | Allowed T _{max} (°C) |
| 1.AC Quick Connector | | 31 | 29 | 25 | 70 |
| 2.Line chock of LF1 | | 69 | 66 | 32 | 85 |
| 3.Varistor MOV1 | | 40 | 37 | 27 | 60 |
| 4.E-capacitor | | 55 | 53 | 41 | 80 |
| 5.X-capacitor (CX1) | | 35 | 34 | 28 | 75 |
| 6.Line chock of L2 | | 54 | 52 | 35 | 85 |
| 7.PCB under BD1 | | 45 | 42 | 29 | 105 |
| 8.PCB near T1 | | 43 | 41 | 40 | 105 |
| 9.Output Quick Connector | | 29 | 28 | 29 | 70 |
| 10.Transformer (T1) Winding | | 70 | 67 | 64 | 85 |
| 11.Transformer (T1) Core | | 64 | 62 | 59 | Ref. |
| 12.Optocoupler U4 | | 42 | 41 | 39 | 85 |
| 13.CY3 body | | 40 | 40 | 39 | 100 |
| Supplementary information: The maximum ambient temperature is 50°C. In the course of practical use, a fan used to provide approximately 10CFM. | | | | | |

| IEC 60601-1 | | | | | |
|---|---|---|-----------------|-----|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | | Verdict |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | | P |
| | Supply voltage (V) | 85 | 90 | 264 | — |
| | Ambient T _{min} (°C) | 24 | 24 | 24 | — |
| | Model | GTM962252P14054*-FW GTM962252P14054*-F | | | — |
| Maximum measured temperature T of part/at.....: | | T (°C) | | | Allowed T _{max} (°C) |
| 1.AC Quick Connector | | 37 | 36 | 31 | 70 |
| 2.Line chock of LF1 | | 80 | 81 | 50 | 85 |
| 3.Varistor MOV1 | | 56 | 57 | 40 | 60 |
| 4.E-capacitor | | 70 | 69 | 55 | 80 |
| 5.X-capacitor (CX1) | | 56 | 55 | 41 | 75 |
| 6.Line chock of L2 | | 77 | 76 | 54 | 85 |
| 7.PCB under BD1 | | 60 | 58 | 43 | 105 |
| 8.PCB near T1 | | 55 | 52 | 49 | 105 |
| 9.Output Quick Connector | | 41 | 40 | 39 | 70 |
| 10.Transformer (T1) Winding | | 76 | 75 | 68 | 85 |
| 11.Transformer (T1) Core | | 72 | 74 | 65 | Ref. |
| 12.Optocoupler U4 | | 64 | 61 | 55 | 85 |
| 13.CY3 body | | 63 | 61 | 55 | 100 |
| Supplementary information: The maximum ambient temperature is 50°C. | | | | | |

| IEC 60601-1 | | | | |
|---|--|--|-----------------|-------------------------------|
| Clause | Requirement + Test | | Result - Remark | |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | P |
| | Supply voltage (V) | 85 | 90 | 264 |
| | Ambient T _{min} (°C) | 24 | 24 | 24 |
| | Model | GTM962253P14054*-P2 GTM962253P14054*-P3 | | — |
| Maximum measured temperature T of part/at.....: | | T (°C) | | Allowed T _{max} (°C) |
| 1.Enclosure | | 35 | 32 | 30 |
| 2.Line chock of LF1 | | 71 | 68 | 50 |
| 3.Varistor MOV1 | | 45 | 41 | 35 |
| 4.E-capacitor | | 60 | 58 | 51 |
| 5.X-capacitor (CX1) | | 42 | 38 | 34 |
| 6.Line chock of L2 | | 62 | 57 | 46 |
| 7.PCB under BD1 | | 58 | 52 | 45 |
| 8.PCB near T1 | | 50 | 46 | 42 |
| 9. Supply cord | | 30 | 29 | 28 |
| 10.Output wire | | 29 | 28 | 29 |
| 11.Transformer (T1) Winding | | 80 | 77 | 72 |
| 12.Transformer (T1) Core | | 76 | 75 | 66 |
| 13.Optocoupler U4 | | 48 | 46 | 43 |
| 14.CY3 body | | 50 | 48 | 46 |
| Supplementary information: The maximum ambient temperature is 50°C. | | | | |

| IEC 60601-1 | | | | |
|--|--|-------------------|----|-------------------------------|
| Clause | Requirement + Test | | | Verdict |
| 11.1.1 | TABLE: Excessive temperatures in ME EQUIPMENT | | | P |
| | Supply voltage (V) | 85 | 90 | 264 |
| | Ambient T _{min} (°C) | 60 | 60 | 60 |
| | Model | GTM962250P12015-F | | |
| Maximum measured temperature T of part/at.....: | | T (°C) | | |
| | | | | Allowed T _{max} (°C) |
| 1.AC Quick Connector | | 64 | 62 | 61 |
| 2.Line chock of LF1 | | 70 | 68 | 64 |
| 3.Varistor MOV1 | | 66 | 64 | 62 |
| 4.E-capacitor | | 67 | 66 | 65 |
| 5.X-capacitor (CX1) | | 65 | 65 | 63 |
| 6.Line chock of L2 | | 75 | 71 | 64 |
| 7.PCB under BD1 | | 72 | 70 | 64 |
| 8.PCB near T1 | | 67 | 67 | 67 |
| 9.Output Quick Connector | | 61 | 61 | 61 |
| 10.Transformer (T1) Winding | | 74 | 74 | 73 |
| 11.Transformer (T1) Core | | 66 | 65 | 65 |
| 12.Optocoupler U4 | | 63 | 63 | 63 |
| 13.CY3 body | | 66 | 65 | 65 |
| Supplementary information: The test performed under 60°C thermal chamber. The test load 15V, 7A for derating testing. | | | | |

| | | |
|---------------|---|------------|
| 11.1.1 | RM RESULTS TABLE: Maximum temperature during normal use (Table 23 or 24) | N/A |
|---------------|---|------------|

| | | |
|-----------------|---|------------|
| 11.1.2.1 | RM RESULTS TABLE: Applied parts intended to supply heat to patient | N/A |
|-----------------|---|------------|

| | | |
|-----------------|---|------------|
| 11.1.2.2 | RM RESULTS TABLE: Applied parts not intended to supply heat to patient | N/A |
|-----------------|---|------------|

| | | | | | | | |
|----------------------------|--|---------------------|--------------------|---------------------|--------------------|--------|-------------------------------|
| 11.1.3 | TABLE: Temperature of windings by change-of-resistance method | | | | | | N/A |
| Temperature T of winding: | | t ₁ (°C) | R ₁ (Ω) | t ₂ (°C) | R ₂ (Ω) | T (°C) | Allowed T _{max} (°C) |
| Insulation class | | | | | | | |
| Supplementary information: | | | | | | | |

| | | |
|---------------|---------------------------------------|------------|
| 11.1.3 | RM RESULTS TABLE: Measurements | N/A |
|---------------|---------------------------------------|------------|

| | | |
|-----------------|---|------------|
| 11.2.2.1 | RM RESULTS TABLE: Risk of fire in an oxygen rich environment | N/A |
|-----------------|---|------------|

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 11.2.2.1 | TABLE: Alternative method to 11.2.2.1 a) 5) to determine existence of an ignition source | | N/A |
| 11.3 | RM RESULTS TABLE: Constructional requirements for fire enclosures of ME equipment | | N/A |
| 11.5 | RM RESULTS TABLE: ME equipment and ME systems intended for use in conjunction with flammable agents | | N/A |
| 11.6.1 | TABLE: overflow, spillage, leakage, ingress of water, cleaning, disinfection, sterilization, compatibility with substances | | N/A |
| 11.6.2 | RM RESULTS TABLE: Overflow in ME equipment | | N/A |
| 11.6.3 | RM RESULTS TABLE: Spillage on ME equipment and ME system | | N/A |
| 11.6.5 | RM RESULTS TABLE: Ingress of water or particulate matter into ME EQUIPMENT and ME SYSTEMS | | N/A |
| 11.6.6 | RM RESULTS TABLE: Cleaning and disinfection of ME equipment and ME systems | | N/A |
| 11.6.7 | RM RESULTS TABLE: Sterilization of ME equipment and ME systems | | N/A |
| 11.6.8 | RM RESULTS TABLE: Compatibility with substances used | | N/A |
| 12.1 | RM RESULTS TABLE: Accuracy of controls and equipment | | N/A |
| 12.3 | RM RESULTS TABLE: Alarm systems | | N/A |
| 12.4.1 | RM RESULTS TABLE: Intentional exceeding of safety limits | | N/A |
| 12.4.2 | RM RESULTS TABLE: Indication of parameters relevant to safety | | N/A |
| 12.4.3 | RM RESULTS TABLE: Accidental selection of excessive output values | | N/A |
| 12.4.4 | RM RESULTS TABLE: Incorrect output | | N/A |
| 12.4.5.2 | RM RESULTS TABLE: Diagnostic X-ray equipment | | N/A |
| 12.4.5.3 | RM RESULTS TABLE: Radiotherapy equipment | | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | |
|----------|--|-----|
| 12.4.5.4 | RM RESULTS TABLE: Other ME equipment producing diagnostic or therapeutic radiation | N/A |
|----------|--|-----|

| | | |
|--------|---|-----|
| 12.4.6 | RM RESULTS TABLE: Diagnostic or therapeutic acoustic pressure | N/A |
|--------|---|-----|

| 13.1.2 | TABLE: measurement of power or energy dissipation in parts & components to waive SINGLE FAULT CONDITIONS in 4.7, 8.1 b), 8.7.2, and 13.2.2 relative to emission of flames, molten metal, or ignitable substances | | | N/A |
|---------------------------------------|--|----------------------------------|---|---------|
| Power dissipated less than (W) | | 15 | | |
| Energy dissipated less than (J) | | 900 | | |
| Part or component tested | Measured power dissipated (W) | Calculated energy dissipated (J) | SINGLE FAULT CONDITIONS waived (Yes/No) | Remarks |
| Supplementary information: | | | | |

| | | |
|------|--|---|
| 13.2 | TABLE: SINGLE FAULT CONDITIONS in accordance with 13.2.2 to 13.2.13, inclusive | P |
|------|--|---|

| Clause No. | Description of SINGLE FAULT CONDITION | Results observed | HAZARDOUS SITUATION (Yes/No) |
|------------|--|-------------------------------|------------------------------|
| 13.2.2 | Electrical SINGLE FAULT CONDITIONS per Clause 8.1: | — | — |
| | C3 short circuit | Fuse open | No |
| | BD1 short circuit | Fuse open | No |
| | D11 short circuit | No output, circuit protected. | No |
| | Q1 1-3 | Fuse open | No |
| | Q1 1-2 | Fuse open | No |
| | Q1 2-3 | No output, circuit protected. | No |
| | Q3 1-3 | Fuse open | No |
| | Q3 1-2 | No output, circuit protected. | No |
| | Q3 2-3 | Fuse open | No |
| | U4 (pri.) short circuit | No output, circuit protected. | No |
| | DS6 short circuit | No output, circuit protected. | No |
| | U4 (sec.) short circuit | No output, circuit protected. | No |
| | C27 short circuit | No output, circuit protected. | No |
| | C28 short circuit | No output, circuit protected. | No |
| 13.2.3 | Overheating of transformers per Clause 15.5: | — | — |
| | | See 15.5 | No |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| Clause No. | Description of SINGLE FAULT CONDITION | Results observed | HAZARDOUS SITUATION (Yes/No) |
|------------|---|--------------------------------|------------------------------|
| 13.2.4 | Failure of THERMOSTATS according to 13.2.13 & 15.4.2, overloading - THERMOSTATS short circuited or interrupted, the less favourable of the two: | — | — |
| | | No thermostat used | N/A |
| 13.2.5 | Failure of temperature limiting devices according to 13.2.13 & 15.4.2, overloading, THERMOSTATS short circuited or interrupted, the less favourable of the two: | — | — |
| | | No temperature limiting device | N/A |
| 13.2.7 | Impairment of cooling that could result in a HAZARD using test method of 11.1: | — | — |
| | Single ventilation fans locked consecutively | No fan used | N/A |
| | Ventilation openings on top and sides impaired by covering openings on top of ENCLOSURE or positioning of ME EQUIPMENT against walls | No ventilation opening | N/A |
| | Simulated blocking of filters | No filter | N/A |
| | Flow of a cooling agent interrupted | No cooling agent used | N/A |
| 13.2.8 | Locking of moving parts – Only one part locked at a time – Also see 13.2.10 below: | — | — |
| | | No moving part | N/A |
| 13.2.9 | Interruption and short circuiting of motor capacitors – Motor capacitors short & open circuited ¹ – Also see 13.10 | — | — |
| | | No such motor | N/A |
| | | No such motor | N/A |
| 13.2.10 | Additional test criteria for motor operated ME EQUIPMENT in 13.2.8 & 13.2.9: | — | — |
| | For every test in SINGLE FAULT CONDITION of 13.2.8 and 13.2.9, motor-operated EQUIPMENT started from COLD CONDITION at RATED voltage or at the upper limit of RATED voltage range for specified time: | No motor | N/A |
| | Temperatures of windings determined at the end of specified test periods or at the instant of operation of fuses, THERMAL CUT-OUTS, motor protective devices | No motor | N/A |
| | Temperatures measured as specified in 11.1.3 d) | No motor | N/A |
| | Temperatures did not exceed limits of Table 26 | No motor | N/A |
| 13.2.12 | Failure of parts that might result in a MECHANICAL HAZARD (See 9 & 15.3): | — | — |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| Clause No. | Description of SINGLE FAULT CONDITION | Results observed | HAZARDOUS SITUATION (Yes/No) |
|---|---------------------------------------|------------------------------|------------------------------|
| | See clause 9 and clause 15.3 | To be checked on end product | N/A |
| Supplementary information: ¹ Test with short-circuited capacitor not performed when motor provided with a capacitor complying with IEC 60252-1 and the ME EQUIPMENT not intended for unattended use including automatic or remote control. See Attachment # and appended Table 8.10. | | | |

| | | |
|--------|--|-----|
| 13.2.6 | RM RESULTS TABLE: Leakage of liquid | N/A |
| 14.1 | RM RESULTS TABLE: Programmable electrical medical systems - General | N/A |
| 14.6.1 | RM RESULTS TABLE: Identification of known and foreseeable hazards | N/A |
| 14.6.2 | RM RESULTS TABLE: Risk control | N/A |
| 14.7 | RM RESULTS TABLE: Requirement specification | N/A |
| 14.8 | RM RESULTS TABLE: Architecture | N/A |
| 14.9 | RM RESULTS TABLE: Design and Implementation | N/A |
| 14.10 | RM RESULTS TABLE: Verification | N/A |
| 14.11 | RM RESULTS TABLE: PEMS validation | N/A |
| 14.13 | RM RESULTS TABLE: Connection of PEMS by NETWORK/DATA COUPLING to other equipment | N/A |
| 15.1 | RM RESULTS TABLE: Construction of ME equipment – Arrangements of controls and indicators of ME equipment | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 15.3 | TABLE: Mechanical Strength tests ¹⁾ | | P |
|-------------|---|---|--------------------------|
| Clause | Name of Test | Test conditions | Observed results/Remarks |
| 15.3.2 | Push Test | Force = 250 N ± 10 N for 5 s | No damage. |
| 15.3.3 | Impact Test | Steel ball (50 mm in dia., 500 g ± 25 g) falling from a 1.3 m | No damage. |
| 15.3.4.1 | Drop Test (hand-held) | Free fall height (m) = | N/A |
| 15.3.4.2 | Drop Test (portable) | Drop height (cm) = 5 | No damage. |
| 15.3.5 | Rough handling test | Travel speed (m/s) = | N/A |
| 15.3.6 | Mould Stress Relief | 7 h in oven at temperature (°C) = 70 | No damage. |
| | | | |

Supplementary information: ¹⁾ As applicable, Push, Impact, Drop, Mould Stress Relief and Rough Handling Tests (delete not applicable rows or state N/A in Remarks field).

| | | |
|--------|-----------------------------|-----|
| 15.3.2 | RM RESULTS TABLE: Push test | N/A |
|--------|-----------------------------|-----|

| | | |
|--------|-------------------------------|-----|
| 15.3.3 | RM RESULTS TABLE: Impact test | N/A |
|--------|-------------------------------|-----|

| | | |
|----------|---|-----|
| 15.3.4.2 | RM RESULTS TABLE: Portable ME equipment | N/A |
|----------|---|-----|

| | | |
|--------|---------------------------------------|-----|
| 15.3.5 | RM RESULTS TABLE: Rough handling test | N/A |
|--------|---------------------------------------|-----|

| | | |
|--------|--|-----|
| 15.4.1 | RM RESULTS TABLE: Construction of connectors | N/A |
|--------|--|-----|

| | | |
|------------|--|-----|
| 15.4.2.1 a | RM RESULTS TABLE: THERMAL CUT-OUTS and OVER-CURRENT RELEASES | N/A |
|------------|--|-----|

| | | |
|------------|---|-----|
| 15.4.2.1 b | RM RESULTS TABLE: THERMAL CUT-OUTS with a safety function | N/A |
|------------|---|-----|

| | | |
|------------|--|-----|
| 15.4.2.1 c | RM RESULTS TABLE: Independent non-SELF-RESETTING THERMAL CUT-OUT | N/A |
|------------|--|-----|

| | | |
|------------|--|-----|
| 15.4.2.1 d | RM RESULTS TABLE: Loss of function of ME EQUIPMENT | N/A |
|------------|--|-----|

| | | |
|------------|--|-----|
| 15.4.2.1 h | RM RESULTS TABLE: ME EQUIPMENT with tubular heating elements | N/A |
|------------|--|-----|

| | | |
|----------|---------------------------|-----|
| 15.4.3.1 | RM RESULTS TABLE: Housing | N/A |
|----------|---------------------------|-----|

| | | |
|----------|------------------------------|-----|
| 15.4.3.2 | RM RESULTS TABLE: Connection | N/A |
|----------|------------------------------|-----|

| | | |
|----------|---|-----|
| 15.4.3.3 | RM RESULTS TABLE: Protection against overcharging | N/A |
|----------|---|-----|

| | | |
|----------|-------------------------------------|-----|
| 15.4.3.4 | RM RESULTS TABLE: Lithium batteries | N/A |
|----------|-------------------------------------|-----|

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | |
|----------|--|-----|
| 15.4.3.5 | RM RESULTS TABLE: Excessive current and voltage protection | N/A |
|----------|--|-----|

| | | |
|--------|------------------------------|-----|
| 15.4.4 | RM RESULTS TABLE: Indicators | N/A |
|--------|------------------------------|-----|

| | | |
|--------|------------------------------------|-----|
| 15.4.5 | RM RESULTS TABLE: Pre-set controls | N/A |
|--------|------------------------------------|-----|

| | | |
|--------|--|-----|
| 15.4.6 | TABLE: actuating parts of controls of ME EQUIPMENT – torque & axial pull tests | N/A |
|--------|--|-----|

| | | |
|------------|------------------------------------|-----|
| 15.4.7.3 b | RM RESULTS TABLE: Entry of liquids | N/A |
|------------|------------------------------------|-----|

| | | | | | | | |
|--|---|--|-----------------------------------|---|---|------------------------------------|--------------|
| 15.5.1.2 | TABLE: transformer short circuit test short-circuit applied at end of windings or at the first point that could be short circuited under SINGLE FAULT CONDITION | | | | | | P |
| Primary voltage (most adverse value from 90 % to 110 % of rated voltage)(V) ¹: | | | | | 90Vac | | — |
| RATED input frequency (Hz): | | | | | 60Hz | | — |
| Winding tested | Class of insulation (A, B, E, F, or H) | Type of protective device (fuse, circuit breaker) /Ratings | Protective device operated Yes/No | Time to THERMAL STABILITY (when protective device did not operate)(Min) | Maximum allowed temp from Table 31 (°C) | Maximum winding temp measured (°C) | Ambient (°C) |
| TF094 | E | Fuse 4A | No | 60min | 155 ² | 75 | 25 |
| TF095 | E | Fuse 4A | No | 60min | 155 ² | 73 | 25 |
| TF096 | E | Fuse 4A | No | 60min | 155 ² | 64 | 25 |
| TF097 | E | Fuse 4A | No | 60min | 155 ² | 67 | 25 |
| TF098 | E | Fuse 4A | No | 60min | 155 ² | 75 | 25 |
| TF099 | E | Fuse 4A | No | 60min | 155 ² | 67 | 25 |
| Supplementary information: | | | | | | | |
| ¹ Loads on other windings between no load and their NORMAL USE load. Short-circuit applied at end of windings or at the first point that could be short circuited under SINGLE FAULT CONDITION. | | | | | | | |
| ² Thermocouples are used, so the limit is to be reduced by10 °C. | | | | | | | |

| | | | | | | |
|---|--|--|---|------------------------------------|------------------|---|
| 15.5.1.3 | TABLE: transformer overload test – conducted only when protective device under short-circuit test operated | | | | | P |
| Primary voltage, most adverse value between 90 % to 110 % of RATED voltage (V) ¹ : | | | | | 90V | |
| RATED input frequency (Hz) : | | | | | 60Hz | |
| Test current just below minimum current that would activate protective device & achieve THERMAL STABILITY under method a) (A)..... : | | | | | See below | |
| Test current based on Table 32 when protective device that operated under method a) is external to transformer, and it was shunted (A): | | | | | Not 60127-1 fuse | |
| Winding tested | Class of insulation (A, B, E, F, H) | Type of protective device used (fuse, circuit breaker)/Ratings | Maximum allowed temp from Table 31 (°C) | Maximum winding temp measured (°C) | Ambient (°C) | |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| Winding tested | Class of insulation (A, B, E, F, H) | Type of protective device used (fuse, circuit breaker)/Ratings | Maximum allowed temp from Table 31 (°C) | Maximum winding temp measured (°C) | Ambient (°C) |
|----------------|-------------------------------------|--|---|------------------------------------|--------------|
| TF094 | E | Fuse 4A (OL current 2.879A) | 155 ² | 77 | 25 |
| TF095 | E | Fuse 4A (OL current 2.880A) | 155 ² | 75 | 25 |
| TF096 | E | Fuse 4A (OL current 2.941A) | 155 ² | 65 | 25 |
| TF097 | E | Fuse 4A (OL current 2.847A) | 155 ² | 70 | 25 |
| TF098 | E | Fuse 4A (OL current 2.871A) | 155 ² | 78 | 25 |
| TF099 | E | Fuse 4A (OL current 2.826A) | 155 ² | 70 | 25 |

Supplementary information:

¹ Loads on other windings between no load and their NORMAL USE load.

Time durations: - IEC 60127-1 fuse: 30 min at current from Table 32.

Non IEC 60127-1 fuse: 30 min at the current based on characteristics supplied by fuse manufacturer, specifically, 30 min clearing-time current. When no 30 min clearing-time current data available, test current from Table 32 used until THERMAL STABILITY achieved.

- Other types of protective devices: until THERMAL STABILITY achieved at a current just below minimum current operating the protective device in a). This portion concluded at specified time or when a second protective device opened.

² Thermocouples are used, so the limit is to be reduced by 10 ° C.

| 15.5.2 | TABLE: Transformer dielectric strength after humidity preconditioning of 5.7 | | | | | P |
|---------------------------------|--|-------------------|---------------------|------------------|----------------------|---|
| Transformer Model/Type/ Part No | Test voltage applied between | Test voltage, (V) | Test frequency (Hz) | Breakdown Yes/No | Deterioration Yes/No | |
| All models | Primary & secondary windings | 4000 | 60 | No | No | |
| All models | Secondary winding & core | 4000 | 60 | No | No | |
| All models | Primary winding | 1200 | 300 | No | No | |
| | | | | | | |
| | | | | | | |

Supplementary information: Tests conducted under the conditions of 11.1, in ME EQUIPMENT or under simulated conditions on the bench. See Clause 15.5.2 for test parameters & other details

| | | |
|--------|---|-----|
| 16.1 | RM RESULTS TABLE: General requirements for ME Systems | N/A |
| 16.6.1 | TABLE: Leakage currents in ME system _ Touch current measurements | N/A |
| 16.9.1 | RM RESULTS TABLE: Connection terminals and connectors | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | |
|----|--|-----|
| 17 | RM RESULTS TABLE: Electromagnetic compatibility of ME equipment and ME systems | N/A |
|----|--|-----|

| | | | |
|----------------------------|--|-------------------------|------------------|
| SP | TABLE: Additional or special tests conducted | | N/A |
| Clause and Name of Test | | Test type and condition | Observed results |
| -- | | -- | -- |
| Supplementary information: | | | |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| ATTACHMENT TO TEST REPORT IEC 60601-1 US NATIONAL DIFFERENCES Medical electrical equipment, Part 1: General Requirements | | | |
|---|---|--|-----|
| Differences according to | | US National standard ANSI/AAMI ES60601-1: 2005 / A2:2010 | |
| Attachment Form No. | | US_ND_IEC60601_1G | |
| Attachment Originator | | Underwriters Laboratories Inc. | |
| Master Attachment | | 2011-04 | |
| Copyright © 2011 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved. | | | |
| | US NATIONAL DIFFERENCES | | P |
| 4.8 b | Replacement: where there was no relevant IEC/ISO standard, the relevant US ANSI standard applied | | P |
| | - when no relevant US ANSI standard existed, the requirements of this standard applied | | P |
| 4.10.2 | Replacement: Rated voltage not exceeding 250V dc or single phase ac. or 600V poly-phase ac for ME EQUIPMENT and ME SYSTEMS up to 4kVA | | P |
| | Rated voltage not exceeding 600 V for all other ME EQUIPMENT and ME SYSTEMS | | N/A |
| 6.6 | Addition: To comply with NFPA 70, X-Ray systems are classified as long time operation (> 5 min) or momentary operation (< 5 sec) | Not X-ray system | N/A |
| 7.2.11 | Addition: To comply with NFPA 70, X-Ray systems are marked as long time operation or momentary operation | Not X-ray system | N/A |
| 7.2.21 | New Sub-clause: Colors of medical gas cylinders | | |
| | To comply with NFPA 99: Cylinders containing medical gases and their connection points are colored in accordance with the requirements of NFPA 99 | No medical gas | N/A |
| 8.2 | Addition: All FIXED ME EQUIPMENT & PERMANENTLY INSTALLED ME EQUIPMENT are CLASS I ME EQUIPMENT | Not fixed & permanently installed ME equipment. | N/A |
| 8.6.1 | Addition: To comply with NFPA 99, the enclosure of X-ray ME EQUIPMENT operating over 600 Vac, 850Vdc MAINS VOLTAGE, or containing voltages up to 50 V peak and enclosed in protectively earthed enclosure as well as connections to X-ray tubes and other high voltage components that include high voltage shielded cables are PROTECTIVELY EARTHED. | Not X-ray system | N/A |
| | To comply with NFPA 99, non-current carrying conductive parts of X-Ray ME EQUIPMENT likely to become energized are PROTECTIVELY EARTHED | Not X-ray system | N/A |
| 8.7.3 d | EARTH LEAKAGE CURRENT values are not higher than the stated values | No earthing | N/A |
| | 5 mA in NORMAL CONDITION | No earthing | N/A |
| | 10 mA in SINGLE FAULT CONDITION | No earthing | N/A |
| 8.11 | Addition prior to the first paragraph: a) To comply with the NEC, add the following requirements to this clause: | | |

| IEC 60601-1 | | | |
|-------------|--|----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Addition: PERMANENTLY CONNECTED ME EQUIPMENT provided with field wiring provision in accordance with NEC | Not permanently connected. | N/A |
| | Installation of connecting cords between EQUIPMENT parts comply with NEC | | N/A |
| | Cable used as external interconnection between units | | N/A |
| | 1) Exposed to abuse: Type SJT, SJTO, SJO, ST, SO, STO, or equivalent, or similar multiple-conductor appliance-wiring material, | No such cable. | N/A |
| | 2) Not exposed to abuse: The cable was as in item 1) above, or | No such cable. | N/A |
| | i) Type SPT-2, SP-2, or SPE-2, or equivalent | No such cable. | N/A |
| | ii) Type SVr, SVRO, SVE, or equivalent or similar multiple-conductor appliance wiring material, | No such cable. | N/A |
| | iii) An assembly of insulated wires each with a nominal insulation thickness of 0.8 mm (1/32 inch) or more, | No such cable. | N/A |
| | - enclosed in acceptable insulating tubing having a nominal wall thickness of 0.8 mm (1/32 inch) or more | No such cable. | N/A |
| | Receptacles provided as part of ME EQUIPMENT and ME SYSTEMS for use in the patient care areas of pediatric wards, rooms, or areas are Listed tamper resistant | No such cable. | N/A |
| | - or employ a Listed tamper resistant cover in accordance with NEC | No such cable. | N/A |
| | Addition at the end of the clause: b) For ME EQUIPMENT provided with NEMA configuration non-locking plug types 120 V/15 A, 125 V/20 A, 250 V/15 A, 250 V/20 A "Hospital Grade" mains plug is provided and the POWER SUPPLY CORD is marked | No such plug. | N/A |
| 8.11.3.2 | Addition: The flexible cord is a type acceptable for the particular application, | No such cord. | N/A |
| | - and it is acceptable for use at a voltage not less than the rated voltage of the appliance | No such cord. | N/A |
| | - and has an ampacity as in NEC, not less than the current rating of the appliance | No such cord. | N/A |
| 8.11.3.3 | Addition: To comply with NFPA 99, for X-Ray ME EQUIPMENT with an attachment plug, the current rating on a hospital grade plug is 2X the maximum input current of the equipment | Not X-ray equipment. | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| ATTACHMENT TO TEST REPORT IEC 60601-1 3 rd edition CA - CANADIAN NATIONAL DIFFERENCES to CAN/CSA-C22.2 No. 60601-1:08 | |
|---|--|
| Differences according to | Canadian National standard: CAN/CSA-C22.2 No. 60601-1:08 |
| Attachment Form No. | CA_ND_IEC60601_1G |
| Attachment Originator | CSA International |
| Master Attachment | 2010-12 |
| Copyright © 2010 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved. | |

| CA - Canadian National Differences as per CAN/CSA-C22.2 No. 60601-1:08 | | | |
|--|--|------------------------------|------------|
| 1 | Scope, object and related documents | | --- |
| 1.1 | Scope | | --- |
| | This standard applies to the BASIC SAFETY and ESSENTIAL PERFORMANCE of MEDICAL ELECTRICAL EQUIPMENT and MEDICAL ELECTRICAL SYSTEMS designed to be installed in accordance with the <i>Canadian Electrical Code (CEC), Part I</i> , CSA C22.1; CAN/CSA-C22.2 No. 0; and CAN/CSA-Z32. | | P |
| | NOTE 1A: <i>In the IEC 60601 standards series adopted for use in Canada, the Canadian-particular standards may modify, replace, or delete requirements contained in this standard as appropriate for the particular ME EQUIPMENT and ME SYSTEMS under consideration, and may add other BASIC SAFETY and ESSENTIAL PERFORMANCE requirements.</i> | | --- |
| 1.3 | Collateral standards | | --- |
| | Applicable Canadian collateral standards become normative at the date of their publication and apply together with this standard. | | P |
| | NOTE 1: <i>When evaluating compliance with CAN/CSA-C22.2 No. 60601-1, it is permissible to assess independently compliance with the adopted Canadian collateral standards.</i> | | --- |
| 1.4 | Particular standards | | --- |
| | A requirement of a Canadian-particular safety standard takes precedence over this standard. | | P |
| 3 | Terminology and definitions | | --- |
| 3.41 | HIGH VOLTAGE | | --- |
| | any voltage above 750 V, 1 050 V peak, as defined in the <i>Canadian Electrical Code (CEC), Part I</i> | Noted, but no such HV in EUT | N/A |
| 4 | General requirements | | --- |
| 4.8 | Components of ME EQUIPMENT | | --- |
| | a) the applicable safety requirements of a relevant CSA, IEC, or ISO standard; or | | P |

| IEC 60601-1 | | | |
|----------------|--|---------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | NOTE 1: <i>For the components, it is not necessary to carry out identical or equivalent tests already performed to check compliance with the component standard.</i> | | --- |
| | b) where there is no relevant CSA, IEC, or ISO standard, the requirements of this standard have to be applied | | P |
| | NOTE 2: <i>If there are neither requirements in this standard nor in a CSA, IEC, or ISO standard, any other applicable source (e.g., standards for other types of devices, national standards) could be used to demonstrate compliance with the RISK MANAGEMENT PROCESS.</i> | | --- |
| 4.10.2 | SUPPLY MAINS for ME EQUIPMENT and ME SYSTEMS | | ---- |
| | and shall be in accordance with the <i>Canadian Electrical Code (CEC), Part I, CSA C22.1:</i> | | P |
| 7 | ME EQUIPMENT identification, marking and documents | | --- |
| 7.7.1 to 7.7.5 | and shall be in accordance with the <i>Canadian Electrical Code (CEC), Part I, CSA C22.1</i> | | P |
| | A PROTECTIVE EARTH CONDUCTOR or a PROTECTIVE EARTH CONNECTION or insulation shall be identified by either green or green and yellow colour. Colours of neutral and POWER SUPPLY CORD conductors shall be in accordance with the <i>Canadian Electrical Code (CEC), Part I, CSA C22.2 No. 21, and CSA C22.2 No. 49.....</i> | | P |
| 8 | Protection against electrical HAZARDS from ME EQUIPMENT | | --- |
| 8.7.3 | Allowable values | | --- |
| | Allowable values shall be in accordance with the <i>Canadian Electrical Code (CEC), Part I, CSA C22.1.</i> | | P |
| 8.11.3 | POWER SUPPLY CORDS | | --- |
| 8.11.3.2 | Types | | --- |
| | a) The MAINS PLUG of non-PERMANENTLY INSTALLED EQUIPMENT shall be | | --- |
| | i) If molded-on type, hospital grade mains plug complying with CSA C22.2 No. 21.....: | Certified connector | N/A |
| | ii) Hospital grade disassembly attachment plug type complying with CSA C22.2 No. 42; or.....: | Certified connector | N/A |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | iii) Class II equipment having fuses on the line side/sides and neutral and may use a non-polarized attachment plug or a polarized attachment plug — CSA configuration type 1-15P shall be required and shall meet all applicable requirements in CSA C22.2 No. 21 and CSA C22.2 No. 42. Where a polarized attachment plug is used, the POWER SUPPLY CORD shall be connected to the wiring of the EQUIPMENT on the ungrounded side of the line when any of the following devices are used in the primary circuit.....: | No power cord | N/A |
| | 1- the centre contact of an Edison base lampholder; | No power cord | N/A |
| | 2- a single pole switch; | No power cord | N/A |
| | 3- an automatic control with a marked off position; | No power cord | N/A |
| | 4- a solitary fuse/fuse holder; or | No power cord | N/A |
| | 5- any other single pole overcurrent protective device | No power cord | N/A |
| | b) Detachable POWER SUPPLY CORD for non-PERMANENTLY INSTALLED EQUIPMENT (cord-connected equipment) shall be of a type that | | --- |
| | i) can be shown to be unlikely to become detached accidentally, unless it can be shown that detachment will not constitute a safety HAZARD to a PATIENT or OPERATOR; | No power cord | N/A |
| | ii) can be shown that the impedance of the earth (ground) circuit contacts will not constitute a safety HAZARD to a PATIENT or OPERATOR; and | No power cord | N/A |
| | iii) has a terminal configuration or other constructional feature that will minimize the possibility of its replacement by a detachable POWER SUPPLY CORD which could create a HAZARDOUS SITUATION | No power cord | N/A |
| | c) A detachable POWER SUPPLY CORD shall | | --- |
| | i) comply with the applicable requirements of CSA C22.2 No. 21; and.....: | No power cord | N/A |
| | ii) not be smaller than No.18 AWG, and the mechanical serviceability shall be not less than.....: | No power cord | N/A |
| | 1) Type SJ or equivalent for mobile or exposed to abuse ME EQUIPMENT; and.....: | No power cord | N/A |
| | 2) Type SV or equivalent for ME EQUIPMENT not exposed to abuse (or Type HPN if required because of temperature).....: | No power cord | N/A |
| | NOTE 1A: See CSA C22.2 No. 49 for requirements on the cord types mentioned in Sub-item 2). | | --- |
| | d) Power supply cords shall meet the requirements of the <i>Canadian Electrical Code, Part I</i> , as applicable.....: | No power cord | N/A |

| IEC 60601-1 | | | |
|-------------|---|---------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Connecting cords between equipment parts shall meet the requirements of the <i>Canadian Electrical Code, Part I</i> , as applicable.....: | No power cord | N/A |
| 8.11.5 | Mains fuses and OVER-CURRENT RELEASES | | --- |
| | Mains fuses and OVER-CURRENT RELEASES shall be in accordance with the <i>Canadian Electrical Code (CEC), Part I</i> , CSA C22.1.....: | | P |
| 9 | Protection against MECHANICAL HAZARDS of ME EQUIPMENT and ME SYSTEMS | | --- |
| 9.7.5 | Pressure vessels | | --- |
| | Pressure vessels shall comply with the requirements of CSA B51, as applicable.....: | No pressure vessel | N/A |
| 9.7.7 | Pressure-relief device | | --- |
| | A pressure-relief device shall also comply as applicable to the requirements of ASME PTC 25 or equivalent Canadian requirements.....: | No pressure relief device | N/A |
| 15 | Construction of ME EQUIPMENT | | --- |
| 15.4.1 | Construction of connectors | | --- |
| | bA) The point of connection of gas cylinders to EQUIPMENT shall be gas specific and clearly identified so that errors are avoided when a replacement is made. Medical gas inlet connectors on EQUIPMENT shall be | | --- |
| | i) gas specific, yoke type, or nut and nipple type valve connections complying with CGA V-1 for pressures over 1 380 kPa (200 psi); or.....: | No gas connection | N/A |
| | ii) DISS type complying with CGA V-5 for pressures 1 380 kPa (200 psi) or less and configured to permit the supply of medical gases from low-pressure connecting assemblies complying with CAN/CSA-Z5359.....: | No gas connection | N/A |
| | NOTE 1A: Users of this standard should consult the CSA Z305 series of standards, CAN/CSA-Z9170-1, CAN/CSA-Z9170-2, CAN/CSA-Z10524, and CAN/CSA-Z15002 for further information regarding inlet connectors; ISO 407 for requirements addressing yoke-type valve connections; and ISO 32 for colour coding. | | --- |
| 15.4.8 | Internal wiring of ME EQUIPMENT | | --- |
| | Internal wiring of ME EQUIPMENT shall be in accordance with the <i>Canadian Electrical Code (CEC), Part I</i> , CSA C22.1.....: | No such wiring. | N/A |
| 16 | ME SYSTEMS | | --- |
| 16.1 | General requirements for the ME SYSTEMS | | --- |
| | An ME SYSTEM shall provide | | --- |

| IEC 60601-1 | | | |
|-------------|--|--------------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - within the PATIENT ENVIRONMENT, the level of safety equivalent to ME EQUIPMENT complying with this standard; and | Not medical system | N/A |
| | - outside the PATIENT ENVIRONMENT, the level of safety equivalent to equipment complying with their respective CSA, IEC, or ISO safety standards | Not medical system | N/A |
| | Non-ME EQUIPMENT, when used in an ME SYSTEM, shall comply with CSA, IEC, or ISO safety standards that are relevant to that equipment. | Not medical system | N/A |
| 16.9.2.1 | MULTIPLE SOCKET OUTLET | | --- |
| | c) The MULTIPLE SOCKET-OUTLET shall comply with the requirements of CSA C22.2 No. 42, CSA C22.2 No. 49, and the following requirements.....: | No MSO | N/A |
| | - The separating transformer shall comply with the requirements of CAN/CSA-E61558-2-1 with a rated output not exceeding | | --- |
| | - 1 kVA for single-phase transformers; and | No MSO | N/A |
| | - 5 kVA for polyphase transformers The separating transformer shall also have a degree of protection not exceeding IPX4. | No MSO | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|--|--|--|------------|
| | National standard reference: SN EN 60601-1:2006 | | P |
| | <p>Ordinance on environmentally hazardous substances SR 814.081, Annex 1.7, Mercury - Annex 1.7 of SR 814.81 applies for mercury. Switches containing mercury such as thermostats, relays and level controllers are not allowed.</p> <p>Ordinance on chemical hazardous risk reduction SR 814.81, Annex 2.15 Batteries Annex 2.15 of SR 814.81 applies for batteries containing cadmium and mercury.</p> <p>Note: Ordinance relating to environmentally hazardous substances, SR 814.013 of 1986-06-09 is not longer in force and superseded by SR 814.81 of 2009-02-01 (ChemRRV).</p> | | P |
| | <p>Supply cords of portable electrical appliances having a rated current not exceeding 10 A shall be provided with a plug complying with IEC 60884-1(3.ed.) + am1, SEV 1011 and one of the following dimension sheets:</p> <ul style="list-style-type: none"> - SEV 6533-2:2009 Plug type 11, L + N, 250V 10A - SEV 6534-2:2009 Plug type 12, L + N + PE, 250V 10A - SEV 6532-2:2009 Plug type 15, 3L + N + PE, 250/400V 10A <p>Supply cords of portable electrical appliances having a rated current not exceeding 16 A shall be provided with a plug complying with IEC 60884-1(3.ed.) + am1, SEV 1011 and one of the following dimension sheets:</p> <ul style="list-style-type: none"> - SEV 5933-2:2009 Plug type 21 L + N, 250 V, 16A - SEV 5934-2:2009 Plug type 23 L + N + PE, 250 V, 16A - SEV 5932-2:2009 Plug type 25 3L + N + PE, 250/400V 16A <p>Note: 16 A plugs are not often used in Swiss domestic installation system. See TRF template regulatory requirements Switzerland on IECCE Website R.R. TRF templates.</p> | | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|--|---|--|------------|
| | KS C IEC 60601-1 | | — |
| | LIMITATIONS <Supply voltage rating> National supply voltages are 110,220V and 380V | | P |
| | <Frequency> Only appliances having supply frequency of 60 Hz or a frequency range including 60 Hz are accepted. | | P |
| | <Instruction> Instruction manuals and appliance markings related safety, including nameplate shall be in Korean or graphical symbols in accordance with IEC Publication 417. Plugs for connection of the equipment to the supply mains shall comply with the Korean Standard (KSC 8305 and 8300) More details are available from KTR on request. | Shall be checked in end product level. | N/A |

| IEC 60601-1 | | | |
|-------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|-----|---|--|----------|
| | National standard reference: JIS T0601-1:2012 | | P |
| 1.1 | At the end, add the following: JIS T0601-1:1999 is applicable until 2017.05.31. | | — |
| 1.3 | In NOTE 3, add the following: In Japan, to check the concerned JIS standard is required. | | — |
| 1.4 | At the end of NOTE, add the following: In Japan, application of the concerned JIS standard(s) is required. | | — |
| 2 | <p>Except the part of the first paragraph, Attention and NOTE, replace the existing part listing standards with the following, and apply these properly in the following clauses if any:</p> <p>JIS B7761-3, Hand-transmitted vibration-Part 3: General requirements for measurement and evaluation</p> <p>NOTE: ISO 5349-1, Mechanical vibration - Measurement and evaluation of human exposure to hand-transmitted vibration - Part 1: General requirements (IDT)</p> <p>JIS B9707, Safety of machinery-Safety distances to prevent danger zones being reached by the upper limbs</p> <p>NOTE: ISO 13852, Safety of machinery - Safety distances to prevent danger zones being reached by the upper limbs (IDT)</p> <p>JIS B9711, Safety of machinery-Minimum gaps to avoid crushing of parts of the human body</p> <p>NOTE: ISO 13854, Safety of machinery - Minimum gaps to avoid crushing of parts of the human body (IDT)</p> <p>JIS C0445, Identification of equipment terminals and of terminations of certain designated conductors, including general rules for an alphanumeric system</p> <p>NOTE: IEC 60445, Basic and safety principles for man-machine interface, marking and identification - Identification of equipment terminals and of terminations of certain designated conductors, including general rules for an alphanumeric system (IDT)</p> <p>JIS C0447, Man-machine interface (MMI) - Actuating principles</p> <p>NOTE: IEC 60447, Basic and safety principles for man-machine interface, marking and identification - Actuating principles (IDT)</p> | | — |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | <p>JIS C0920:2003, Degrees of protection provided by enclosures (IP Code)</p> <p>NOTE: IEC 60529:2001, Degrees of protection provided by enclosures (IP Code) (IDT)</p> <p>JIS C1509-1, Electroacoustics - Sound level meters- Part 1: Specifications</p> <p>NOTE: IEC 61672-1, Electroacoustics - Sound level meters - Part 1: Specifications (IDT)</p> <p>JIS C1509-2, Electroacoustics -Sound level meters - Part 2: Pattern evaluation tests</p> <p>NOTE: IEC 61672-2, Electroacoustics - Sound level meters - Part 2: Pattern evaluation tests (IDT)</p> <p>JIS C2134, Method for the determination of the proof and the comparative tracking indices of solid insulating materials</p> <p>NOTE: IEC 60112, Method for the determination of the proof and the comparative tracking indices of solid insulating materials (IDT)</p> <p>JIS C3301:2000, Rubber insulated flexible cords</p> <p>NOTE: IEC 60245-4:1994, Rubber insulated cables of rated voltages up to and including 450/750 V - Part 4: Cords and flexible cables, Amendment 1:1997 (NEQ)</p> <p>JIS C3306:2000, Polyvinyl chloride insulated flexible cords</p> <p>NOTE: IEC 60227-5:1997, Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V - Part 5: Flexible cables (cords) (NEQ)</p> <p>JIS C4003, Electrical insulation-Thermal evaluation and designation</p> <p>NOTE: IEC 60085, Electrical insulation - Thermal evaluation and designation (MOD)</p> <p>JIS C5101-14:2009, Fixed capacitors for use in electronic equipment - Part 14: Sectional specification: Fixed capacitors for electromagnetic interference suppression and connection to the supply mains</p> <p>NOTE: IEC 60384-14:2005, Fixed capacitors for use in electronic equipment - Part 14: Sectional specification: Fixed capacitors for electromagnetic interference suppression and connection to the supply mains (IDT)</p> <p>JIS C6065:2007, Audio, video and similar electronic apparatus-Safety requirements</p> <p>NOTE: IEC 60065:2001, Audio, video and similar</p> | | |

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | <p>electronic apparatus - Safety requirements (MOD)</p> <p>JIS C6802:2005, Safety of laser products</p> <p>NOTE: IEC 60825-1:1993, Safety of laser products - Part 1: Equipment classification, requirements and user's guide, Amendment 1:1997 and Amendment 2 :2001 (IDT)</p> <p>JIS C6965, Mechanical safety of cathode ray tubes</p> <p>NOTE: IEC 61965, Mechanical safety of cathode ray tubes (IDT)</p> <p>JIS C8282-1, Plugs and socket-outlets for household and similar purposes - Part 1: General requirements</p> <p>NOTE: IEC 60884-1, Plugs and socket-outlets for household and similar purposes - Part 1: General requirements (MOD)</p> <p>JIS C8303, Plugs and receptacles for domestic and similar general use</p> <p>NOTE: No corresponding JIS exists. This standard has been listed as normative reference corresponding to IEC60083, Plugs and socket-outlets for domestic and similar general use standardized in member countries of IEC, which has been listed in IEC 60601-1:2005. Refer to JIS T1021, too.</p> <p>JIS C60068-2-2:1995, Environmental testing -Part 2-2:Tests -Test B: Dry heat</p> <p>NOTE: IEC 60068-2-2:1974, Environmental testing - Part 2: Tests. Tests B: Dry heat, Amendment 1:1993 and Amendment 2:1994 (IDT)</p> <p>JIS C60079-0, Explosive atmospheres-Part 0: Equipment-General requirements</p> <p>NOTE: IEC 60079-0, Electrical apparatus for explosive gas atmospheres - Part 0: General requirements (IDT)</p> <p>JIS C60079-2, Electrical apparatus for explosive gas atmospheres - Part 2: Pressurized enclosures "p"</p> <p>NOTE: IEC 60079-2, Electrical apparatus for explosive gas atmospheres - Part 2: Pressurized enclosures "p" (IDT)</p> <p>JIS C60079-6, Electrical apparatus for explosive gas atmospheres - Part 6:Oil immersion "o"</p> <p>NOTE: IEC 60079-6, Electrical apparatus for explosive gas atmospheres - Part 6: Oil-immersion "o" (IDT)</p> <p>JIS C60364-4-41, Low-voltage electrical installations-Part 4-41: Protection for safety -</p> | | |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | <p>Protection against electric shock</p> <p>NOTE: IEC 60364-4-41, Electrical installations of buildings - Part 4-41: Protection for safety - Protection against electric shock (IDT)</p> <p>JIS C60664-1:2009, Insulation coordination for equipment within low-voltage systems - Part 1: Principles, requirements and tests</p> <p>NOTE: IEC 60664-1:2007, Insulation coordination for equipment within low-voltage systems - Part 1: Principles, requirements and tests (IDT)</p> <p>JIS C60695-11-10, Fire hazard testing-Part 11-10: Test flames-50W horizontal and vertical flame test methods</p> <p>NOTE: IEC 60695-11-10, Fire hazard testing - Part 11-10: Test flames - 50 W horizontal and vertical flame test methods (IDT)</p> <p>JIS T0307, Medical devices-Symbols to be used with medical device labels, labelling and information to be supplied</p> <p>NOTE: ISO 15223, Medical devices - Symbols to be used with medical device labels, labelling and information to be supplied (IDT)</p> <p>JIS T0601-1-3, Medical electrical equipment-Part 1-3: General requirements for basic safety and essential performance-Collateral Standard: Radiation protection in diagnostic X-ray equipment</p> <p>NOTE: IEC60601-1-3, Medical electrical equipment - Part 1: General requirements for safety - 3. Collateral standard: General requirements for radiation protection in diagnostic X-ray equipment (IDT)</p> <p>JIS T14971:2003, Medical devices-Application of risk management to medical devices</p> <p>NOTE: ISO 14971:2000, Medical devices - Application of risk management to medical devices (IDT)</p> <p>JIS Z8202 (all parts), Quantities and units</p> <p>NOTE: ISO 31 (all parts), Quantities and units (IDT)</p> <p>JIS Z8203, SI units and recommendations for the use of their multiples and of certain other units</p> <p>NOTE: ISO 1000, SI units and recommendations for the use of their multiples and of certain other units (IDT)</p> <p>JIS Z8736-1, Acoustics - Determination of sound power levels of noise sources using sound intensity - Part 1 : Measurement at discrete points</p> | | |

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | <p>NOTE: ISO 9614-1, Acoustics - Determination of sound power levels of noise sources using sound intensity - Part 1: Measurement at discrete points (IDT)</p> <p>JIS Z9101:2005, Safety colours and safety signs- Design principles for safety signs in workplaces and public areas</p> <p>NOTE: ISO 3864-1:2002, Graphical symbols - Safety colours and safety signs - Part 1: Design principles for safety signs in workplaces and public areas (IDT)</p> <p>ISO 780, Packaging - Pictorial marking for handling of goods</p> <p>NOTE: The corresponding JIS standard is JIS Z0150 Packaging-Pictorial marking for handling of goods (MOD)</p> <p>ISO 1853, Conducting and dissipative rubbers, vulcanized or thermoplastic— Measurement of resistivity</p> <p>NOTE: The corresponding JIS standard is JIS K6271 Rubber, vulcanized or thermoplastic- Determination of volume and surface resistivity (MOD)</p> <p>ISO 2878, Rubber - Antistatic and conductive products - Determination of electrical resistance</p> <p>ISO 2882, Rubber, vulcanized - Antistatic and conductive products for hospital use - Electrical resistance limits</p> <p>ISO 3746, Acoustics - Determination of sound power levels of noise sources using sound pressure – Survey method using an enveloping measurement surface over a reflecting plane</p> <p>ISO 7000-DB:2004, Graphical symbols for use on equipment - Index and synopsis</p> <p>ISO 7010:2003, Graphical symbols - Safety colours and safety signs - Safety signs used in workplaces and public areas</p> <p>ISO 10993 (all parts), Biological evaluation of medical devices</p> <p>NOTE: The corresponding JIS standard is JIS T0993-1 Biological evaluation of medical devices- Part 1: Evaluation and testing within a risk management process (MOD). However, other Parts than Part 1 and Part 7 have still not been published as JIS.</p> <p>ISO 11134, Sterilization of health care products - Requirements for validation and routine control - Industrial moist heat sterilization</p> | | |

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | <p>NOTE: At present, as the corresponding JIS or international standards, the following exist:</p> <p>JIS T0816-1:2010 Sterilization of health care products - Moist heat - Part 1: Requirements for the development, validation and routine control of a sterilization process for medical devices</p> <p>ISO 17665-1:2006, Sterilization of health care products - Moist heat - Part 1: Requirements for the development, validation and routine control of a sterilization process for medical devices (IDT)</p> <p>ISO 11135, Medical devices - Validation and routine control of ethylene oxide sterilization</p> <p>NOTE: At present, as the corresponding JIS or international standards, the following exist:</p> <p>JIS T0801-1:2010 Sterilization of health care products - Ethylene oxide - Part 1: Requirements for development, validation and routine control of a sterilization process for medical devices</p> <p>ISO 11135-1:2007, Sterilization of health care products - Ethylene oxide - Part 1: Requirements for development, validation and routine control of a sterilization process for medical devices (IDT)</p> <p>ISO 11137, Sterilization of health care products - Requirements for validation and routine control – Radiation Sterilization</p> <p>NOTE: At present, as the corresponding JIS or international standards, the following exist:</p> <p>JIS T0806-1:2010 Sterilization of health care products - Radiation - Part 1: Requirements for development, validation and routine control of a sterilization process for medical devices</p> <p>ISO 11137-1:2006, Sterilization of health care products - Radiation - Part 1: Requirements for development, validation and routine control of a sterilization process for medical devices (IDT)</p> <p>ISO 23529, Rubber - General procedures for preparing and conditioning test pieces for physical test methods</p> <p>NOTE: The corresponding JIS standard is JIS K6250 Rubber-General procedures for preparing and conditioning test pieces for physical test methods (MOD)</p> <p>IEC 60079-5, Explosive gas atmospheres — Part 5: Equipment protection by powder filling “q”</p> <p>IEC/TR 60083, Plugs and socket-outlets for domestic and similar general use standardized in member countries of IEC</p> | | |

| IEC 60601-1 | | | |
|-------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | <p>IEC 60086-4, Primary batteries - Part 4: Safety of lithium batteries</p> <p>NOTE: The corresponding JIS standard is JIS C8513 Safety of primary lithium batteries (MOD)</p> <p>IEC 60127-1, Miniature fuses - Part 1: Definitions for miniature fuses and general requirements for miniature fuse-links</p> <p>NOTE: The corresponding JIS standard is JIS C6575-1 Miniature fuses-Part 1: Definitions of miniature fuses and general requirements for miniature fuse-links (MOD)</p> <p>IEC 60227-1:1993, Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 1: General requirements, Amendment 1:1995 and Amendment 2:1998</p> <p>NOTE: The corresponding JIS standard is JIS C3662-1:2009 Polyvinyl chloride insulated cables of rated voltages up to and including 450/750V - Part 1: General requirements (MOD)</p> <p>IEC 60245-1:2003, Rubber insulated cables - Rated voltages up to and including 450/750 V - Part 1: General requirements</p> <p>NOTE: The corresponding JIS standard is JIS C3663-1:2007 Rubber insulated cables-Rated voltages up to and including 450/750 V-Part 1: General requirements (MOD)</p> <p>IEC 60252-1, AC motor capacitors - Part 1: General - Performance, testing and rating - Safety requirements -Guide for installation and operation</p> <p>IEC 60320-1, Appliance couplers for household and similar general purposes - Part 1: General requirements</p> <p>NOTE: The corresponding JIS standard is JIS C8283-1 Appliance couplers for household and similar general purposes-Part 1: General requirements (MOD)</p> <p>IEC 60335-1:2001, Household and similar electrical appliances - Safety - Part 1: General requirements</p> <p>NOTE: The corresponding JIS standard is JIS C9335-1:2003 Household and similar electrical appliances - Safety - Part 1 : General requirements (MOD)</p> <p>IEC 60417-DB:2002, Graphical symbols for use on equipment</p> <p>IEC 60601-1-2, Medical electrical equipment - Part 1 - 2: General requirements for basic safety and essential performance - Collateral standard:</p> | | |

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | <p>Electromagnetic compatibility - Requirements and tests</p> <p>NOTE: The current "JIS T0601-1-2:2012 Medical electrical equipment - Part 1-2: General requirements for safety - Electromagnetic compatibility - Requirements and tests" corresponds to IEC 60601-1-2:2001 and Amendment 1:2004.</p> <p>IEC 60601-1-6, Medical electrical equipment - Part 1 - 6: General requirements for basic safety and essential performance - Collateral standard: Usability</p> <p>NOTE: As the corresponding international standard, IEC 62336 is applicable.</p> <p>IEC 60601-1-8, Medical electrical equipment - Part 1 - 8: General requirements for basic safety and essential performance - Collateral standard: General requirements, tests and guidance for alarm systems in medical electrical equipment and medical electrical systems</p> <p>NOTE: The corresponding JIS standard is now under drafting.</p> <p>IEC 60730-1:1999, Automatic electrical controls for household and similar use - Part 1: General requirements, Amendment 1:2003 and Amendment 2:2007</p> <p>NOTE: The corresponding JIS standard is JIS C9730-1:2010 Automatic electrical controls for household and similar use-Part 1:General requirements (MOD)</p> <p>IEC 60851-3:1996, Winding wires - Test methods - Part 3: Mechanical properties, Amendment 1:1997 and Amendment 2:2003</p> <p>IEC 60851-5:1996, Winding wires - Test methods - Part 5: Electrical properties, Amendment 1:1997 and Amendment 2:2004</p> <p>IEC 60851-6:1996, Winding wires - Test methods - Part 6: Thermal properties and Amendment 1:1997</p> <p>IEC 60878:2003, Graphical symbols for electrical equipment in medical practice</p> <p>IEC 60884-1, Plugs and socket-outlets for household and similar purposes - Part 1: General requirements</p> <p>IEC 60950-1:2001, Information technology equipment – Safety - Part 1: General requirements</p> <p>NOTE: The corresponding JIS standard is JIS C 6950-1:2009 Information technology equipment - Safety - Part 1: General requirements (MOD)</p> | | |

| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | <p>IEC 61058-1:2000, Switches for appliances - Part 1: General requirements and Amendment 1:2001</p> <p>NOTE: The corresponding JIS standard is JIS C4526-1:2005 Switches for appliances - Part 1: General requirements (MOD)</p> <p>IEC 61558-1:1997, Safety of power transformers, power supply units and similar products - Part 1: General requirements and tests and Amendment 1:1998</p> <p>NOTE: No corresponding JIS exists. However, as the standard corresponding to IEC 61558-1:2005, the following exists:</p> <p>JIS C 61558-1:2008 Safety of power transformers, power supplies, reactors and similar products - Part 1: General requirements and tests (MOD)</p> <p>IEC 61558-2-1, Safety of power transformers, power supplies, reactors and similar products - Part 2-1: Particular requirements and tests for separating transformers and power supplies incorporating separating transformers for general applications</p> <p>NOTE: The corresponding JIS standard is JIS C61558-2-1 Safety of power transformers, power supplies, reactors and similar products-Part 2-1: Particular requirements and tests for separating transformers and power supplies incorporating separating transformers for general applications (MOD)</p> | | |
| 3.61 | <p>Add NOTE as follows:</p> <p>NOTE In this standard, MECHANICAL HAZARD is understandable suitably by replacing with mechanical HAZARD, mechanical HADARDOUS SITUATION, HARM or unacceptable RISK.</p> | | — |
| 3.70 | <p>Replace the existing text with:</p> <p>condition in which all means provided for protection against HAZARDOUS SITUATION or HAZARDS are intact</p> | | — |
| 4.2 | <p>Replace the existing NOTE 2 with the following:</p> <p>NOTE 2 Conditions or faults that can give rise to HAZARDOUS SITUATIONS are identified in the clauses of this standard. In these cases, it will often be necessary to carry out a RISK MANAGEMENT PROCESS to determine what the actual HAZARDOUS SITUATIONS are and the tests that need to be done to show that the identified HAZARDOUS SITUATIONS do not arise in the specified circumstances.</p> | | — |
| 4.10.1 | <p>In the existing text, replace “a separate power supply” with “a separate power supply (e.g., a power supply of other equipment)”.</p> | | — |

| IEC 60601-1 | | | |
|-------------|---|-----------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.3.3 | In the third paragraph, replace “could result in a HAZARD” with “could result in a HAZARDOUS SITUATION”. | | — |
| 7.4.3 | Replace the existing first paragraph with the following: Numeric indications of parameters on ME EQUIPMENT shall be expressed in SI units according to JIS Z8202 (ISO 31 (IDT)) except the base quantities listed in Table 1 may be expressed in the indicated units, which are used in conjunction with the SI units system or as the approved combination. Replace the title of Table 1 with the following: Units which are used in conjunction with the SI units system or as the approved combination | | N/A |
| 7.7.4 | Under the existing text, add the following: If polyvinyl chloride insulated flexible cord of JIS C3306 or rubber insulated flexible cord of JIS C3301 is used, the conductor may be coloured "white". | | N/A |
| 7.7.5 | Under the existing text, add the following: If polyvinyl chloride insulated flexible cord of JIS C3306 or rubber insulated flexible cord of JIS C3301 is used, conductors may be of the colour specified in the said standards. | | N/A |
| 7.9.3.2 | In the fourth dash, replace “the nature of the HAZARD” with “the HAZARDOUS SITUATION”. | | — |
| 8.4.2 | For Item c), at the end of the paragraph of “For such parts, the voltage to earth or --,” replace “at a potential up to 2 V” with “at a potential of 2 V or more”. For Item c), replace the existing NOTE with NOTE 1, and add the following new NOTE 2: NOTE 2 – The corresponding international standard specifies as “not exceed 20 J at a potential up to 2 V”. However, 1.2.8.9 of IEC 60950-1, which was quoted by the said international standard, specifies as “2 V or more”. Therefore, this JIS standard was harmonized to IEC 60950-1. | | — |
| 8.8.2 | For a), add the following NOTE: NOTE – Generally, “distance through insulation” means the thickness of insulation. However, for example, if a transformer installed into a metal case is insulated by filler, the thickness is always not uniformly. Therefore, such expression was used. | | P |
| 8.8.3 | Between the third dash and the paragraph of “Initially, not more than --”, add the following new paragraph. | | P |

| IEC 60601-1 | | | |
|-------------|--|-----------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | During the above-mentioned tests, the state of the power switch shall be kept with closed circuit. | | |
| 8.9.1.2 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.3 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.4 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.5 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.6 | At the end of the title of this sub-clause, add "(Apply to MOOP and MOPP)". | | — |
| 8.9.1.7 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.8 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.9 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.10 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.11 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.12 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.13 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.9.1.14 | At the end of the title of this sub-clause, add "(Apply to MOOP)". | | — |
| 8.11.3.2 | <p>Add the following between the first paragraph and the second paragraph: And, rubber insulated flexible cords of JIS C3301, polyvinyl chloride insulated flexible cords of JIS C3306 or cords of which the robustness is equal to or more than those are usable.</p> <p>Add the following between the second paragraph and the last paragraph: And, in the case of cords of JIS C3306, shall not use;</p> <ul style="list-style-type: none"> - for polyvinyl chloride insulated flexible cords, if the temperature of the above-mentioned external metal part exceeds 60 °C, and; - for grade heat-resistant polyvinyl chloride insulated flexible cords, if the temperature of the above-mentioned external metal part exceeds 75 °C. | | N/A |
| 9.2.2.2 | In the bottom column of Table 20, replace the existing text with the following: | | — |


| IEC 60601-1 | | | |
|-------------|--|-----------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | ^a The values in this table are taken from JIS B9711 (ISO 13854 (IDT)). | | |
| 9.2.2.4.4 | In the second dash, replace “no HAZARD or damage shall result” with “any HAZARDOUS SITUATION or unacceptable RISK shall result”. | | — |
| 9.2.4 | In e), replace “no HAZARD or damage shall result” with “no HAZARDOUS SITUATION or unacceptable RISK shall result”. | | — |
| 9.4.4 | In the first paragraph of a), replace “and no HAZARDS can develop” with “and no HAZARDOUS SITUATION can develop”. | | — |
| 9.7.5 | In the last paragraph, delete “unmarked”. | | — |
| 9.8.4.1 | Replace the existing NOTE with the following: NOTE The upper carriage of the human body test mass apparatus is formed of wood or a similar material. The bottom portion is foam. The resiliency or spring factor of the foam (ILD or IFD ratings) has not been specified. The foam is cylindrical, rather than spherical. | | N/A |
| 10.1.1 | In the paragraph, replace “0,5 mR/h” with “0,5 mR/h \approx 5 μ Gy/h”; and in NOTE 2, “0,1 mR/h” with “0,5 mR/h \approx 1 μ Gy/h”. | | N/A |
| 11.1.1 | To the existing text of a in the Table 22, add the following: (For example, the maximum temperature limit of a transformer with three insulating materials of Class A, Class B and Class E shall be 105 °C of Class A of the lowest limit.) | | P |
| 13.2.7 | In the title of this sub-clause, replace “in a HAZARD” with “in a HAZARDOUS SITUATION”. | | — |
| 13.2.10 | In Table 26, replace the existing NOTE with the following: NOTE The temperature limits in this table were derived from Table B.1 of IEC 60950-1:2001 (in the corresponding international standard, IEC 61010-1:2001 [22]). | | — |
| 15.4.2.1 | In c), replace “could constitute a HAZARD” with “could constitute a HAZARDOUS SITUATION”. | | — |
| 15.4.3.4 | In the first paragraph, replace “could become a HAZARD” with “could become a HAZARDOUS SITUATION”. | | — |
| 16.1 | Replace the last two paragraphs with the following: Otherwise, non-medical equipment shall be those which are in compliance with relevant JIS standards or the Technical Requirements of the Electrical Appliance and Material Safety Act or which ensure safety equivalent to the said standards/technical requirements. | | N/A |

| IEC 60601-1 | | | |
|--------------|--|-----------------|------------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | <p>Equipment in which protection against electric shock relies only on BASIC INSULATION shall not be used in an ME SYSTEM.</p> <p>For the measures for ensuring safety, e.g., the case combined with a separating transformer with DOUBLE INSULATION or REINFORCED INSULATION, equipment only with BASIC INSULATION may be used.</p> <p>Compliance is checked by inspection of appropriate documents or certificates.</p> | | |
| 16.6.4.1 | In NOTE, replace "no possibility of any HAZARD" with "no possibility of any HAZARDOUS SITUATION". | | — |
| Annex D | <p>In Table D.2, replace the sign of No. 10, which is shown as "IEC 60878 Safety 01 b", with the sign of "ISO 7010-M002 b".</p> <p>In the bottom column of Table D.2, replace the existing a and b with the following:</p> <p>a The description of this commonly used safety sign appeared in Annex B of ISO 3864:1984.</p> <p>b In accordance with the corrigendum of IEC 60601-1, Replaced "IEC 60878 Safety 01 " with "ISO 7010-M002</p> | | N/A |
| Annex I | <p>In 1.1.3, replace the first dash with the following:</p> <p>- PATIENTS should only be connected to APPLIED PARTS of ME EQUIPMENT complying with this standard. Other equipment should comply with relevant IEC or ISO standards or comply with relevant JIS safety standards or the Technical Requirements of the Electrical Appliance and Material Safety Act, or ensure safety equivalent to the said standards/technical requirements.</p> <p>Replace the existing NOTE 2 with the following:</p> <p>NOTE 2 IEC 60601: MEDICAL ELECTRICAL EQUIPMENT in compliance with IEC 60601 (all parts) or JIS T0601 (all parts).</p> <p>Replace the existing NOTE 3 with the following:</p> <p>NOTE 3 IEC xxxxx: Non-medical equipment in compliance with relevant IEC safety standards. Include non-medical equipment in compliance with relevant JIS safety standards or the Technical Requirements of the Electrical Appliance and Material Safety Act, or non-medical equipment ensuring safety equivalent to the said standards/technical requirements.</p> | | N/A |
| Annex L | In the text of c), replace "IEC 60884-1" with "IEC 60884-1 or JIS C8282-1". | | — |
| Bibliography | Add the following at the end: [55] JIS T1021, "Hospital grade" outlet-sockets | | — |


| IEC 60601-1 | | | |
|-------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | and plugs [56] JIS Q13485, Medical devices - Quality management systems - Requirements for regulatory purposes | | |

Photo


External view for open frame models




External view for open frame models




External view for L frame models




External view for L frame models



External view for cage models




External view for cage models




External view for potted models




External view for potted models




Internal view for potted models




Internal view for potted models




External view for open frame models



External view for open frame models




Transformer view




Transformer view



Transformer view




Transformer view



Transformer view



Transformer view



Transformer view



Transformer view



Transformer view




Transformer view



Transformer view



Transformer view



Transformer view




Transformer view




Transformer view




Transformer view




Transformer view



Transformer view




Transformer view




Transformer view




Transformer view




Transformer view



Transformer view



Transformer view



Transformer view



Transformer view

